



Date: April 10, 2017

To: To all interested parties on the subject
of **225A Bus Ratings for Square D CSED's**

From: Cedric Short
Offer Manager – Metering
Schneider Electric
1010 Airpark Center Drive
Nashville, Tennessee 37217
Ph: 615-844-8540

Re: Square D CSED products.

LETTER OF CERTIFICATION

Schneider Electric is committed to providing our customers with electrical equipment that complies with the latest national standards including the National Electrical Code (NEC®); and other local and regional standards such as California Title 24 and EUSERC.

The following Commercial References have been tested and validated to carry an internal bus current rating of **225A**. Labels and drawings have been updated to reflect the change.

This self certification letter **DOES NOT SUPPORT the replacement of the Main Breaker above 200A**. The commercial references covered by this letter are as follows:

SC2040M200PS	SC816F200PS
SC42M200PS	SC42M200PSH
SC3042M200PS	SC2040M200PF
SC2040M200PS100	SC3042M200PF
SC2040M200PS125	SC3042M225PF
SC2040M200PS150	SC816F200PF
SC816F150PS	SC2040M125PF

Regards,

Cedric Short
Offer Manager – Metering and CSED's
Final Distribution North America
Ph: 615-844-8540