

CERTIFICATE OF COMPLIANCE

Certificate Number 20180529-E497830
Report Reference E497830-20180525
Issue Date 2018-MAY-29

Issued to: Schneider Electric Industries SAS
35 Rue Joseph Monier
92500 Rueil Malmaison FRANCE

**This is to certify that
representative samples of**

EMERGENCY STOP DEVICES FOR USE IN
HAZARDOUS LOCATIONS, EMERGENCY STOP
DEVICES FOR USE IN ZONE CLASSIFIED HAZARDOUS
LOCATIONS

See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

See Addendum Page

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.



CERTIFICATE OF COMPLIANCE

Certificate Number 20180529-E497830
Report Reference E497830-20180525
Issue Date 2018-MAY-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product

PRODUCT COVERED:

Emergency stop Metallic Push button assemblies (22 mm line) Cat. No. XB4B followed by S, followed by 8, followed by 4, followed by 4, followed by 5, followed by GEX
for use in Class I, Zone 1, AEx db eb IIC;
Zone 21, AEx tb IIIC;
Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.

Emergency stop Metallic Push button assemblies (22 mm line) Cat. No. XB4B followed by S, followed by 9, followed by 4, followed by 4, followed by 5, followed by GEX
for use in Class I, Zone 1, AEx db eb IIB;
Zone 21, AEx tb IIIC;
Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.

Emergency stop Metallic Push button assemblies (22 mm line) Cat. No. XB4B followed by T, followed by 8, followed by 4, followed by 5, followed by GEX
for use in Class I, Zone 1, AEx db eb IIC;
Zone 21, AEx tb IIIC;
Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.

Emergency stop Metallic Push button assemblies (22 mm line) Cat. No. XB4B followed by S, followed by 8, followed by 4, followed by 4, followed by 5, followed by GEX
for use in Zone 1, Ex db eb IIC;
Zone 21, Ex tb IIIC;
Class I, Division 2, Group A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.

Emergency stop Metallic Push button assemblies (22 mm line) Cat. No. XB4B followed by S, followed by 9, followed by 4, followed by 4, followed by 5, followed by GEX
for use in Zone 1, Ex db eb IIB;
Zone 21, Ex tb IIIC;
Class I, Division 2, Group A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.



CERTIFICATE OF COMPLIANCE

Certificate Number 20180529-E497830
Report Reference E497830-20180525
Issue Date 2018-MAY-29

Emergency stop Metallic Push button assemblies (22 mm line) Cat. No. XB4B followed by T, followed by 8, followed by 4, followed by 5, followed by GEX for use in Zone 1, Ex db eb IIC; Zone 21, Ex tb IIIC; Class I, Division 2, Group A, B, C and D; Class II, Division 2, Groups F and G; Class III, Division 1 and 2 Hazardous Locations.

Standards:

UL 50E Enclosures for Electrical Equipment, Environmental Considerations – Edition 2 – Issue Date 2015/10/16

UL 508, Standard for industrial control equipment - Edition 17 - Revision Date 2013/10/16

IEC 60947-5-5, Standard for Low-voltage Switchgear and Controlgear part 5-5 for Control circuit devices and switching elements – electrical emergency stop device with mechanical latching function – Edition 1.1 – Dated April 1, 2005

UL 60079-0, 6th Edition, Explosive atmospheres - Part 0: Equipment - General requirements, Revision Date 2017/10/20

UL 60079-1, 7th Edition, Explosive Atmospheres - Part 1: Equipment Protection by Flameproof Enclosures “d”, Issue Date 2015/09/18

UL 60079-7, 5th Edition, Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety “e”, Revision Date 2017/04/21

UL 121201, 9th Edition, Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations - Issue Date 2017/09/15

CSA C22.2 No. 94-2 Enclosures for Electrical Equipment, Environmental Considerations - Edition 2 - Issue Date 2015/10/16

CSA C22.2 NO. 14-13 Industrial control equipment - Edition 12 - Issue Date 2013/03/01

IEC 60947-5-5, Standard for Low-voltage Switchgear and Controlgear part 5-5 for Control circuit devices and switching elements – electrical emergency stop device with mechanical latching function – Edition 1.1 – Dated April 1, 2005

CSA C22.2 No. 60079-0:15, Explosive atmospheres - Part 0: Equipment - General requirements – Edition 3 – Issue Date 2017/10/20

CSA C22.2 No. 60079-1:16, Explosive Atmospheres - Part 1: Equipment Protection by Flameproof Enclosures “d” – Edition 3 – Issue Date 2016/05/01

CSA C22.2 No. 60079-7:16, Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety “e” - Edition 2 – Issue Date 2016/10/01

CSA C22.2 No.213-17, Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations – Issue Date 2017/09/15



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.

