



NOTE: WHEN INSTALLED AT 1600A, THIS TAP BOX MUST BE CENTER MOUNTED WITH BRANCH UNITS CONNECTED TO BOTH SIDES OF THIS MAIN DEVICE. IF INSTALLED AT 1200A, CAPACITY THIS TAP BOX MUST BE CENTER MOUNTED WHEN USED WITH BRANCH UNITS SUPPLIED WITH 800A HORIZONTAL CROSS BUS.

DUAL DIMENSIONS:

SYSTEM TYPE	MAIN RATING (AMPERES)	CATALOG NUMBER *	LINE PHASE AND NEUTRAL LUG WIRE RANGE FOR AL OR CU CONDUCTORS (FACTORY INSTALLED)	GROUND LUG WIRE RANGE (FACTORY INSTALLED)
1Ø 3W 120/240VAC	1600	E2M1600TB	(6) 1/0-600 OR (12) 1/0 - 300	(1) #6-300

*SERIES M03

NOTES: FINISH - GRAY BAKED ENAMEL POWDER COAT PAINT OVER CLEANED GALVANNEAL STEEL.
[36/]
U LISTED - FILE-10582 VOL. M E131840 VOL. M.
SUITABLE FOR USE ON THE LINE SIDE OF SERVICE EQUIPMENT.
MAIN HORIZONTAL CROSS BUS RATED AT 1200 AMPERES.
MAIN DEVICES ARE SEALABLE BY UTILITY.
GANGABLE MULTI-METERING EQUIPMENT IS DESIGNED FOR WALL MOUNTING ONLY.
(NOT SUITABLE FOR FLOOR STANDING EQUIPMENT).



SQUARE D
Schneider Electric

DWG# 3373
NO.

F7M11600TB

SEPTEMBER 2006