



PRODUCT OBSOLESCENCE: PowerPacT H-, J-, L-Frame Undervoltage Release and Shunt Trip Coils (06/10/22)

PowerPacT H-, J-, L-Frame Undervoltage Release (UVR) and Shunt Trip (S/T) accessories will transition from the current screw terminal to a spring clamp terminal. This product will also undergo a visual update.

The hard transition to factory-installed UVR and Shunt Trip will launch the week of June 10, 2022.

- The connection type will change from screw to spring clamp (a/k/a screwless or cage clamp).
- No change to factory-installed suffix codes. One-time transition from screw to spring clamp terminal. **Refer to page 4 for additional detail.**
- New commercial references for field-installable accessories. The 'S' prefix will transition to 'P'. The five numbers following the prefix will not change. **Refer to page 5 for additional detail.**
 - *Example : S29382 will transition to P29382*
- Simplified content layout on the product label.
- Product label will transition from white to black.
- Select plastics will transition from light gray to black.
- No change to flammability performance (V-0), listings, or certifications.
- Wire type and size.

No change to PowerPacT auxiliary contacts (S29450 or S29452); they will remain with the screw terminal.