

Danfoss Thermostat

Air

24.3°C ↘21.5

+

Floor

24.3°C ↘21.5

-



Settings "Danfoss Thermostat" ✕

General Objects Styles

Air temperature *

32/1/25 (DPT 9) ✕ ▼

Floor temperature *

32/1/25 (DPT 9) ✕ ▼

Air temperature setpoint input

32/1/25 (DPT 9) ✕ ▼

Air temperature setpoint output

32/1/25 (DPT 9) ✕ ▼

Floor temperature setpoint output

32/1/25 (DPT 9) ✕ ▼

Operation mode

32/1/21 (DPT 5) ✕ ▼

Thermostat status, alert

32/1/21 (DPT 5) ✕ ▼

Air hysteresis (+-0,1 to 3 degrees)

32/1/25 (DPT 9) ✕ ▼

Device status object

32/1/17 (DPT 1) ✕ ▼

⬆ From JSON

⬇ Download JSON

Cancel

Save