
Declaracion de conformidad Declaration of Conformity

Reference: PP_LVS_53_01

Fecha: 11 de Marzo, 2015

Productos: **Sistema funcional Prisma**

Referencia: **norma internacional IEC 61439-1 - § 8.4.3.2.2**

Declaración: **No es necesario instalar el cable de tierra en la puerta cuando no este equipada de aparamenta. Muestras referentes a los productos mencionados anteriormente, montados con una puerta sin cable de tierra y sin aparamenta, han sido ensayados y están conforme al estándar internacional referido.**

Product: **Prisma functional system**

Reference: **international standard IEC 61439-1 - § 8.4.3.2.2**

Declaration: **It's not necessary to install earth wire on the door when not equipped with devices. Samples of the above mentioned products, fitted with door without earth wire and devices, have been tested and found to be in conformity with the international standard referenced.**



Eric Bouvier
Director of Customer Satisfaction & Quality department
Partner Projects
Busways, Enclosures, Equipments Line of Business