

PowerLogic PM8000 DNP 3.0 device profile

This document describes the DNP V3.0 communications protocol employed by PowerLogic™ PM8000 meters. The DNP protocol can be selected for the following:

- the RS-485 serial communication port
- up to three Ethernet connections.

A maximum of three ports/connections in total may be used at the same time.

It is assumed that the reader is familiar with the DNP V3.00 protocol and serial communications in general.

In this document

Safety information	2
Important information.....	2
Please note.....	2
Safety precautions	3
1. DNP device profile	4
1.1 Implementation table.....	10
2. Time synchronization information	15
2.1 Time Sync Request Configuration	15
2.2 Configuring DNP communications port to accept time synchronization.....	15
3. PM8000 default DNP configuration	16
4. Details on customizing DNP v3.0 configuration	17
4.1 Customizing the DNP Point map	17
4.2 Report-by-exception processing (DNP Events)	17
4.3 Control Relay Output Block.....	18
4.4 Freezing Binary Counter Points	18
4.5 Scaling.....	18
4.6 Assigning ION DNP Slave Options Modules to Meter Communication Ports	19
5. Glossary of terms	20
6. List of acronyms and abbreviations	20

Safety information

Important information



Read these instructions carefully and look at the equipment to become familiar with the device before trying to install, operate, service or maintain it. The following special messages may appear throughout this manual or on the equipment to warn of potential hazards or to call attention to information that clarifies or simplifies a procedure.

The addition of either symbol to a “Danger” or “Warning” safety label indicates that an electrical hazard exists which will result in personal injury if the instructions are not followed.

This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages that follow this symbol to avoid possible injury or death.

DANGER

DANGER indicates a hazardous situation which, if not avoided, **will result in** death or serious injury.

WARNING

WARNING indicates a hazardous situation which, if not avoided, **can result in** death or serious injury.

CAUTION

CAUTION indicates a potentially hazardous situation which, if not avoided, **can result in** minor or moderate injury.

NOTICE

Notice is used to address practices not related to physical injury. The safety alert symbol shall not be used with this signal word.

Please note

Electrical equipment should be installed, operated, serviced and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction, installation, and operation of electrical equipment and has received safety training to recognize and avoid the hazards involved.

Safety precautions

Installation, wiring, testing and service must be performed in accordance with all local and national electrical codes

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Apply appropriate personal protective equipment (PPE) and follow safe electrical work practices. See NFPA 70E in the USA, CSA Z462 or applicable local standards.
- Turn off all power supplying this device and the equipment in which it is installed before working on the device or equipment.
- Always use a properly rated voltage sensing device to confirm power is off.
- Do not exceed the device's ratings for maximum limits.
- Do not use the device for critical control or protection applications where human or equipment safety relies on the operation of the control circuit.
- Incorrectly configured ION modules may render the meter non-functional. Do not modify a module's configuration without understanding the impact to the meter and any associated devices.

Failure to follow these instructions will result in death or serious injury.

1.DNP device profile

DNP V3.0	
DEVICE PROFILE DOCUMENT	
Vendor Name: Power Measurement Ltd	
Device Name: PM8000	
Highest DNP Level Supported:	Device Function:
For Requests: Level 2 For Responses: Level 2	<input type="checkbox"/> Master <input checked="" type="checkbox"/> Slave
<p>Notable objects, functions, and/or qualifiers supported in addition to the Highest DNP Levels Supported (the complete list is described in the attached table):</p> <p>For static (non-change-event) object requests, request qualifier codes 07 and 08 (limited quantity), and 17 and 28 (index) are supported. Static object requests sent with qualifiers 07, or 08, will be responded with qualifiers 00 or 01.</p> <p>16-bit, 32-bit and Floating Point Analog Change Events with Time may be requested. 16-bit, 32-bit Frozen Analog Input and Frozen Analog Events with and without Time may be requested. Floating Point Analog Output Status and Output Block Objects 40 are supported.</p>	
Maximum Data Link Frame Size (octets):	Maximum Application Fragment Size (octets):
Transmitted: 292 Received 292	Transmitted: Configurable 50 to 2048 Received 2048
Maximum Data Link Re-tries:	Maximum Application Layer Re-tries:
<input type="checkbox"/> None <input type="checkbox"/> Fixed <input checked="" type="checkbox"/> Configurable from 0 to 15	<input checked="" type="checkbox"/> None <input type="checkbox"/> Configurable
Requires Data Link Layer Confirmation:	
<input type="checkbox"/> Never <input type="checkbox"/> Always <input type="checkbox"/> Sometimes <input checked="" type="checkbox"/> Configurable as: Never, Only for multi-frame messages, or Always	
Requires Application Layer Confirmation:	
<input type="checkbox"/> Never <input type="checkbox"/> Always <input type="checkbox"/> When reporting Event Data (Slave devices only) <input type="checkbox"/> When sending multi-fragment responses (Slave devices only) <input type="checkbox"/> Sometimes <input checked="" type="checkbox"/> Configurable as: "Only when reporting event data", or "When reporting event data or multi-fragment messages."	

DNP V3.0

DEVICE PROFILE DOCUMENT

Timeouts while waiting for:

- Data Link Confirm: None Fixed at _____ Variable **Configurable.**
- Complete Appl. Fragment: **None** Fixed at _____ Variable Configurable
- Application Confirm: None **Fixed at 10s** Variable Configurable.
- Complete Appl. Response: **None** Fixed at _____ Variable Configurable

Others: Transmission Delay, configurable

- Select/Operate Arm Timeout, configurable 0 sec to 30 sec
- Need Time Interval, configurable 1 sec to 86400 sec (1 day)
- Data Link Confirm Timeout, configurable 0.1 sec to 30 sec
- Unsolicited Notification Delay, random value between 1 and 10 sec
- Unsolicited Response Retry Delay, configurable 1 sec to 7200 sec (2 hours)
- Unsolicited Max Number of Retries, configurable 0 to 100, 0 is infinite retries
- Binary Change Event Scan Period, fixed at 1 sec
- Analog Change Event Scan Period, fixed at 1 sec
- Counter Change Event Scan Period, fixed at 1 sec
- Frozen Counter Change Event Scan Period, fixed at 1 sec
- Analog Change Event Scan Period, fixed at 1 sec
- Frozen Analog Change Event Scan Period, fixed at 1 sec

Sends/Executes Control Operations:

- | | | | | |
|-------------------------|--|---|------------------------------------|---------------------------------------|
| WRITE Binary Outputs | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| SELECT/OPERATE | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| DIRECT OPERATE | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| DIRECT OPERATE – NO ACK | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Count > 1 | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Pulse On | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Pulse Off | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Latch On | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Latch Off | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Queue | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Clear Queue | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |

Attach explanation if 'Sometimes' or 'Configurable' was checked for any operation.

Reports Binary Input Change Events when no specific variation requested:

- Never
- Only time-tagged
- Only non-time-tagged
- Configurable to send time-tagged or non-time-tagged**

Reports time-tagged Binary Input Change Events when no specific variation requested:

- Never
- Binary Input Change With Time
- Binary Input Change With Relative Time
- Configurable to Binary Input Change With Time and Binary Input Change With Relative Time**

<h1 style="margin: 0;">DNP V3.0</h1> <h2 style="margin: 0; text-align: center;">DEVICE PROFILE DOCUMENT</h2>																						
<p>Sends Unsolicited Responses:</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> Never <input type="checkbox"/> Configurable – enable/disable <input type="checkbox"/> Only certain objects <input type="checkbox"/> Sometimes (attach explanation) <input type="checkbox"/> ENABLE/DISABLE UNSOLICITED Function codes supported 	<p>Sends Static Data in Unsolicited Responses:</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> Never <input type="checkbox"/> When Device Restarts <input type="checkbox"/> When Status Flags Change <p>No other options are permitted.</p>																					
<p>Default Counter Object/Variation:</p> <ul style="list-style-type: none"> <input type="checkbox"/> No Counters Reported <input checked="" type="checkbox"/> Configurable <input type="checkbox"/> Default Object Default Variation: <input type="checkbox"/> Point-by-point list attached 	<p>Counters Roll Over at:</p> <ul style="list-style-type: none"> <input type="checkbox"/> No Counters Reported <input checked="" type="checkbox"/> Configurable – controlled partly by rollover configured in input ION modules. See the <i>Multiport DNP 3.0 and ION Technology</i> technical note. <input type="checkbox"/> 16 Bits <input type="checkbox"/> 32 Bits <input type="checkbox"/> Other Value: _____ <input type="checkbox"/> Point-by-point list attached 																					
<p>Sends Multi-Fragment Responses:</p> <ul style="list-style-type: none"> <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Configurable – “Always” or “When reporting Event Data” 																						
<p style="text-align: center;">Sequential File Transfer Support:</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 30%;">Append File Mode</td> <td style="width: 15%;"><input type="checkbox"/> Yes</td> <td style="width: 15%;"><input checked="" type="checkbox"/> No</td> </tr> <tr> <td>Custom Status Code Strings</td> <td><input type="checkbox"/> Yes</td> <td><input checked="" type="checkbox"/> No</td> </tr> <tr> <td>Permissions Field</td> <td><input type="checkbox"/> Yes</td> <td><input checked="" type="checkbox"/> No</td> </tr> <tr> <td>File Events Assigned to Class</td> <td><input type="checkbox"/> Yes</td> <td><input checked="" type="checkbox"/> No</td> </tr> <tr> <td>File Events Send Immediately</td> <td><input type="checkbox"/> Yes</td> <td><input checked="" type="checkbox"/> No</td> </tr> <tr> <td>Multiple Blocks in a Fragment</td> <td><input type="checkbox"/> Yes</td> <td><input checked="" type="checkbox"/> No</td> </tr> <tr> <td>Max Number of Files Open</td> <td>0</td> <td></td> </tr> </table>		Append File Mode	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Custom Status Code Strings	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Permissions Field	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	File Events Assigned to Class	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	File Events Send Immediately	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Multiple Blocks in a Fragment	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Max Number of Files Open	0	
Append File Mode	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No																				
Custom Status Code Strings	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No																				
Permissions Field	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No																				
File Events Assigned to Class	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No																				
File Events Send Immediately	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No																				
Multiple Blocks in a Fragment	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No																				
Max Number of Files Open	0																					

Requires Data Link Layer Confirmation:

- Never
- Always
- Sometimes If 'Sometimes', when? _____

Configurable If 'Configurable', how?

User option to set Data Link Confirmation to:

- **Always** – device will always request Data Link Confirmations.
- **Multi-packet only** – the device will request Data Link Confirmations when sending multi-packet responses.
- **Never** – the device will never request Data Link Confirmations.

Requires Application Layer Confirmation:

- Never
- Always (not recommended)
- When reporting Event Data (Slave devices only)
- When sending multifragment responses (Slave devices only)

- Sometimes If 'Sometimes', when? _____

- Configurable If 'Configurable', how? _____

Timeouts while waiting for:

- | | | | | |
|-------------------------|--|--------------------------------------|-----------------------------------|--|
| Data Link Confirm | <input type="checkbox"/> None | <input type="checkbox"/> Fixed at __ | <input type="checkbox"/> Variable | <input checked="" type="checkbox"/> Configurable |
| Complete Appl. Fragment | <input checked="" type="checkbox"/> None | <input type="checkbox"/> Fixed at __ | <input type="checkbox"/> Variable | <input type="checkbox"/> Configurable |
| Application Confirm | <input checked="" type="checkbox"/> None | <input type="checkbox"/> Fixed at __ | <input type="checkbox"/> Variable | <input type="checkbox"/> Configurable |
| Complete Appl. Response | <input checked="" type="checkbox"/> None | <input type="checkbox"/> Fixed at __ | <input type="checkbox"/> Variable | <input type="checkbox"/> Configurable |

Others _____

Attach explanation if 'Variable' or 'Configurable' was checked for any timeout

- **Data Link Confirm timeout** is configurable: 0.1s to 30s

Sends/Executes Control Operations:

- | | | | | |
|-------------------------|---|--|------------------------------------|---------------------------------------|
| WRITE Binary Outputs | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| SELECT/OPERATE | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| DIRECT OPERATE | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| DIRECT OPERATE - NO ACK | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Count > 1 | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Pulse On | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Pulse Off | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Latch On | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Latch Off | <input type="checkbox"/> Never | <input checked="" type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Queue | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |
| Clear Queue | <input checked="" type="checkbox"/> Never | <input type="checkbox"/> Always | <input type="checkbox"/> Sometimes | <input type="checkbox"/> Configurable |

- **Select timeout** period is configurable: 0s to 30s

FILL OUT THE FOLLOWING ITEMS FOR SLAVE DEVICES ONLY:

Reports Binary Input Change Events when no specific variation requested:

- Never
- Only time-tagged
- Only non-time-tagged
- Configurable to send both, one or the other (explanation below)

User option to have all Binary Input Change Events returned as either:

- time-tagged OR
- non-time-tagged

Reports time-tagged Binary Input Change Events when no specific variation requested:

- Never
- Binary Input Change With Time
- Binary Input Change With Relative Time
- Configurable (attach explanation)

Sends Unsolicited Responses:

- Never
- Configurable (attach explanation)
- Only certain objects
- Sometimes (attach explanation)
- ENABLE/DISABLE UNSOLICITED Function codes supported

Sends Static Data in Unsolicited Responses:


- Never
- When Device Restarts
- When Status Flags Change

No other options are permitted.

<p>Default Counter Object/Variation:</p> <p><input type="checkbox"/> No Counters Reported <input checked="" type="checkbox"/> Configurable (explanation below) <input type="checkbox"/> Default Object _____ Default Variation _____ <input type="checkbox"/> Pointby-point list attached</p> <p>User option to return all static counters in one of the following variations:</p> <ul style="list-style-type: none">• 32-Bit Binary Counter• 32-Bit Binary Counter Without Flag• 16-Bit Binary Counter• 16-Bit Binary Counter Without Flag	<p>Counters Roll Over at:</p> <p><input type="checkbox"/> No Counters Reported <input checked="" type="checkbox"/> Configurable (explanation below) <input type="checkbox"/> 16 Bits <input type="checkbox"/> 32 Bits <input type="checkbox"/> Other Value _____ <input type="checkbox"/> Pointby-point list attached</p> <p>User option to select roll over:</p> <ul style="list-style-type: none">• 32 bit counters roll over at 2^{32}.• 16 bit counters roll over at 2^{16}
<p>Sends Multi-Fragment Responses: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>	

1.1 Implementation table

Level 2 Implementation (DNP-L2)

 WARNING

HAZARD OF UNINTENDED OPERATION

- Do not use the meter for critical control or protection applications where human or equipment safety relies on the operation of the control circuit.
- Be aware that an unexpected change of state of the digital outputs may result when the supply power to the meter is interrupted or after a meter firmware or template upgrade.

Failure to follow these instructions can result in death or serious injury.

OBJECT			REQUEST <small>(slave must parse)</small>		RESPONSE <small>(master must parse)</small>	
Obj	Var	Description	Func Codes (dec)	Qual Codes (hex)	Func Codes	Qual Codes (hex)
1	0	Binary Input - Any Variation	1	00,01,06,07,08,17,28		
1	1	Binary Input	1	00,01,06,07,08,17,28	129	00,01,17,28
1	2	Binary Input with Status	1	00,01,06,07,08,17,28	129	00,01,17,28
2	0	Binary Input Change - All Variations	1	06,07,08		
2	1	Binary Input Change without Time	1	06,07,08	129	17,28
2	2	Binary Input Change with Time	1	06,07,08	129	17,28
2	3	Binary Input Change with Relative Time	1	06,07,08	129	17,28
10	0	Binary Output – always mapped to variation 2				
10	1	Binary Output	1	00,01,06,07,08,17,28	129	00,01,17,28
10	2	Binary Output Status	1	00,01,06,07,08,17,28	129	00,01,17,28
12	1	Control Relay Output Block	3,4,5,6	17,28	129	echo of request
12	2	Pattern Control Block				
12	3	Pattern Mask				

OBJECT			REQUEST (slave must parse)		RESPONSE (master must parse)	
Obj	Var	Description	Func Codes (dec)	Qual Codes (hex)	Func Codes	Qual Codes (hex)
20	0	Binary Counter - Any Variation	1	00,01,06,07,08, 17,28		
			7,8	00,01,06,07,08		
20	1	32-Bit Binary Counter	1	00,01,06,07,08, 17,28	129	00,01,17,28
20	2	16-Bit Binary Counter	1	00,01,06,07,08, 17,28	129	00,01,17,28
20	5	32-Bit Binary Counter without Flag	1	00,01,06,07,08, 17,28	129	00,01,17,28
21	0	Frozen Counter - Any Variation	1	00,01,06,07,08, 17,28		
21	1	32-Bit Frozen Counter	1	00,01,06,07,08, 17,28	129	00,01,17,28
21	2	16-Bit Frozen Counter	1	00,01,06,07,08, 17,28	129	00,01,17,28
21	5	32-Bit Frozen Counter with Time of Freeze	1	00,01,06	129	00,01,17,28
21	6	16-Bit Frozen Counter with Time of Freeze	1	00,01,06	129	00,01,17,28
21	9	32-Bit Frozen Counter without Flag	1	00,01,06	129	00,01,17,28
21	10	16-Bit Frozen Counter without Flag	1	00,01,06	129	00,01,17,28
22	0	Counter Change Event - Any Variation	1	06,07,08		
22	1	32-Bit Counter Change Event without Time	1	06,07,08	129	17,28
22	2	16-Bit Counter Change Event without Time	1	06,07,08	129	17,28
22	5	32-Bit Counter Change Event with Time	1	06,07,08	129	17,28
22	6	16-Bit Counter Change Event with Time	1	06,07,08	129	17,28
23	0	Frozen Counter Event - Any Variation	1	06,07,08		
23	1	32-Bit Frozen Counter Event without Time	1	06,07,08	129	17,28
23	2	16-Bit Frozen Counter Event without Time	1	06,07,08	129	17,28
23	5	32-Bit Frozen Counter Event with Time	1	06,07,08	129	17,28
23	6	16-Bit Frozen Counter Event with Time	1	06,07,08	129	17,28

¹ The device can be configured to respond with the object/variations marked with “***”. Note that these object/variations are not listed in the DNP V3.00 Subset 2 definitions. If the meter is configured to respond with these objects care must be taken to ensure that the master can parse the response.

OBJECT			REQUEST (slave must parse)		RESPONSE (master must parse)		
Obj	Var	Description	Func Codes (dec)	Qual Codes (hex)	Func Codes	Qual Codes (hex)	
30	0	Analog Input - Any Variation	1,7,8	00,01,06,07,08,17,28			
30	1	32-Bit Analog Input	1	00,01,06,07,08,17,28	129	00,01,17,28	
30	2	16-Bit Analog Input	1	00,01,06,07,08,17,28	129	00,01,17,28	
30	3	32-Bit Analog Input without Flag	1	00,01,06,07,08,17,28	129	00,01,17,28	
30	4	16-Bit Analog Input without Flag	1	00,01,06,07,08,17,28	129	00,01,17,28	
30	5	Short Floating Point	1	00,01,06,07,08,17,28	129	00,01,17,28	**
30	6	Long Floating Point	1	00,01,06,07,08,17,28	129	00,01,17,28	**
31	0	Frozen Analog Input - Any Variation	1	00,01,06,07,08,17,28			**
31	1	32-Bit Frozen Analog Input	1	00,01,06,07,08,17,28	129	00,01,17,28	**
31	2	16-Bit Frozen Analog Input	1	00,01,06,07,08,17,28	129	00,01,17,28	**
31	3	32-Bit Frozen Analog Input with Time of Freeze	1	00,01,06,07,08,17,28	129	00,01,17,28	**
31	4	16-Bit Frozen Analog Input with Time of Freeze	1	00,01,06,07,08,17,28	129	00,01,17,28	**
31	5	32-Bit Frozen Analog Input without Flag	1	00,01,06,07,08,17,28	129	00,01,17,28	**
31	6	16-Bit Frozen Analog Input without Flag	1	00,01,06,07,08,17,28	129	00,01,17,28	**
32	0	Analog Change Event - Any Variation	1	06,07,08			
32	1	32-Bit Analog Change Event without Time	1	06,07,08	129	17,28	
32	2	16-Bit Analog Change Event without Time	1	06,07,08	129	17,28	
32	3	32-Bit Analog Change Event with Time	1	06,07,08	129	17,28	**
32	4	16-Bit Analog Change Event with Time	1	06,07,08	129	17,28	**
32	5	Short Floating Point Analog Change Event without Time	1	06,07,08	129	17,28	**

OBJECT			REQUEST (slave must parse)		RESPONSE (master must parse)		
Obj	Var	Description	Func Codes (dec)	Qual Codes (hex)	Func Codes	Qual Codes (hex)	
32	6	Long Floating Point Analog Change Event without Time	1	06,07,08	129	17,28	**
32	7	Short Floating Point Analog Change Event with Time	1	06,07,08	129	17,28	**
32	8	Long Floating Point Analog Change Event with Time	1	06,07,08	129	17,28	**
33	0	Frozen Analog Event - Any Variation	1	06,07,08	129	17,28	**
33	1	32-Bit Frozen Analog Event without Time	1	06,07,08	129	17,28	**
33	2	16-Bit Frozen Analog Event without Time	1	06,07,08	129	17,28	**
33	3	32-Bit Frozen Analog Event with Time	1	06,07,08	129	17,28	**
33	4	16-Bit Frozen Analog Event with Time	1	06,07,08	129	17,28	**
40	0	Analog Output Status – Any Variation	1	00,01,06,07,08, 17,28			
40	1	32-Bit Analog Output Status	1	00,01,06,07,08, 17,28	129	00,01,17,28	**
40	2	16-Bit Analog Output Status	1	00,01,06,07,08, 17,28	129	00,01,17,28	
40	3	Short Floating Point Analog Output Status	1	00,01,06,07,08, 17,28	129	00,01,17,28	**
40	4	Long Floating Point Analog Output Status	1	00,01,06,07,08, 17,28	129	00,01,17,28	**
41	0	Analog Output Block - Any Variation					
41	1	32-Bit Analog Output Block	3,4,5,6	17,28	129	echo of request	**
41	2	16-Bit Analog Output Block	3,4,5,6	17,28	129	echo of request	
41	3	Short Floating Point Analog Output Block	3,4,5,6	17,28	129	echo of request	**
41	4	Long Floating Point Analog Output Block	3,4,5,6	17,28	129	echo of request	**
50	0	Time and Date - Any Variation					
50	1	Time and Date	1	00,01,06,07,08	129	00,01,17,28	**
			2	07 where quantity = 1			
52	0	Time Delay - All Variations					
52	1	Time Delay Coarse			129	07, quantity=1	

OBJECT			REQUEST (slave must parse)		RESPONSE (master must parse)		
Obj	Var	Description	Func Codes (dec)	Qual Codes (hex)	Func Codes	Qual Codes (hex)	
52	2	Time Delay Fine			129	07, quantity=1	
60	0	Not defined					
60	1	Class 0 Data	1	06,07,08			
60	2	Class 1 Data	1	06,07,08			
60	3	Class 2 Data	1	06,07,08			
60	4	Class 3 Data	1	06,07,08			
80	1	Internal Indications	1	00,01			**
			2	00 index=7			
		No Object (Cold Restart)	13				
		No Object (Warm Restart)	14				
		No Object (Delay Measurement)	23				

2. Time synchronization information

Parameter	Time
Maximum time base drift over a 10 minute interval	See the PM8000 datasheet for the most current specifications.
Maximum difference between meter time base and master station time base after time set from DNP protocol	2s
Maximum delay measurement error	200ms

2.1 Time Sync Request Configuration

The time interval which the device waits before requesting a time sync from the master (using IIN1-4) is configurable from 1 second to 1 day (in 1 second intervals). The factory default is 1 day.

A Setup option in the DNP Slave Options ION Module is used to configure the Time Sync Request period.

2.2 Configuring DNP communications port to accept time synchronization

Setup options in the ION Clock Module need to be configured before DNP Time Syncs to be processed correctly:

- TimeSyncSource identifies the communications port running the DNP Protocol.
- TimeSyncType indicates if the time syncs are sent in local time or universal time format.

3. PM8000 default DNP configuration

PM8000 meters are shipped from the Factory with the following DNP static objects defined. These objects are returned in response to a Class 0 Poll. Note that the protocol of the desired communications port must set to “DNP 3.0” before the meter will respond to DNP master requests.

Analog Input Objects (16-Bit Analog Input without Flag) (Object 30, Variation 4)		
Point	Measurement	Scaling
0	VIn a	x1
1	VIn b	x1
2	VIn c	x1
3	VIn avg	x1
4	VII ab	x1
5	VII bc	x1
6	VII ca	x1
7	VII avg	x1
8	I a	x1
9	I b	x1
10	I c	x1
11	I avg	x1
12	kW a	x1
13	kW b	x1
14	kW c	x1
15	kW tot	x1
16	kVAR a	x1
17	kVAR b	x1
18	kVAR c	x1
19	kVAR tot	x1
20	kVA a	x1
21	kVA b	x1
22	kVA c	x1
23	kVA tot	x1
24	PFsign a	x1
25	PFsign b	x1
26	PFsign c	x1
27	PFsign tot	x1
28	V unbal	x10
29	I unbal	x10
30	I4	x1
31	Freq	x10
32	kW sd del-rec ²	x1
33	kVAR sd del-rec ³	x1
34	kVA sd del+rec ³	x1

Binary Counter Objects (16-Bit Binary Counter without Flag) (Object 20, Variation 6)		
Point	Measurement	Scaling
0	kWh del (Import)	x1
1	kWh rec (Export)	x1
2	kWh del+rec (Total)	x1
3	kWh del-rec (Net)	x1
4	kVARh del (Import)	x1
5	kVARh rec (Export)	x1
6	kVARh del+rec (Total)	x1
7	kVARh del-rec (Net)	x1
8	kVAh del+rec (Total)	x1

² Note : These are instantaneous demand quantities, not peak (maximum) demand.

4. Details on customizing DNP v3.0 configuration

The PM8000 is factory configured with the basic DNP objects as outlined in “PM8000 default DNP configuration” on page 16. The PM8000 DNP configuration can be further customized to take advantage of other DNP features.

4.1 Customizing the DNP Point map

WARNING

HAZARD OF UNINTENDED OPERATION

- Do not use the meter for critical control or protection applications where human or equipment safety relies on the operation of the control circuit.
- Be aware that an unexpected change of state of the digital outputs may result when the supply power to the meter is interrupted or after a meter firmware or template upgrade.

Failure to follow these instructions can result in death or serious injury.

The PM8000 configuration can be modified to define which measurements are mapped to DNP Static points – this allows a user to exactly control the number of objects returned in a Class 0 poll. ION Modules are used to map PM8000 measurements to DNP points as follows:

- Up to 100 PM8000 measurements can be mapped to DNP Static points. The DNP Slave Export ION Module is used to map PM8000 measurements to DNP Binary Input, Binary Counter, or Analog Input points. A DNP Static point is defined for each PM8000 measurement that is “linked” to a DNP Slave Export ION Module. The type of DNP Static point is a setup option of the DNP Slave Export ION Module.
- Up to 16 relays can be controlled through DNP. The DNP Slave Import ION Module is used to map DNP Control Relay Output Block, and Analog Output Block points to PM8000 relay and analog output hardware.

4.2 Report-by-exception processing (DNP Events)

Any DNP Static point can be configured to create DNP Event objects on value changes. Binary Input Change Events are created when a DNP Binary Input point changes state. Counter and Analog Change Event objects are created when the corresponding Static object changes by more than a programmable deadband value. Deadbands can be set on a per-object basis. Further, Event objects can be assigned as either Class 1, Class 2, or Class 3 on a per-object basis.

Setup options in the DNP Slave Export ION Module are used to enable Events, define deadband values, and assign DNP Event Classes.

Setup options in the DNP Slave Options ION Module are used to select the Object/Variations of Events that will be produced.

The “scan time” for Binary Counter and Analog Input Points is 1 second.

The “scan time” for Binary Input Points is 20ms.

Event capacities are:

- Binary Input Change Events – 25 events
- Frozen Counter Events – 25 events
- Counter Change Events – 25 events
- Frozen Analog Input Events – 25 events
- Analog Input Change Events – 50 events

4.3 Control Relay Output Block

WARNING

HAZARD OF UNINTENDED OPERATION

- Do not use the meter for critical control or protection applications where human or equipment safety relies on the operation of the control circuit.
- Be aware that an unexpected change of state of the digital outputs may result when the supply power to the meter is interrupted or after a meter firmware or template upgrade.

Failure to follow these instructions can result in death or serious injury.

Both ‘1 point per address’ and ‘2 points per address’ modes of addressing are supported for Control Relay Output Block objects. A setup option in the DNP Slave Import ION Module selects the addressing mode. Up to 10 CROB requests can be requested in a single message.

4.4 Freezing Binary Counter Points

Any DNP Binary Counter Point can be configured to support the freeze command. When a Binary Counter is frozen it copies its value into a DNP Frozen Counter point. These Frozen Counter points are returned in a Class 0 poll. Freeze, Freeze/Clear, Freeze/No-Ack, and Freeze/Clear/No-Ack functions are supported.

A Setup option in the DNP Slave Export ION Module is used to give freeze capabilities to the associated Static point.

A Setup option in the DNP Slave Options ION Module is used to select the Object/Variation of the Frozen Static object.

4.5 Scaling

Counter and Analog Input objects can be scaled on a per-object basis. Scaling can be used to maintain resolution in floating point measurements. For example, Frequency measurements can be multiplied by 10 to obtain 1 decimal place of resolution. Alternatively, for Analog Input objects, floating point variations can be requested to maintain multiple decimal places of resolution.

4.6 Assigning ION DNP Slave Options Modules to Meter Communication Ports

The ION DNP Slave Options Module contains a CommPort setup register that assigns this ION DNP Slave Options Module to a particular communication port. Only the settings in the assigned ION DNP Slave Options Module have any affect on that communications port.

For TCP/IP connections (port is set to Ethernet) the MasterIP Addr setup register is used to differentiate between the connections. Setting a specific IP address in this register allows only that IP address to connect to this session. If the register is set to None or left blank, any IP address can connect and use the session.

For more information see the Multiport DNP 3.0 and ION Technology technical note, available from www.schneider-electric.com.

5. Glossary of terms

Application	A piece of software (a program) consisting of one or more processes and supporting functions.
Binary	A number system having only two symbols (1 and 0), and where values are expressed in the base two number system.
Bit	Abbreviation of binary digit. The smallest unit of information in a binary system. Has a value of either one (1) or zero (0).
Master	The client or host station or computer, with which the RTU equipment communicates. Also referred to as a host or host computer.
Non-volatile random-access memory	A semi-permanent type of data storage (memory) that is backed up by batteries to maintain stored data even if system power is lost. Can be both read and changed by the system. Abbreviated as NVRAM.
Random-access memory	A type of temporary data storage (memory) that can be read and changed while the computer is in use. Data stored in random-access memory is lost if the system loses power. Abbreviated as RAM.
Remote terminal unit	A piece of equipment located at a distance from a master station to monitor and control the status of outlying equipment, and to communicate the information back to the master station or host. Abbreviated as RTU.
Sequence of events	A time-tagged change of state, logged as part of a chronological record of significant changes in the condition of a particular point or points being monitored. Abbreviated as SOE.

6. List of acronyms and abbreviations

DNP	distributed network protocol
IED	intelligent electronic device
NVRAM	non-volatile random-access memory
OSI	open systems interconnect
RAM	random-access memory
RTU	remote terminal unit
SOE	sequence of events