



declaration of conformity

/

déclaration de conformité

Chalon -sur-Saône: 08/07/08

réf. :DC 356/2008

From/Emetteur : Jean-Pierre Hattet

Products/Produits : Vigi C60

TO/Destinataire : Sylvie Seiller

Nous attestons que les produits de la gamme Vigi C60 peuvent fonctionner sous une tension alternative de 110V(Vigis fonctionnellement indépendants de la tension d'alimentation)

Cependant, le dispositif de contrôle (bouton test) n'est fonctionnel que pour des tensions comprises entre 0,85 fois et 1,1 fois la tension nominale du produit. Cette tension étant indiquée sur les Vigi C60.

We declare hereby that the C60 Vigi devices can function at a voltage equal to 110Va.c.
(RCBOs functionally independent of line voltage)

However, the operation of the test device is guaranteed only for a voltage between 0.85 times to 1.1 times of the rated voltage. The rated voltage being mentioned on the C60 Vigi.

Continuous Engineering manager

~~SOCIÉTÉ FRANÇAISE GARD
Z.I. Des Biches NILON
71530 CHAMPEORGEUIL
B.P. 159 - 71104 CHALON-SUR-SAÔNE
Tél. : 03 47 65 65 - Télex : 800 18~~