



How to Configure a Compact NS MCCB using product selector tool:


1. Open browser and Go to www.se.com
2. Click on products and select Circuit Breakers and Switches.




3. Scroll down to MasterPact NW Air circuit breaker and click on launch product selector.




4. Select the range required.




5. You need to configure the breaker in this window and make sure to complete all the mandatory.




6. After configuration you will find all the child references on the right side under My Solution




7. Click on add to cart. Make sure your cart is empty first. You can see you are adding 14 items to cart.



8. Close this window and click on My Products.



9. The screen appears as below. Now click on download as excel sheet.



10. An excel sheet “My Product” gets downloaded.

€154.38 +1.46% Global(English) My Products My Documents Login/Register

Life Is On Schneider Electric

Search products, documents & more

IMPACT Company

Products Solutions Services Support About us

Home > All products > My Products

My Products

All Items Configurations Single Items

Name	Quantity
#2 MasterPact NW	
☐  48231 circuit breaker Masterpact NW08H1 - 800 A - 3 poles - drawout - w/o trip unit	1
☐  33091 sensor plug 630 A for Masterpact NT/NW equipped with Micrologic	1
☐  48603 Escutcheon - for drawout Masterpact NW/NW DG	1

Export XML

Product List

- Download as Excel
- Download as PDF

Product Datasheets

- Download as PDF

Configuration Files

- Download as XML (3)

Compare (0/4)

Remove All

Total items: 41

My Products.xlsx

11. Email the excel sheet to the [Sales Team/BD team/Marketing](#) for prices.