



CB TEST CERTIFICATE

Ref. Certificate No.

NL-26922

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.
Product:	Moulded-Case Circuit Breaker
Applicant:	Schneider Electric Industries SAS 35, rue Joseph Monier FR-92500 France RUEIL-MALMAISON
Manufacturer:	Schneider Electric Industries SAS 35, rue Joseph Monier FR-92500 France RUEIL-MALMAISON
Factory: nb: Additional factory information on page 2	Schneider (Beijing) Medium & Low Voltage Co., Ltd No.2 Liang Shui He 2nd Street, Beijing Economic Technological Development Area, Beijing China
Rating and principal characteristics:	Ue: 220 / 230 V, 380 / 400 V, 415 V, 440 V Ui: 690 V Uimp: 6 kV In: EasyPact EZC 400N / 400H: 320, 350, 400 A EasyPact EZC 630N / 630H: 500, 600 A Icu: N type: 40 kA at 220 / 230 V, 36 kA at 380 / 400 V, 36 kA at 415 V, 36 kA at 440 V H type: 70 kA at 220 / 230 V, 50 kA at 380 / 400 V, 50 kA at 415 V, 50 kA at 440 V Ics: N type: 40 kA at 220 / 230 V, 36 kA at 380 / 400 V, 36 kA at 415 V, 18 kA at 440 V H type: 70 kA at 220 / 230 V, 50 kA at 380 / 400 V, 50 kA at 415 V, 25 kA at 440 V 3 poles and 4 poles (3P+N, N marked, N has overcurrent protection) See annex for further ratings
Trade mark (if any):	Schneider Electric
Type of Manufacturer's Testing Laboratories used:	WMT
Model/Type reference:	EasyPact EZC400N/400H/630N/630H
Additional information:	
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1
Test Report Ref. No:	3304654.50

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: H.L. Schendstok

Date of issue: 2013-06-06



**IEC SYSTEM FOR CONFORMITY TESTING TO
STANDARDS FOR SAFETY OF ELECTRICAL
EQUIPMENT (IECEE) CB SCHEME**

Ref. Certificate No.

NL-26922

Schneider Electric India Private Limited
Survey #215, Gagillapur Village, Medak Road, Hyderabad
Andhra Pradesh

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: H.L. Schendstok

Date of issue: 2013-06-06

Product data

number of poles	: 3 poles and 4 poles (3P+N, N marked, N has overcurrent protection)
rated operational voltage (Ue)	: 220 / 230 V, 380 / 400 V, 415 V, 440 V
rated insulation voltage (Ui)	: 690 V
rated impulse withstand voltage (Uimp)	: 6 kV
rated frequency	: 50 / 60 Hz
rated current (In)	: EasyPact EZC400N / 400H: 320 A, 350 A, 400 A, EasyPact EZC630N / 630H: 500 A, 600 A,
rated operational current (Ie)	: Equal to In
conventional thermal current (Ith)	: Equal to In
rated ultimate short-circuit breaking capacity (Icu)	: N type: 40 kA at 220 / 230 V, 36 kA at 380 / 400 V, 36 kA at 415 V, 36 kA at 440 V H type: 70 kA at 220 / 230 V, 50 kA at 380 / 400 V, 50 kA at 415 V, 50 kA at 440 V
rated service short-circuit breaking capacity (Ics)	: N type: 40 kA at 220 / 230 V, 36 kA at 380 / 400 V, 36 kA at 415 V, 18 kA at 440 V H type: 70 kA at 220 / 230 V, 50 kA at 380 / 400 V, 50 kA at 415 V, 25 kA at 440 V
Individual pole short-circuit breaking capacity (I _{1T})	1,2 li
suitable for isolation	: Suitable
utilization category	: A
method of mounting	: Fixed
EMC Environment	: A and B
circuit-breaker for use on phase-earthed systems	: N / A
circuit-breaker for use in IT systems	: Yes
reference temperature	: 40 °C
connection	: Prepared conductors (with lug)
safety distance	: Up / down: 60 mm Left / right: 5 mm Front / back: 0 mm
inverse time delay release	: Thermal type, fixed Equal to In
instantaneous release	: Magnetic type, fixed, for 2 phase poles in series: li (In): 3200 A (320 A) / 3500 A (350 A) / 4000 A (400 A) / 5000 A (500 A) / 5000 A (600 A) for single pole: 1,2 li
line/load terminal infor	: Line and Load are not marked