

1. ให้ดูค่าในปุ่มที่ PowerChute Network shutdown หน้า configure event

WIN-U2T0ZW0L1HT

View Event Log

Configure Events

Configure Shutdown

Set Up Communications

Check for Updates

Configuration Wizard

UPS Information

Help

Logout

Configure Events ?

The table below identifies how PowerChute Network Shutdown will respond to UPS events. Select an icon to see the details of the event.

Events	Log Event	Notify Users	Run Command File	Shut Down System
UPS: On Battery	☒	☐	☐	☐
Input Power: Restored	☒	☐	☐	☐
Runtime: Exceeded	☒	☐	☐	☐
Runtime: Normal Again	☒	☐	☐	☐
Battery: Discharged	☒	☐	☐	☐
Battery: Recharged	☒	☐	☐	☐
Bypass: Due to a Fault	☒	☐	☐	☐
Bypass: For Maintenance	☒	☐	☐	☐
Bypass: Manual	☒	☐	☐	☐
Bypass: Ended	☒	☐	☐	☐
Communication: Lost while on Battery	☒	☐	☐	☐
Communication: NMC cannot communicate with the UPS	☒	☐	☐	☐
Communication: PowerChute cannot communicate with the NMC	☒	☐	☐	☐
Communication: Established	☒	☐	☐	☐
UPS Temperature: Overheated	☒	☐	☐	☐
UPS Temperature: Normal Again	☒	☐	☐	☐
UPS: Overloaded	☒	☐	☐	☐
UPS Overload: Corrected	☒	☐	☐	☐



WIN-U2T0ZW0L1HT

- WIN-U2T0ZW0L1HT

View Event Log

Configure Events

Configure Shutdown

Set Up Communications

Check for Updates

Configuration Wizard

+ UPS Information

+ Help

Logout

Shut Down Operating System

?

Do you want to shut down the PCNS operating system when the selected event happens?

Yes, I want to shut down the PCNS operating system.

☒

Shut down the PCNS operating system only when the event lasts this long (seconds):

120

Apply

Reset

ว่าดึงเวลาไว้กี่นาที

แล้วเครื่องถูกสั่งมี Runtime กี่นาที

2. การที่จะให้ SERVER เปิดขึ้นเองอัตโนมัติจะต้องตั้งค่าที่ BIOS ของ Server

Solution:

To resolve this, change this BIOS setting, if possible, to Last State. If you cannot modify this setting, then the UPS will not be able to automatically reboot the computer under any circumstances - with APC or any other UPS.

Please contact your computer or BIOS manufacturer to find out if it is possible to change this BIOS setting on your particular computer and for exact instructions on how to do so.

