

April 3, 2007

LETTER OF CERTIFICATION

Type QO(B) 10-30 amp Circuit Breakers comply with the Marine Rating Requirements in the UL 489

This letter is to certify that 10-30 amp Type QO(B) circuit breakers comply with the Marine Rating requirements in the UL 489 10th edition. These circuit breakers comply with the requirement with no length restrictions as per UL file E85161.

Letters of Certification are based upon present construction of the specific circuit breaker(s), for which certification has been requested and should be relied upon solely in connection therewith. Changes in design and/or manufacture, which may not be readily apparent from appearance or catalog number or other designation, may cause other versions of these circuit breakers not to meet this certification.

Regards,



Paul Rustebakke
Applications Engineer