



中国国家强制性产品认证证书

证书编号: 2012010309537267

委托人名称、地址

Schneider Electric Korea Ltd.
韩国汉城市永登浦区永登浦洞7街94-46, 第一BLDG, 6层

生产者(制造商)名称、地址

Schneider Electric Korea Ltd.
韩国汉城市永登浦区永登浦洞7街94-46, 第一BLDG, 6层

生产企业名称、地址

Schneider Electric Korea Ltd.
韩国全罗北道益山市龙提洞574

产品名称和系列、规格、型号

电子式过载继电器

3DE, 3EZ, FDE, FEZ (型号解释详见附件); $U_i=AC690V$; $U_e=AC690V$; $I_e: (0.5A-60A) \times 0.9$;
脱扣级别: 2, 3, 5E, 10E, 20E, 30E, 40; 3P; 配用的辅助触头: AC-15: AC250V/3A, DC-
13: DC30V/1A

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-01C-011: 2007的要求, 特发此证。

发证日期: 2012年04月17日

有效期至: 2017年04月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0539760



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010309537267

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.
6/F, Cheil Bldg. 94-46 Yeongdeungpo-dong7(chil)-ga, Yeongdeungpo-gu,
seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Korea Ltd.
6/F, Cheil Bldg. 94-46 Yeongdeungpo-dong7(chil)-ga, Yeongdeungpo-gu,
seoul, Korea

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.
574 Yongjae-Dong, Iksan City, Jun Book, Korea

NAME, MODEL AND SPECIFICATION

Electronic Overload Relay
3DE, 3EZ, FDE, FEZ;Ui=AC690V;Ue=AC690V; Ie: (0.5A-60A) × 0.9; Trip
Class:2, 3, 5E, 10E, 20E, 30E, 40;3P; Auxiliary Contact:AC-15:AC250V/3A, DC-
13:DC30V/1A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-01C-011:2007).

Date of issue: Apr.17,2012 Date of expiry: Apr.17,2017

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0539760



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2012010309537267

证书纸号: 539760

型号的解释:

FEZ - C - WR D Z7 T A Q
1 2 3 4 5 6 7 8

1. 型号代号

电子式过载继电器:

型号	功能
3DE:	Overcurrent, Undercurrent, Phase loss, Phase reversal, Unbalance, Locked Rotor, stall,
3EZ:	Overcurrent, Undercurrent, Phase loss, Phase reversal, Unbalance, Locked Rotor, stall, Ground Fault
FDE:	Overcurrent, Undercurrent, Phase loss, Phase reversal, Unbalance, Locked Rotor, stall
FEZ:	Overcurrent, Undercurrent, Phase loss, Phase reversal, Unbalance, Locked Rotor, stall, Ground Fault

2. CCC 认证产品

3. 电流范围

WR: (0.5A~60A)×0.9

外接电流互感器, H1:CT100 型, HH:CT150 型, H2:CT200 型, H3:CT300 型, H4:CT400 型

4. 输出触头类型

A: 1 常开(97, 98) +1 常开(57, 58) (仅 3EZ, FEZ)

D: 1 常开(97, 98) +1 常闭(95, 96) +1 常开(07, 08) (仅 3DE, FDE)

5. 控制电路电源电压及频率:

M7: 220 VAC, 50/60Hz

F7: 110 VAC, 50/60Hz

Z7: 85~250VAC/DC, 50/60Hz (仅 FDE, FEZ 端子类型)

B: 24 VAC/DC, 50/60Hz

6. 接线端子类型

W: 直通型(无主电路接线端子)

T: 具有主电路接线端子(仅 FDE, FEZ)

7. 接地故障电流范围(仅 3EZ, FEZ)

A: 0.02A~3A

注: 此附录与证书同时使用时有效。



主 任:

(Signature)

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2012010309537267

证书纸号: 539760

B: 0.2A~10A

8. 产品用途

Q: 适用于出口

空白: 本地产品

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2012010309537266

证书纸号: 539761

型号的解释:

$\frac{SSD}{1}$ - $\frac{C}{2}$ - $\frac{05}{3}$ $\frac{D}{4}$ $\frac{M7}{5}$ $\frac{Q}{6}$

1. 系列代号
SSD: 电子式过载继电器
2. CCC 认证产品
3. 电流范围
05: (0.5A - 6A) × 0.9
30: (3A - 30A) × 0.9
60: (10A - 60A) × 0.9
4. 辅助触头类型
D: OL(1 常闭 + 1 常开)
5. 控制电路电源电压及频率:
M7: 220 VAC, 50/60Hz
F7: 110 VAC, 50/60Hz
B: 24 VAC/DC, 50/60Hz
6. 产品用途
Q: 适用于出口
空白: 本地产品

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

