



中国国家强制性产品认证证书

证书编号: 2012010303526771

委托人名称、地址

Schneider Electric Korea Ltd.
韩国汉城市永登浦区永登浦洞7街94-46, 第一BLDG, 6层

生产者(制造商)名称、地址

Schneider Electric Korea Ltd.
韩国汉城市永登浦区永登浦洞7街94-46, 第一BLDG, 6层

生产企业名称、地址

Schneider Electric Korea Ltd.
韩国全罗北道益山市龙提洞 574

产品名称和系列、规格、型号

电子过电压继电器

EVRPD, EVRFD(型号解释详见附件); $U_i=AC480V$; $I_{th}=5A$; AC-15: $U_e=AC240V$, $I_e=2A$; DC-13: $U_e=DC30V$, $I_e=1A$

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2012年02月15日

有效期至: 2017年02月15日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0485432



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010303526771

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.
6/F, Ceil Bldg., 94-46 Yeongdeungpo-dong7(chil)-ga, Yeongdeungpo-gu,
Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Korea Ltd.
6/F, Ceil Bldg., 94-46 Yeongdeungpo-dong7(chil)-ga, Yeongdeungpo-gu,
Seoul, Korea

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.
574 Yongjae-Dong, Iksan City, Jun Book, Korea

NAME, MODEL AND SPECIFICATION

Electronic Over-voltage Relay

EVRPD, EVRFD;Ui=AC480V;Ith=5A; AC-15:Ue=AC240V, Ie=2A;DC-13:Ue=DC30V, Ie=1A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Feb.15,2012 Date of expiry: Feb.15,2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0485432



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2012010303526771

纸号: 485432

型号的解释:

$\frac{\text{EVRPD}}{1}$ - $\frac{\text{C}}{2}$ - $\frac{44}{3}$ $\frac{\text{N}}{4}$ $\frac{\text{Z5}}{5}$ $\frac{\text{M}}{6}$ $\frac{\text{Q}}{7}$

1. Series Designation
EVRPD, EVRFD: Electronical Over voltage Relay Series name
EVRPD: Integral type, EVRFD: Display separation type
2. CCC certified products
3. Input Voltage
11: OVR 110-150VAC, UVR 80-120VAC, 3Phase
22: OVR 220-300VAC, UVR 160-240VAC, 3Phase
44: OVR 480-480VAC, UVR 300-440VAC, 3Phase
4. Output contacts
N: Normally Energized
R: Normally De-Energized
5. Control voltage and frequency
Z6: 100-240VAC, 50/60Hz
Z5: 100-240VAC, 50Hz
6. Mode method
M: Mode type
7. Classification of Products
Q: Export products
Blank: Local products

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

