



中国国家强制性产品认证证书

证书编号: 2011010309461946

委托人名称、地址

Schneider Electric Korea Ltd.
6rd floor, Cheil Bldg, 94-46, Yeongdeungpo-dong 7(Chil)-ga, Yeongdeungpo-gu, Seoul, Korea

生产者(制造商)名称、地址

Schneider Electric Korea Ltd.
6rd floor, Cheil Bldg, 94-46, Yeongdeungpo-dong 7(Chil)-ga, Yeongdeungpo-gu, Seoul, Korea

生产企业名称、地址

Schneider Electric Korea Ltd.
韩国 全罗北道 益山市 龙提洞574

产品名称和系列、规格、型号

电子式过电流继电器

SE Ue:690V;Ie:1A-6A, 5A-30A, 10A-60A; 配用的辅助触头:AC-15:Ue:AC240V;Ie:2A;DC-13:Ue:DC30V;Ie:1A;型号详见附录

产品标准和技术要求

GB 14048.4-2003

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2011年03月02日

有效期至: 2016年03月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0382561



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010309461946

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.
6rd floor, Cheil Bldg, 94-46, Yeongdeungpo-dong 7(Chil)-ga, Yeongdeungpo-gu, Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Korea Ltd.
6rd floor, Cheil Bldg, 94-46, Yeongdeungpo-dong 7(Chil)-ga, Yeongdeungpo-gu, Seoul, Korea

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.
574 Yongjae-Dong, Iksan City, Jun Book, Korea

NAME, MODEL AND SPECIFICATION

Electronical Overload Relays

SE Ue:690V;Ie:1A-6A, 5A-30A, 10A-60A; Attached Auxiliary Contacts:AC-15:Ue:AC240V;Ie:2A;DC-13:Ue:DC30V;Ie:1A;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2003

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Mar.02,2011 Date of expiry: Mar.02,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0382561



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2011010309461946

纸号: 382561

型号的解释:

SE	-	C	-	05	R	Y7	Q
1		2		3	4	5	6

1. Series Designation 系列型号

SE: Electronic Overload Relay Series name 电子过载继电器系列名称

2. CCC certified products CCC 认证产品

3. Current range 电流范围

05: 1 ~ 6A
30: 5 ~ 30A
60: 10 ~ 60A

4. Output contacts 输出触头

N: Normally energize in control power applied 通常在控制电源通电的应用

R: Normally de-energize in control power applied 通常去控制电源通电中的应用

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2011010309461946

纸号: 382561

5. Control voltage 控制电压

Y7: 100 ~ 240 VAC, 50/60Hz

Y5: 100 ~ 240 VAC, 50Hz

B: 24 VAC/DC, 50/60Hz

6. Classification of Products 产品分类

Q: Export products Q: 出口产品

Blank: Local products 空白: 本地销售产品

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

