



中国国家强制性产品认证证书

证书编号: 2014010309745314

委托人名称、地址

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

生产者(制造商)名称、地址

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

生产企业名称、地址

Schneider Electric Korea Ltd.
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

产品名称和系列、规格、型号

电子式过载继电器

EOCRDS1(T)、EOCRDS3(T)、EOCRSE2; Ui:690V; Ue:AC690V; Ie[EOCRDS1(T)]: 0.5A~6A、3A~30A;
Ie[EOCRDS3(T)、EOCRSE2]: 0.5A~6A、3A~30A、5A~60A; 脱扣级别: 2E,3E,5E,10E; 2P(EOCRSE2),
3P[EOCRDS1(T)、EOCRDS3(T)]; IP20; 配用的辅助触头: 1NO1NC; Ith:3A; AC-15:250V/3A; DC-13:30V/3A;
型号解释详见附件

产品标准和技术要求

GB/T14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 12 月 04 日 有效期至: 2024 年 12 月 04 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2014 年 12 月 31 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2014010309745314

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

PRODUCT NAME, MODEL AND SPECIFICATION

Electronic Overload Relay

EOCRDS1(T)、EOCRDS3(T)、EOCRSE2; Ui:690V; Ue:AC690V; Ie[EOCRDS1(T)]: 0.5A~6A、3A~30A; Ie[E
OCRDS3(T)、EOCRSE2]: 0.5A~6A、3A~30A、5A~60A; Tripping class: 2E,3E,5E,10E; 2P(EOCRSE2), 3
P[EOCRDS1(T)、EOCRDS3(T)]; IP20; Attached Auxiliary Contacts: 1NO1NC; Ith:3A; AC-15:250V/3A; DC-13:
30V/3A; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Dec.04,2019

Valid until: Dec.04,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by
issuing certification body until the expiry date.

Date of original issued: Dec.31,2014

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2014010309745314

纸号: 2480296

型号的解釋:

EOCR ☐ ☐ - ☐ ☐ ☐ ☐
① ② ③ ④ ⑤ ⑥

No	Type	Meaning
①	Model	DS1 逆相, 缺相, 反时限
		DS3 逆相, 缺相, 定时限
		SE2 定时限
②	Terminal	T Terminal type 螺钉端子连接
		Blank Non-terminal type 无螺钉端子(穿孔连接)
③	Standard	05 Ie:0.5A~6A
		30 Ie:3A~30A
		60 Ie:5A~60A
④	Fail safety	N Fail safe ON 有故障判断
		R Fail safe OFF 无故障判断
		Blank 可设定 N Type 或 R Type
⑤	Power Supply	S AC/DC (24~240)V
		W AC (380~440)V
⑥	Product Usage	Q 出口产品
		Blank 本地销售产品

注: 此附录与证书同时使用时有效。



主任:

陆梅



中国质量认证中心