



中国国家强制性产品认证证书

证书编号: 2019010304252589

委托人名称、地址

Schneider Electric Korea Ltd.

(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

生产者(制造商)名称、地址

Schneider Electric Korea Ltd.

(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

生产企业名称、地址

Schneider Electric Korea Ltd.

63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

产品名称和系列、规格、型号

电子式过载继电器

PFZ, PMZ; U_i : 690V; U_e : 690V; I_e : (0.5A-60A) $\times$ 0.9; 脱扣级别: 2, 3, 5E, 10E, 20E, 30E, 40; 3P;
配用的辅助触头: U_e/I_e : AC-15: AC250V/3A, DC-13: DC30V/1A; 型号解释详见附件

产品标准和技术要求

GB/T14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 11 月 22 日 有效期至: 2024 年 11 月 22 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010304252589

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

PRODUCT NAME, MODEL AND SPECIFICATION

Electronic Overload Relay
PFZ, PMZ; Ui: 690V; Ue: 690V; Ie: (0.5A-60A) × 0.9; Tripping Class: 2, 3, 5E, 10E, 20E, 30E, 40, 3P;
Auxiliary Contact: Ue/Ie: AC-15: AC250V/3A, DC-13: DC30V/1A; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO.CNCA-C03-02:2014).

Valid from: Nov.22,2019

Valid until: Nov.22,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录

第 1 页 共 1 页

证书编号: 2019010304252589

纸 号: 2452186

型号的解释

<u>PMZ</u>	-	<u>C</u>	-	<u>WR</u>	<u>D</u>	<u>Z7</u>	<u>T</u>	<u>Q</u>
1		2		3	4	5	6	7

1. 型号代号
电子式过载继电器:
PMZ: 集成一体式
PFZ: 显示分离式
2. CCC 强制认证产品
3. 电流范围
WR: (0.5A~60A) × 0.9
外接电流互感器, H1: CT 100 型, HH: CT 150 型, H2: CT 200 型, H3: CT 300 型,
H4: CT 400 型
4. 输出触头类型
D: 1 常开(97, 98) + 1 常闭(95, 96) + 1 常开(57, 58)
5. 控制电路电源电压及频率:
Z7: 100~240VAC/DC, 50/60Hz
B: 24 VAC/DC, 50/60Hz
6. 接线端子类型
T: 具有主电路接线端子
W: 无主电路接线端子
7. 产品用途
Q: 适用于出口
空白: 本地产品

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心