

**Note:** Ensure you note the changes made on settings under customer setting column.

## 100 - Quick setup settings

Menu	Factory setting	Customer setting
Un	400 V	
Ct	1	
Al	(No setting)	
PFC	On	
CP1	0.95i	
St	10 s	
Out	AUTO [step 1... max 12]	

## 200 - Measurement settings

201	400 V	
202	1	
203	1	
204	10 %	
205	Yes (LL meas.) / No (LN meas.)	
206	90° (LL meas.) / 0° (LN meas.)	
207	(No setting)	
208	Auto	
209	0 °C	

## 300 - Control settings

301	75 %	
302	0.95i	
303	0.95i	
304	No	
305	10 s	
306	2 s	
307	No	
308	Yes	
309	Yes	
310	On	
311	1	
312	0	
313	1	
314	No	
315	No	

## 400 - Step database settings

Menu	Factory setting	Customer setting
401	50 s	
402	3 var C [step 1...max 12]	
403	Auto [step 1...max 12]	
404	0 [step 1...max 12]	

## 500 - Alarm settings

501	No	
502	7 %	
503	Yes	
504	60 s	
505	No	
506	Yes	
507	100 k	
508	65.5 k h (7 ans)	
509	1.3	
510	Yes	
511	30 °C	
512	50 °C	
513	Yes	
514	Yes	
515	Yes	
516	Yes	
517	7	

## 600 - reset

607	xxx.xxx.xxx	
608	242	

## 700 - communication settings

701	19.2 k	
702	Even	
703	1	