


iMX powered by main network



Control by N/O push-button with verification of voltage presence (iMX+OF)

iMX, iMX+OF: shunt release units

Function

- Tripping of the associated protective device when a voltage appears across the terminals of the auxiliary (control by: N/O push-button, dry contact, etc.).
- Resetting of the protective device is possible only when the voltage across the terminals of the auxiliary has disappeared.
- A locking push-button control allows the circuit protected by the circuit breaker (e.g. machine control) to be placed in safety configuration.

Operation timing chart

