

TEST REPORT FOR THE PATTERN AND CONSTRUCTION OF ELECTRICITY METERS

MANUFACTURER : *Schneider Electric India Pvt. Ltd*

TYPE : *PM5**1*

CLASS : *0.5s (kWh) & 2(kvarh)*

DESCRIPTION : *Polyphase, Active Import/ Export (kWh), Transformer Operated, Electricity Meter*

Tested in accordance with IEC 62052-11: 2003, Electricity metering equipment (AC) – General requirements, tests and test conditions.

Part 11: Metering equipment.

And IEC 62053-22: 2003, Electricity metering equipment (AC) – Particular requirements

Part 22: Static meters for active energy (classes 0.2s and 0.5s).

And IEC 62053-23: 2003, Electricity metering equipment (AC) – Particular requirements

Part 23: Static meters for reactive energy (classes 2 & 3).

The meters tested satisfied the required specification.

ISSUED BY:



K. Hunter
Test Engineer

CHECKED BY:



P. Fairless
Test Engineer

VERIFIED BY:



R. Jackson
Metering Manager

REPORT ISSUE DATE: 13th March 2014 Issue 3

“This document is issued by the Company subject to its General Conditions of Service available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Company’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.” “Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.”

Tests marked * are not covered under our UKAS scope.



CONTENTS

INTRODUCTION

INFORMATION OF THE ELECTRICITY METER TESTED

SUPPORTING DOCUMENTATION

SUMMARY OF TEST RESULTS

- 1 INSULATION
 - 1.1 Impulse Voltage Test
 - 1.2 AC Voltage Test

- 2 ACCURACY REQUIREMENTS
 - 2.1 Meter Constant
 - 2.2 Starting Conditions
 - 2.3 Running with no load
 - 2.4 Influence of ambient temperature
 - 2.5 Influence Quantities -
 - 2.5.1 Current Variation
 - 2.5.2 Voltage Variation
 - 2.5.3 Frequency Variation
 - 2.5.4 Reverse Phase Sequence
 - 2.5.5 Voltage Unbalance
 - 2.5.6 Continuous Magnetic Induction
 - 2.5.7 Magnetic Induction of 0.5mT
 - 2.5.8 Auxiliary Power Supply Voltage Variation
 - 2.6 Accuracy test in the Presence of Harmonics
 - 2.6.1 Harmonic Components in the Current and Voltage Circuits
 - 2.6.2 Influence of Odd and Sub Harmonics in the AC Current Circuit

- 3 ELECTRICAL REQUIREMENTS
 - 3.1 Power Consumption
 - 3.2 Influence of Supply Voltage - Interruptions and Dips.
 - 3.3 Influence of Short-Time Over-currents
 - 3.4 Influence of Self Heating
 - 3.5 Influence of Heating

- 4 ELECTROMAGNETIC COMPATIBILITY (EMC)
 - 4.1 Immunity to Electrostatic Discharges
 - 4.2 Immunity to Electromagnetic HF Fields
 - 4.3 Fast Transient Burst Test
 - 4.4 Immunity to Conducted Disturbances
 - 4.5 Surge Immunity
 - 4.6 Immunity to Damped Oscillatory Waves

5	CLIMATIC INFLUENCES
5.1	Dry Heat Test
5.2	Cold Test
5.3	Damp Heat Cyclic Test
6	MECHANICAL REQUIREMENTS
6.1	Spring Hammer
6.2	Shock
6.3	Vibration
6.4	Resistance to Heat & Fire
6.5	Penetration of Dust and Water
ANNEX A	Photographs of Meter Under Test



INTRODUCTION

The type tests described were carried out in the SGS (Durham) measurement laboratory on behalf of:

CLIENT DETAILS: Schneider Electric India Pvt. Ltd.
44P Electronic City
Phase II East
Hosur Road
Bangalore
Kamataka 560100
India

ORDER No's: 1400043774, 1400050278

DATE OF RECEIPT OF SAMPLES: 15th August 2013, 1st November 2013, 8th January 2014

DATE OF TESTS: 14th April 2013 to 13th March 2014

In the cases where no or only limited tests have been conducted on the submitted samples, tests carried out during previous OFGEM approval (or by other accredited bodies) on meters of similar construction and designs have been taken to confirm that the meter satisfies the requirements of the relevant standard. See supporting documentation for reference.

Conditions under which the type tests took place:

Unless otherwise stated, the meters were examined at an ambient temperature of $23^{\circ}\text{C} \pm 2^{\circ}\text{C}$, and after the voltage circuits had been connected to reference voltage for at least 1 hour.

Unless otherwise stated, Polyphase tests were tested with a standard phase sequence of L1-L2-L3 (corresponding to the Red, Yellow & Blue phases).

The tests were conducted using equipment, traceable to National and International Standards.

INFORMATION ON THE ELECTRICITY METERS TESTED

Manufacturer : *Schneider Electric*
 Type : *PM5**1*
 Class : *0.5s (kWh) & 2(kvarh)*
 Type of circuit : *3 phase 4 wire, 3 phase 3 wire*
 In : *5A*
 I_{max} : *6A*
 Reference Supply Voltage : *3x63.5/110V-277/480V*
 Rated Frequency : *50Hz*
 Pulse output constant : *10000 imp/kWh/kvarh, 20000 imp/kWh/kvarh*
 Manufacturers Serial No's. : *JB1310214000072, JB1310214000122, JB1310426000105, 340000002002, 340090000114, 3400000002003, 340060001062, 340090000120, 340000002001, 340090000112, 34000000114 3400000008115, New case sample No.1*

The meter types submitted for testing PM5111, PM5331 and PM5341 are superset models and the test report covers below listed models.

Meter series	Description (2nd digit meaning)	Model reference number	VAF, PQS-power & Energy, PF, DM, THD	Accuracy Class	Ind Harmonics	Alarms	Whetting Voltage	RS485	Ethernet	Multitariff	Digital Inputs (DI)	Digital Outputs (S=Solid State Relay & R=Form A relay)	Data Logging	Remote display	MID*	
PM5100	Basic power and energy meter with Class 0.5S accuracy	METSEPM5100	✓	0.5S	15th	33	x	x	x	x	x	1DO (kWh only)	x	x	x	
		METSEPM5110	✓	0.5S	15th	33	x	✓	x	x	x	1DO (kWh only)	x	x	x	
		METSEPM5111	✓	0.5S	15th	33	x	✓	x	x	x	1DO (kWh only)	x	x	✓	
PM5300	Basic power and energy meter with Class 0.5S, DI/DO, Multi Tariff, Data logging & Relays	METSEPM5310	✓	0.5S	31st	35	✓	✓	x	4	2 DI	2 DO	✓	x	x	
		METSEPM5330	✓	0.5S	31st	35	✓	✓	x	4	2 DI	2 DO+2R	✓	x	x	
		METSEPM5331	✓	0.5S	31st	35	✓	✓	x	4	2 DI	2 DO+2R	✓	x	✓	
		METSEPM5320	✓	0.5S	31st	35	✓	✓	x	✓	4	2 DI	2 DO	✓	x	x
		METSEPM5340	✓	0.5S	31st	35	✓	✓	x	✓	4	2 DI	2 DO+2R	✓	x	x
		METSEPM5341	✓	0.5S	31st	35	✓	✓	x	✓	4	2 DI	2 DO+2R	✓	x	✓

	Tested for EN 50470-1 and EN 50470-3
--	--------------------------------------

2nd digit :

PM51xx = Basic w/ 0.5S accuracy

PM53xx = Basic w/ 0.5S accuracy + up to 31st harmonics +DI/DO + whetting + Multitariff + Datalog

3rd digit: 0 = Non com

1 = RS-485

2 = Ethernet

3 = RS485 + Relay

4 = Ethernet + Relay

4th digit: 0 = Non MID

1 = MID



GENERAL REQUIREMENTS

Sealing Arrangements

IEC 62052-11 X-Ref. 5.2.1

The meter shall have a case which can be sealed in such a way that the internal parts of the meter are accessible only after breaking the seal(s)
The cover shall not be removable without the use of a tool.
Non permanent deformation may not influence the meter.

Complied

Display of Measured Values

IEC 62052-11 X-Ref. 5.10

The principal unit is (kWh)
The active tariff shall be indicated.
The identification of each tariff applied shall be possible.
The register shall be able to record and display, starting from zero, for a minimum of 1500 h, the energy corresponding to maximum current at reference voltage and unity power factor.

Complied

Non-volatile memory shall have a minimum retention time of four months.
In the case of multiple values presented by a single display, it shall be possible to display the content of all relevant memories.
Automatic sequencing displays shall display each value for at least 5 s.
Every numerical element of an electronic display shall be able to show all numbers from "zero" to "nine":

Complied

Inspection of Markings

IEC 62052-11 X-Ref. 5.12

The requirements are met for the marking of the meter samples with respect to both name-plates and connection diagrams.

Complied



SUPPORTING DOCUMENTATION

Accredited Laboratory tests reports:

Dust Ingress IP5X Test
MS Testing (UK) Ltd

X-Ref. 5.9
Report No.: TL13083 Issued: 17th September 2013



SUMMARY OF TEST RESULTS

IEC 62052-11: 2003 General Requirements:

EN 62052-11 Clause	Test	Performed	Result
5.2.2.1	Spring hammer	Yes	Complied
5.2.2.2	Shock	Yes	Complied
5.2.2.3	Vibration	Yes	Complied
5.8	Resistance to heat and fire	Yes	Complied
5.9	Penetration of water	Yes	Complied
5.9	Penetration of dust	Yes*	Complied
6.3.1	Dry heat	Yes	Complied
6.3.2	Cold	Yes	Complied
6.3.3	Damp heat cyclic	Yes	Complied
6.3.4	Solar radiation	No	-
7.1.2	Voltage dips and short interruptions	Yes	Complied
7.2	Influence of heating	Yes	Complied
7.3.2	Impulse voltage	Yes	Complied
7.5.2	Electrostatic discharge immunity	Yes	Complied
7.5.3	Radiated immunity	Yes	Complied
7.5.4	Fast transient bursts immunity	Yes	Complied
7.5.5	Conducted immunity	Yes	Complied
7.5.6	Surge immunity	Yes	Complied
7.5.7	Damped oscillatory waves immunity	Yes	Complied
7.5.8	Radio interference suppression	Yes	Complied

IEC 62053-22: 2003 Particular Requirements:

EN 62053-22 Clause	Test	Performed	Result
7.1	Power consumption	Yes	Complied
7.2	Influence of short-time over-currents	Yes	Complied
7.3	Influence of self-heating	Yes	Complied
7.3.3	AC voltage	Yes	Complied
8.1	Current variation	Yes	Complied
8.2	Variation of error due to voltage variation	Yes	Complied
8.2	Variation of error due to frequency variation	Yes	Complied
8.2	Reverse Phase Sequence	Yes	Complied
8.2	Voltage Unbalance	Yes	Complied
8.2	Operation of accessories	No	-
8.2	Auxiliary voltage variation	Yes	Complied
8.2	Variation of error due to temperature variation	Yes	Complied
8.2	Variation of error due to harmonics	Yes	Complied
8.2	Sub-harmonics in the AC circuit	Yes	Complied
8.2	Continuous magnetic induction of external origin	Yes	Complied
8.2	Magnetic induction of external origin (0.5mT)	Yes	Complied
8.3	Starting and no-load condition	Yes	Complied
8.4	Meter constant	Yes	Complied



SUMMARY OF TEST RESULTS (cont.)

IEC 62053-23: 2003 Particular Requirements:

EN 62053-23 Clause	Test	Performed	Result
7.1	Power consumption	No	-
7.2	Influence of short-time overcurrents	No	-
7.3	Influence of self-heating	No	-
7.4	AC voltage	No	-
8.1	Current variation	Yes	Complied
8.2	Variation of error due to voltage variation	Yes	Complied
8.2	Variation of error due to frequency variation	Yes	Complied
8.2	Operation of accessories	No	-
8.2	Variation of error due to temperature variation	No	-
8.2	DC Component in the current circuit	No	-
8.2	Continuous magnetic induction of external origin	No	-
8.2	Magnetic induction of external origin (0.5mT)	No	-
8.3	Starting and no-load condition	Yes	Complied
8.4	Meter constant	Yes	Complied

Yes Tests performed at SGS (UK) Ltd

Yes* Tests performed at MS Testing (UK) Ltd Report No.: TL13083 2013



1.2 AC Voltage Test

IEC 62053-22 X-Ref. 7.4

Test Results ID / Sample No.
AC / 34000002002

Test Procedure: IEC62052-22 AC Voltage
I9EMA TP13

Environmental Conditions

Temperature	23°C
Relative Humidity	42%
Barometric Pressure	998mB

Test level 2kV & 4kV Test duration 1 minute.

The a.c. voltage tests were conducted as follows:

- 1) Between all meter voltage and current circuits connected together, and earth.
- 2) Between all circuits not intended to be connected together in service, and earth.

The earth consisting of a conductive foil wrapped around the meter and connected to a flat conducting earth surface, upon which the meter was placed.

During the tests auxiliary circuits with reference rated voltage $\leq 40V$ were connected to earth.

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or degradation in the meter's insulation properties.

2 ACCURACY REQUIREMENTS

IEC 62053-22 X-Ref. 8

2.1 Meter Constant

X-Ref. 8.4

The relation between the test output and the meter energy registers were checked to ensure the constant marking on the meter nameplate.

Measurement mode - Active Import Energy kWh

Test Results ID / Sample No. Meter Constant / 340090000120	Test Procedure: Meter Constant (1h @ Im) 19EMA TP37
---------------------------------------------------------------	--------------------------------------------------------

Test conditions: $U_n: 3 \times 230/400V$ $I_{max}: 6A$ $\cos. \phi = 1.0, 50Hz$

Test Circuit: $3 \text{ phase } 4 \text{ wire}$

Measurement mode: *Active Import Energy kWh*

Number of Pulses Recorded	Pulse Constant (p/ kWh)	LED Test Output (kWh)	Energy Registered By Meter (kWh)	Percentage difference between Energy Registered and LED Test Output (%)
83061	20000	4.15	4.15	0.00

Limit of % Error Variation: $\pm 0.5\%$ for Class 0.5s (kWh)

Measurement mode - Active Export Energy kWh

Test Results ID / Sample No. Meter Constant / 340090000120	Test Procedure: Meter Constant (1h @ Im) 19EMA TP37
---------------------------------------------------------------	--------------------------------------------------------

Test conditions: $U_n: 3 \times 230/400V$ $I_{max}: 6A$ $\cos. \phi = 1.0, 50Hz$

Test Circuit: $3 \text{ phase } 4 \text{ wire}$

Measurement mode: *Active Export Energy kWh*

Number of Pulses Recorded	Pulse Constant (p/ kWh)	LED Test Output (kWh)	Energy Registered By Meter (kWh)	Percentage difference between Energy Registered and LED Test Output (%)
83079	20000	4.159	4.154	0.00

Limit of % Error Variation: $\pm 0.5\%$ for Class 0.5s (kWh)

During the registration tests, rate registers not active were found not to have been corrupted.



Meter Constant (cont.)

IEC 62053-23 X-Ref. 8.4

Measurement mode - Reactive Import Energy kvarh

Test Results ID / Sample No. Meter Constant / 34009000120	Test Procedure: Meter Constant (1h @ Im) 19EMA TP37
--------------------------------------------------------------	--------------------------------------------------------

Test conditions: $U_n: 3x230/400V$ $I_{max}: 6A$ $Cos. \phi = 1.0, 50Hz$

Test Circuit: $3\text{ phase } 4\text{ wire}$

Measurement mode: *Reactive Import Energy kvarh*

Number of Pulses Recorded	Pulse Constant (p/ kvarh)	LED Test Output (kvarh)	Energy Registered By Meter (kvarh)	Percentage difference between Energy Registered and LED Test Output (%)
83037	20000	4.15185	4.152	0.00

Limit of % Error Variation: $\pm 2\%$ for Class 2 (kvarh)

Measurement mode - Reactive Export Energy kvarh

Test Results ID / Sample No. Meter Constant / 34009000120	Test Procedure: Meter Constant (1h @ Im) 19EMA TP37
--------------------------------------------------------------	--------------------------------------------------------

Test conditions: $U_n: 3x230/400V$ $I_{max}: 6A$ $Cos. \phi = 1.0, 50Hz$

Test Circuit: $3\text{ phase } 4\text{ wire}$

Measurement mode: *Reactive Export Energy kvarh*

Number of Pulses Recorded	Pulse Constant (p/ kvarh)	LED Test Output (kvarh)	Energy Registered By Meter (kvarh)	Percentage difference between Energy Registered and LED Test Output (%)
83058	20000	4.1529	4.153	0.00

Limit of % Error Variation: $\pm 2\%$ for Class 2 (kvarh)

During the registration tests, rate registers not active were found not to have been corrupted.



2.2 Starting and No-Load condition

IEC 62053-22 X-Ref. 8.3

Initial Start-up of the meter

X-Ref. 8.3.1

Test Results ID / Sample No.
Start Up / 340090000120

Test Procedure: Start-up

The meter sample was fully functional within 5s after rated voltage U_n was applied to the meter terminals.

Starting

X-Ref. 8.3.3

Test Results ID / Sample No.
Starting Current / 340090000120

Test Procedure: Starting Current 0.1(% Ib)
19EMA TP36

The meter commenced and continued to measure the active power in both the import and export directions.

Test conditions for Transformer Operated meters

Class 0.2s Active meters : U_{min} , 0.1% I_n , Cos. $\phi = 1.0$, 50Hz

Class 0.5s Active meters : U_{min} , 0.1% I_n , Cos. $\phi = 1.0$, 50Hz

Running with No-Load

X-Ref. 8.3.2

Test Results ID / Sample No.
No Load / 340090000120

Test Procedure: Non Registration Test 115(%U)
19EMA TP36

Tests were conducted as follows;

Test conditions: *115% U_n , current circuits open*

The minimum test duration in minutes being given by

$$\Delta t \geq \frac{900 \times 10^6}{k \cdot m \cdot U_n \cdot I_{max}} \quad [\text{min}] \text{ for meters of class 0.2s}$$

$$\Delta t \geq \frac{600 \times 10^6}{k \cdot m \cdot U_n \cdot I_{max}} \quad [\text{min}] \text{ for meters of class 0.5s}$$

where

k is the meter output constant (pulses per kWh)

m is the number of measuring elements

The meter sample was tested for a period of at least Δt minutes, on completion of which, no changes in the energy registers were recorded, and the test output did not produce more than one pulse.



Starting and No-Load condition (cont)

IEC 62053-23 X-Ref. 8.3

Initial Start-up of the meter

X-Ref. 8.3.1

Test Results ID / Sample No. Start Up / 340090000120	Test Procedure: Start-up
---------------------------------------------------------	--------------------------

The meter sample was fully functional within 5s after rated voltage U_n was applied to the meter terminals.

Starting

X-Ref. 8.3.3

Test Results ID / Sample No. Starting Current / 340090000120	Test Procedure: Starting Current 0.3(% I_b) 19EMA TP36
-----------------------------------------------------------------	--------------------------------------------------------------

The meter commenced and continued to measure the reactive power in both the import and export directions.

Test conditions for Transformer Operated meters

Class 2 Reactive meters : $U_{min}, 0.3\% I_n, \sin \phi = 1.0, 50\text{Hz}$

Class 3 Reactive meters : $U_{min}, 0.5\% I_n, \sin \phi = 1.0, 50\text{Hz}$

Running with No-Load

X-Ref. 8.3.2

Tests were conducted as follows;

Test conditions: *115% U_n , current circuits open*

The minimum test duration in minutes being given by

$$\Delta t \geq \frac{480 \times 10^6}{k \cdot m \cdot U_n \cdot I_{max}} \quad [\text{min}] \text{ for meters of class 2}$$

$$\Delta t \geq \frac{300 \times 10^6}{k \cdot m \cdot U_n \cdot I_{max}} \quad [\text{min}] \text{ for meters of class 3}$$

where

k is the meter output constant (pulses per kvarh)

m is the number of measuring elements

The meter sample was tested for a period of at least Δt minutes, on completion of which, no changes in the energy registers were recorded, and the test output did not produce more than one pulse.

2.4 Influence of Ambient Temperature

IEC 62053-22 X-Ref. 8
X-Ref. 8.2

Test Results ID / Sample No.
Temperature Var. / 340090000112

Test Procedure: IEC62053-22 Temperature Variation
19EMA TP31

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

Temperature °C	Current	PF Cos. ϕ	% Error	Mean Temperature coefficient %/K
33	0.05In	1.0	0.28	0.01
13	0.05In	1.0	0.08	
33	0.1In	0.5ind	0.31	0.0115
13	0.1In	0.5ind	0.08	
33	In	1.0	0.27	0.0065
13	In	1.0	0.14	
33	In	0.5ind	0.48	0.0135
13	In	0.5ind	0.21	
33	Im	1.0	0.28	0.0065
13	Im	1.0	0.15	
33	Im	0.5ind	0.48	0.0135
13	Im	0.5ind	0.21	

Limit of Mean Temperature coefficient for: Class 0.2s $\pm 0.01\%/K$ @ Cos. $\phi = 1.0$
 $\pm 0.02\%/K$ @ Cos. $\phi = 0.5ind$
Class 0.5s $\pm 0.03\%/K$ @ Cos. $\phi = 1.0$
 $\pm 0.05\%/K$ @ Cos. $\phi = 0.5ind$

Influence of Ambient Temperature (cont.)

**Operation of meter at the limit of the specified operating temperature range
(Indoor meters)**

IEC 62053-22 X-Ref. 6.1

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Temperature /°C	Current	PF Cos. ϕ	% Error
-10°C	0.1In	1.0	-0.14
45°C	0.1In	1.0	0.40
-10°C	0.2In	0.5ind	-0.17
45°C	0.2In	0.5ind	0.48
-10°C	In	1.0	-0.01
45°C	In	1.0	0.35
-10°C	In	0.5ind	-0.06
45°C	In	0.5ind	0.66
-10°C	Im	1.0	0.00
45°C	Im	1.0	0.36
-10°C	Im	0.5ind	-0.06
45°C	Im	0.5ind	0.65

Limits of % Error: Class accuracy.

**Operation of meter at the Limit of temperature range
(Indoor meters)**

X-Ref. 6.1

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Temperature /°C	Current	% Error
70°C	In	0.39
-25°C	In	-0.18

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions.

2.5 Influence Quantities

IEC 62053-22 X-Ref. 8

2.5.1 Variation in Current

X-Ref. 8.1

Test Results ID / Sample No. Current Variation / 340090000112	Test Procedure: IEC62053-22 Acc3P4W kWh +P 19EMA TP25
------------------------------------------------------------------	----------------------------------------------------------

Test conditions: U_n : 3x230/400V I_n : 5A I_m : 6A F_n : 50Hz
 U_x : 230V

Test Circuit: 3 phase 4 wire

Measurement mode - Active Import Energy kWh

CURRENT	PF Cos. ϕ	% Error	Limit of % Error	
			Accuracy	
			Class 0.2s	Class 0.5s
0.01 In	1.0	0.12	±0.4	±1.0
0.02 In	-	-0.06	±0.4	±1.0
0.05 In	-	0.08	±0.2	±0.5
0.1 In	-	0.11	±0.2	±0.5
0.2 In	-	0.13	±0.2	±0.5
0.5 In	-	0.17	±0.2	±0.5
In	-	0.15	±0.2	±0.5
0.4 Im	-	0.17	±0.2	±0.5
0.6 Im	-	0.15	±0.2	±0.5
0.8 Im	-	0.16	±0.2	±0.5
Im	-	0.16	±0.2	±0.5
0.02 In	0.5ind	0.08	±0.5	±1.0
0.05 In	-	0.23	±0.5	±1.0
0.1 In	-	0.19	±0.3	±0.6
0.2 In	-	0.12	±0.3	±0.6
0.5 In	-	0.24	±0.3	±0.6
In	-	0.28	±0.3	±0.6
Im	-	0.28	±0.3	±0.6
0.1 In	0.25ind	0.28	±0.5	±1.0
0.2 In	-	0.11	±0.5	±1.0
0.5 In	-	0.30	±0.5	±1.0
In	-	0.43	±0.5	±1.0
0.1 In	0.8cap	0.10	±0.3	±0.6
0.2 In	-	0.14	±0.3	±0.6
0.5 In	-	0.15	±0.3	±0.6
In	-	0.11	±0.3	±0.6
0.1 In	0.5cap	0.05	±0.5	±1.0
0.2 In	-	0.13	±0.5	±1.0
0.5 In	-	0.12	±0.5	±1.0
In	-	0.03	±0.5	±1.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.05 In	1.0	0.19	0.02	0.17	± 0.3	± 0.6
0.1 In	-	0.21	0.04	0.17	± 0.3	± 0.6
0.2 In	-	0.33	-0.03	0.11	± 0.3	± 0.6
0.5 In	-	0.27	0.07	0.19	± 0.3	± 0.6
In	-	0.23	0.08	0.17	± 0.3	± 0.6
Im	-	0.23	0.10	0.18	± 0.3	± 0.6
0.1 In	0.5ind	0.21	0.13	0.31	± 0.4	± 1.0
0.2 In	-	0.44	-0.11	0.13	± 0.4	± 1.0
0.5 In	-	0.37	0.11	0.31	± 0.4	± 1.0
In	-	0.30	0.24	0.40	± 0.4	± 1.0
Im	-	0.32	0.18	0.27	± 0.4	± 1.0
0.2 In	0.5cap	0.51	-0.20	0.00	-	-
In	-	0.18	-0.06	-0.04	-	-
Im	-	0.18	-0.09	-0.04	-	-



Variation in Current(cont.)

X-Ref. 8.1

Test Results ID / Sample No. Current Variation / 340090000112	Test Procedure: IEC62053-22 Acc 3P4W kWh -P I9EMA TP25
------------------------------------------------------------------	-----------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Export Energy kWh

CURRENT	PF Cos. ϕ	% Error	Limit of % Error	
			Class 0.2s	Class 0.5s
0.01 In	1.0	0.16	± 0.4	± 1.0
0.02 In	-	-0.03	± 0.4	± 1.0
0.05 In	-	0.12	± 0.2	± 0.5
0.1 In	-	0.14	± 0.2	± 0.5
0.2 In	-	0.18	± 0.2	± 0.5
0.5 In	-	0.20	± 0.2	± 0.5
In	-	0.18	± 0.2	± 0.5
Im	-	0.18	± 0.2	± 0.5
0.02 In	0.5ind	0.10	± 0.5	± 1.0
0.05 In	-	0.26	± 0.5	± 1.0
0.1 In	-	0.23	± 0.3	± 0.6
0.2 In	-	0.20	± 0.3	± 0.6
0.5 In	-	0.28	± 0.3	± 0.6
In	-	0.33	± 0.3	± 0.6
Im	-	0.37	± 0.3	± 0.6
0.1 In	0.25ind	0.33	± 0.5	± 1.0
0.2 In	-	0.23	± 0.5	± 1.0
0.5 In	-	0.38	± 0.5	± 1.0
In	-	0.51	± 0.5	± 1.0
0.1 In	0.8cap	0.11	± 0.3	± 0.6
0.2 In	-	0.17	± 0.3	± 0.6
0.5 In	-	0.17	± 0.3	± 0.6
In	-	0.12	± 0.3	± 0.6
0.1 In	0.5cap	0.07	± 0.5	± 1.0
0.2 In	-	0.18	± 0.5	± 1.0
0.5 In	-	0.14	± 0.5	± 1.0
In	-	0.04	± 0.5	± 1.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Export Energy kWh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.1 In	1.0	0.19	0.06	0.17	± 0.3	± 0.6
In	-	0.19	0.17	0.20	± 0.3	± 0.6
Im	-	0.20	0.14	0.21	± 0.3	± 0.6
0.2 In	0.5ind	-0.07	0.30	0.35	± 0.4	± 1.0
In	-	0.27	0.33	0.48	± 0.4	± 1.0
Im	-	0.25	0.31	0.38	± 0.4	± 1.0
0.2 In	0.5cap	-0.01	0.26	0.23	-	-
In	-	0.09	-0.01	0.02	-	-
Im	-	0.09	0.01	0.07	-	-



Variation in Current(cont)

X-Ref. 8.1

Test Results ID / Sample No. Current Variation / 34000008115	Test Procedure: IEC62053-22 Acc3P4W kWh +P I9EMA TP25
-----------------------------------------------------------------	----------------------------------------------------------

Test conditions: U_n : 3x230/400V I_n : 5A I_m : 6A F_n : 50Hz
 U_x : 230V

Test Circuit: 3 phase 4 wire

Measurement mode - Active Import Energy kWh

CURRENT	PF Cos. ϕ	% Error	Limit of % Error	
			Class 0.2s	Class 0.5s
0.01 In	1.0	-0.23	± 0.4	± 1.0
0.02 In	-	-0.20	± 0.4	± 1.0
0.05 In	-	-0.06	± 0.2	± 0.5
0.1 In	-	-0.09	± 0.2	± 0.5
0.2 In	-	-0.10	± 0.2	± 0.5
0.5 In	-	-0.09	± 0.2	± 0.5
In	-	-0.09	± 0.2	± 0.5
0.4 Im	-	-0.10	± 0.2	± 0.5
0.6 Im	-	-0.09	± 0.2	± 0.5
0.8 Im	-	-0.08	± 0.2	± 0.5
Im	-	-0.07	± 0.2	± 0.5
0.02 In	0.5ind	-0.07	± 0.5	± 1.0
0.05 In	-	0.07	± 0.5	± 1.0
0.1 In	-	0.05	± 0.3	± 0.6
0.2 In	-	-0.16	± 0.3	± 0.6
0.5 In	-	-0.03	± 0.3	± 0.6
In	-	0.05	± 0.3	± 0.6
Im	-	0.13	± 0.3	± 0.6
0.1 In	0.25ind	0.21	± 0.5	± 1.0
0.2 In	-	-0.21	± 0.5	± 1.0
0.5 In	-	0.04	± 0.5	± 1.0
In	-	0.22	± 0.5	± 1.0
0.1 In	0.8cap	-0.13	± 0.3	± 0.6
0.2 In	-	-0.07	± 0.3	± 0.6
0.5 In	-	-0.11	± 0.3	± 0.6
In	-	-0.13	± 0.3	± 0.6
0.1 In	0.5cap	-0.21	± 0.5	± 1.0
0.2 In	-	-0.04	± 0.5	± 1.0
0.5 In	-	-0.14	± 0.5	± 1.0
In	-	-0.21	± 0.5	± 1.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.05 In	1.0	0.01	-0.14	-0.02	± 0.3	± 0.6
0.1 In	-	0.00	-0.16	-0.07	± 0.3	± 0.6
0.2 In	-	-0.08	-0.07	-0.18	± 0.3	± 0.6
0.5 In	-	0.01	-0.14	-0.08	± 0.3	± 0.6
In	-	0.00	-0.13	-0.08	± 0.3	± 0.6
Im	-	0.00	-0.14	-0.06	± 0.3	± 0.6
0.1 In	0.5ind	0.11	0.01	0.15	± 0.4	± 1.0
0.2 In	-	-0.14	0.02	-0.26	± 0.4	± 1.0
0.5 In	-	-0.13	0.00	-0.02	± 0.4	± 1.0
In	-	0.06	0.03	0.10	± 0.4	± 1.0
Im	-	0.21	0.12	0.15	± 0.4	± 1.0
0.2 In	0.5cap	0.08	0.10	-0.30	-	-
In	-	-0.08	-0.28	-0.32	-	-
Im	-	-0.09	-0.39	-0.41	-	-



Variation in Current(cont.)

X-Ref. 8.1

Test Results ID / Sample No. Current Variation / 34000008115	Test Procedure: IEC62053-22 Acc 3P4W kWh -P 19EMA TP25
-----------------------------------------------------------------	-----------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Export Energy kWh

CURRENT	PF Cos. ϕ	% Error	Limit of % Error	
			Class 0.2s	Class 0.5s
0.01 In	1.0	-0.21	± 0.4	± 1.0
0.02 In	-	-0.18	± 0.4	± 1.0
0.05 In	-	-0.04	± 0.2	± 0.5
0.1 In	-	-0.07	± 0.2	± 0.5
0.2 In	-	-0.11	± 0.2	± 0.5
0.5 In	-	-0.08	± 0.2	± 0.5
In	-	-0.07	± 0.2	± 0.5
Im	-	-0.06	± 0.2	± 0.5
0.02 In	0.5ind	-0.04	± 0.5	± 1.0
0.05 In	-	0.10	± 0.5	± 1.0
0.1 In	-	0.07	± 0.3	± 0.6
0.2 In	-	-0.17	± 0.3	± 0.6
0.5 In	-	-0.03	± 0.3	± 0.6
In	-	0.07	± 0.3	± 0.6
Im	-	0.15	± 0.3	± 0.6
0.1 In	0.25ind	0.26	± 0.5	± 1.0
0.2 In	-	-0.25	± 0.5	± 1.0
0.5 In	-	0.06	± 0.5	± 1.0
In	-	0.25	± 0.5	± 1.0
0.1 In	0.8cap	-0.12	± 0.3	± 0.6
0.2 In	-	-0.08	± 0.3	± 0.6
0.5 In	-	-0.10	± 0.3	± 0.6
In	-	-0.13	± 0.3	± 0.6
0.1 In	0.5cap	-0.20	± 0.5	± 1.0
0.2 In	-	-0.06	± 0.5	± 1.0
0.5 In	-	-0.14	± 0.5	± 1.0
In	-	-0.21	± 0.5	± 1.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Export Energy kWh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.1 In	1.0	0.03	-0.17	-0.05	± 0.3	± 0.6
In	-	0.04	-0.22	-0.04	± 0.3	± 0.6
Im	-	0.05	-0.19	-0.03	± 0.3	± 0.6
0.2 In	0.5ind	-0.06	-0.55	0.11	± 0.4	± 1.0
In	-	0.06	-0.05	0.21	± 0.4	± 1.0
Im	-	0.15	0.06	0.29	± 0.4	± 1.0
0.2 In	0.5cap	0.07	-0.44	0.05	-	-
In	-	0.00	-0.39	-0.26	-	-
Im	-	-0.07	-0.45	-0.24	-	-



Variation in Current(cont.)

X-Ref. 8.1

Test Results ID / Sample No. Current Variation / 3400000114	Test Procedure: IEC62053-22 Acc 3P3W kWh +P 19EMA TP25
----------------------------------------------------------------	-----------------------------------------------------------

Test conditions: *Un: 3x230V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 3 wire*

Measurement mode - Active Import Energy kWh

CURRENT	PF Cos. ϕ	% Error	Limit of % Error	
			Class 0.2s	Class 0.5s
0.01 In	1.0	-0.27	± 0.4	± 1.0
0.02 In	-	-0.36	± 0.4	± 1.0
0.05 In	-	-0.26	± 0.2	± 0.5
0.1 In	-	-0.22	± 0.2	± 0.5
0.2 In	-	-0.23	± 0.2	± 0.5
0.5 In	-	-0.22	± 0.2	± 0.5
In	-	-0.21	± 0.2	± 0.5
Im	-	-0.20	± 0.2	± 0.5
0.02 In	0.5ind	-0.21	± 0.5	± 1.0
0.05 In	-	-0.17	± 0.5	± 1.0
0.1 In	-	-0.15	± 0.3	± 0.6
0.2 In	-	-0.22	± 0.3	± 0.6
0.5 In	-	-0.14	± 0.3	± 0.6
In	-	-0.13	± 0.3	± 0.6
Im	-	-0.08	± 0.3	± 0.6
0.1 In	0.25ind	-0.08	± 0.5	± 1.0
0.2 In	-	-0.22	± 0.5	± 1.0
0.5 In	-	-0.07	± 0.5	± 1.0
In	-	-0.04	± 0.5	± 1.0
0.1 In	0.8cap	-0.18	± 0.3	± 0.6
0.2 In	-	-0.19	± 0.3	± 0.6
0.5 In	-	-0.20	± 0.3	± 0.6
In	-	-0.21	± 0.3	± 0.6
0.1 In	0.5cap	-0.23	± 0.5	± 1.0
0.2 In	-	-0.19	± 0.5	± 1.0
0.5 In	-	-0.23	± 0.5	± 1.0
In	-	-0.25	± 0.5	± 1.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: $U_n: 3 \times 230V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 3 wire*

Measurement mode - Active Import Energy kWh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.05 In	1.0	-0.18	-	-0.26	± 0.3	± 0.6
0.1 In	-	-0.14	-	-0.22	± 0.3	± 0.6
0.2 In	-	-0.14	-	-0.21	± 0.3	± 0.6
0.5 In	-	-0.12	-	-0.24	± 0.3	± 0.6
In	-	-0.10	-	-0.30	± 0.3	± 0.6
Im	-	-0.07	-	-0.10	± 0.3	± 0.6
0.1 In	0.5ind	0.02	-	-0.17	± 0.4	± 1.0
0.2 In	-	-0.11	-	-0.23	± 0.4	± 1.0
0.5 In	-	0.05	-	-0.03	± 0.4	± 1.0
In	-	0.09	-	-0.20	± 0.4	± 1.0
Im	-	0.09	-	-0.01	± 0.4	± 1.0
0.2 In	0.5cap	-0.13	-	-0.15	-	-
In	-	-0.27	-	-0.42	-	-
Im	-	-0.33	-	-0.33	-	-



Variation in Current(cont.)

X-Ref. 8.1

Test Results ID / Sample No.
Current Variation / 3400000114

Test Procedure: IEC62053-22 Acc 3P3W kWh -P
19EMA TP25

Test conditions: U_n : 3x230V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 6A

Test Circuit: 3 phase 3 wire

Measurement mode - Active Export Energy kWh

CURRENT	PF Cos. ϕ	% Error	Limit of % Error	
			Class 0.2s	Class 0.5s
0.01 In	1.0	-0.27	±0.4	±1.0
0.02 In	-	-0.29	±0.4	±1.0
0.05 In	-	-0.18	±0.2	±0.5
0.1 In	-	-0.16	±0.2	±0.5
0.2 In	-	-0.18	±0.2	±0.5
0.5 In	-	-0.16	±0.2	±0.5
In	-	-0.17	±0.2	±0.5
Im	-	-0.17	±0.2	±0.5
0.02 In	0.5ind	-0.11	±0.5	±1.0
0.05 In	-	-0.09	±0.5	±1.0
0.1 In	-	-0.17	±0.3	±0.6
0.2 In	-	-0.10	±0.3	±0.6
0.5 In	-	-0.09	±0.3	±0.6
In	-	-0.08	±0.3	±0.6
Im	-	-0.03	±0.3	±0.6
0.1 In	0.25ind	-0.01	±0.5	±1.0
0.2 In	-	-0.17	±0.5	±1.0
0.5 In	-	-0.02	±0.5	±1.0
In	-	-0.02	±0.5	±1.0
0.1 In	0.8cap	-0.19	±0.3	±0.6
0.2 In	-	-0.19	±0.3	±0.6
0.5 In	-	-0.19	±0.3	±0.6
In	-	-0.21	±0.3	±0.6
0.1 In	0.5cap	-0.23	±0.5	±1.0
0.2 In	-	-0.17	±0.5	±1.0
0.5 In	-	-0.23	±0.5	±1.0
In	-	-0.25	±0.5	±1.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: $U_n: 3 \times 230V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 3 wire*

Measurement mode - Active Export Energy kWh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.1 In	1.0	-0.13	-	-0.20	± 0.3	± 0.6
In	-	-0.12	-	-0.33	± 0.3	± 0.6
Im	-	-0.20	-	-0.21	± 0.3	± 0.6
0.2 In	0.5ind	0.02	-	-0.24	± 0.4	± 1.0
In	-	0.06	-	-0.09	± 0.4	± 1.0
Im	-	0.09	-	-0.08	± 0.4	± 1.0
0.2 In	0.5cap	-0.29	-	-0.31	-	-
In	-	-0.37	-	-0.12	-	-
Im	-	-0.29	-	-0.42	-	-



Variation in Current (cont.)

IEC 62053-23X-Ref. 8
X-Ref. 8.1

Test Results ID / Sample No. Current Variation / 340090000112	Test Procedure: IEC62053-23 Acc 3P4W kvarh +Q 19EMA TP25
------------------------------------------------------------------	-------------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Reactive Import Energy kvarh

CURRENT	PF Sin ϕ	% Error	Limit of % Error	
			Accuracy	
			Class 2	Class 3
0.05 In	1.0	0.15	± 2.5	± 4.0
0.1 In	-	0.15	± 2.0	± 3.0
0.2 In	-	0.17	± 2.0	± 3.0
0.5 In	-	0.20	± 2.0	± 3.0
In	-	0.18	± 2.0	± 3.0
0.4 Im	-	0.19	± 2.0	± 3.0
0.6 Im	-	0.18	± 2.0	± 3.0
0.8 Im	-	0.18	± 2.0	± 3.0
Im	-	0.19	± 2.0	± 3.0
0.1 In	0.5ind	0.07	± 2.5	± 4.0
0.2 In	-	0.16	± 2.0	± 3.0
0.5 In	-	0.13	± 2.0	± 3.0
In	-	0.03	± 2.0	± 3.0
Im	-	0.05	± 2.0	± 3.0
0.2 In	0.25ind	0.21	± 2.5	± 4.0
0.5 In	-	0.04	± 2.5	± 4.0
In	-	-0.14	± 2.5	± 4.0
0.2 In	0.5cap	0.20	± 2.0	± 3.0
0.5 In	-	0.29	± 2.0	± 3.0
In	-	0.33	± 2.0	± 3.0
Im	-	0.33	± 2.0	± 3.0
0.2 In	0.25cap	0.30	± 2.5	± 4.0
0.5 In	-	0.41	± 2.5	± 4.0
In	-	0.53	± 2.5	± 4.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Reactive Import Energy kvarh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Sin ϕ	% Error	% Error	% Error	Accuracy	
0.1 In	1.0	0.21	0.07	0.18	Class 2 ±3.0	Class 3 ±4.0
In	-	0.24	0.13	0.21	±3.0	±4.0
Im	-	0.22	0.13	0.19	±3.0	±4.0
0.2 In	0.5ind	0.22	0.32	-0.07	±3.0	±4.0
In	-	0.08	0.02	-0.05	±3.0	±4.0
Im	-	0.17	0.01	0.01	±3.0	±4.0
0.2 In	0.5cap	0.20	0.37	0.07	±3.0	±4.0
In	-	0.30	0.41	0.33	±3.0	±4.0
Im	-	0.31	0.35	0.33	±3.0	±4.0



Variation in Current(cont.)

X-Ref. 8.1

Test Results ID / Sample No. Current Variation / 340090000112	Test Procedure: IEC62053-23 Acc 3P4W kvarh -Q I9EMA TP25
------------------------------------------------------------------	-------------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Reactive Export Energy kvarh

CURRENT	PF Sin ϕ	% Error	Limit of % Error	
			Accuracy	
			Class 2	Class 3
0.05 In	1.0	0.14	± 2.5	± 4.0
0.1 In	-	0.15	± 2.0	± 3.0
0.2 In	-	0.17	± 2.0	± 3.0
0.5 In	-	0.20	± 2.0	± 3.0
In	-	0.18	± 2.0	± 3.0
Im	-	0.19	± 2.0	± 3.0
0.1 In	0.5ind	0.08	± 2.5	± 4.0
In	-	0.03	± 2.0	± 3.0
Im	-	0.05	± 2.0	± 3.0
0.1 In	0.5cap	0.25	± 2.0	± 4.0
In	-	0.34	± 2.0	± 3.0
Im	-	0.33	± 2.0	± 3.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 6A

Test Circuit: 3 phase 4 wire

Measurement mode - Reactive Export Energy kvarh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Sin ϕ	% Error	% Error	% Error	Accuracy	
					Class 2	Class 3
In	1.0	0.23	0.09	0.21	±3.0	±4.0
In	0.5ind	0.14	-0.10	0.02	±3.0	±4.0
In	0.5cap	0.34	0.23	0.44	±3.0	±4.0

Variation in Current (cont.)

 IEC 62053-23X-Ref. 8
 X-Ref. 8.1

 Test Results ID / Sample No.
 Current Variation / 34000008114

 Test Procedure: IEC62053-23 Acc 3P3W kvarh +Q
 19EMA TP25

 Test conditions: *Un: 3x230V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

 Test Circuit: *3 phase 3 wire*
Measurement mode - Reactive Import Energy kvarh

CURRENT	PF Sin ϕ	% Error	Limit of % Error	
			Accuracy	
			Class 2	Class 3
0.05 In	1.0	-0.19	± 2.5	± 4.0
0.1 In	-	-0.18	± 2.0	± 3.0
0.2 In	-	-0.18	± 2.0	± 3.0
0.5 In	-	-0.19	± 2.0	± 3.0
In	-	-0.19	± 2.0	± 3.0
0.4 Im	-	-0.20	± 2.0	± 3.0
0.6 Im	-	-0.18	± 2.0	± 3.0
0.8 Im	-	-0.18	± 2.0	± 3.0
Im	-	-0.18	± 2.0	± 3.0
0.1 In	0.5ind	-0.22	± 2.5	± 4.0
0.2 In	-	-0.08	± 2.0	± 3.0
0.5 In	-	-0.20	± 2.0	± 3.0
In	-	-0.23	± 2.0	± 3.0
Im	-	0.29	± 2.0	± 3.0
0.2 In	0.25ind	0.22	± 2.5	± 4.0
0.5 In	-	-0.12	± 2.5	± 4.0
In	-	-0.22	± 2.5	± 4.0
0.2 In	0.5cap	-0.02	± 2.0	± 3.0
0.5 In	-	-0.06	± 2.0	± 3.0
In	-	-0.07	± 2.0	± 3.0
Im	-	0.03	± 2.0	± 3.0
0.2 In	0.25cap	0.33	± 2.5	± 4.0
0.5 In	-	0.28	± 2.5	± 4.0
In	-	0.22	± 2.5	± 4.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: $U_n: 3 \times 230V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 3 wire*

Measurement mode - Reactive Import Energy kvarh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Sin ϕ	% Error	% Error	% Error	Accuracy	
0.1 In	1.0	-0.15	-	-0.19	Class 2 ±3.0	Class 3 ±4.0
In	-	-0.15	-	-0.16	±3.0	±4.0
Im	-	-0.14	-	-0.13	±3.0	±4.0
0.2 In	0.5ind	-0.40	-	-0.01	±3.0	±4.0
In	-	-0.22	-	-0.27	±3.0	±4.0
Im	-	-0.32	-	-0.27	±3.0	±4.0
0.2 In	0.5cap	-0.16	-	-0.16	±3.0	±4.0
In	-	-0.05	-	-0.11	±3.0	±4.0
Im	-	0.00	-	-0.13	±3.0	±4.0



Variation in Current(cont.)

X-Ref. 8.1

Test Results ID / Sample No. Current Variation / 34000008114	Test Procedure: IEC62053-23 Acc 3P3Wkvarh -Q 19EMA TP25
-----------------------------------------------------------------	------------------------------------------------------------

Test conditions: *Un: 3x230V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 3 wire*

Measurement mode - Reactive Export Energy kvarh

CURRENT	PF Sin ϕ	% Error	Limit of % Error	
			Accuracy	
			Class 2	Class 3
0.05 In	1.0	-0.15	± 2.5	± 4.0
0.1 In	-	-0.14	± 2.0	± 3.0
0.2 In	-	-0.14	± 2.0	± 3.0
0.5 In	-	-0.15	± 2.0	± 3.0
In	-	-0.16	± 2.0	± 3.0
Im	-	-0.15	± 2.0	± 3.0
0.1 In	0.5ind	-0.17	± 2.5	± 4.0
In	-	-0.23	± 2.0	± 3.0
Im	-	-0.28	± 2.0	± 3.0
0.1 In	0.5cap	-0.05	± 2.0	± 4.0
In	-	-0.04	± 2.0	± 3.0
Im	-	0.00	± 2.0	± 3.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: U_n : 3x230V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 6A

Test Circuit: 3 phase 3 wire

Measurement mode - Reactive Export Energy kvarh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Sin ϕ	% Error	% Error	% Error	Accuracy	
In	1.0	-0.11	-	-0.21	Class 2 ±3.0	Class 3 ±4.0
In	0.5ind	-0.25	-	-0.35	±3.0	±4.0
In	0.5cap	0.01	-	-0.18	±3.0	±4.0



2.5.2 Voltage Variation

IEC 62053-22 X-Ref. 8.2

Specified Operating Range

Test Results ID / Sample No. Voltage Variation / 340090000120	Test Procedure: IEC62053-22 Voltage Variation P 19EMA TP26
------------------------------------------------------------------	---------------------------------------------------------------

Test conditions: *Un: 3x63.5/110V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

		110% Un	100% Un	90% Un	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
0.05 In	1.0	0.09	0.04	0.05	Class 0.2s ±0.1	Class 0.5s ±0.2
In	-	0.14	0.09	0.10	±0.1	±0.2
Im	-	0.15	0.10	0.10	±0.1	±0.2
0.1 In	0.5ind	0.20	0.16	0.17	±0.2	±0.4
In	-	0.30	0.26	0.27	±0.2	±0.4
Im	-	0.31	0.27	0.28	±0.2	±0.4

Limit Range of Operation

		115% Un	80% Un	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	Accuracy	
In	1.0	0.14	0.09	Class 0.2s ±0.3	Class 0.5s ±0.6
In	0.5ind	0.31	0.28	±0.6	±1.2



Voltage Variation (cont.)

IEC 62053-22 X-Ref. 8.2

Specified Operating Range

Test Results ID / Sample No. Voltage Variation / 340090000120	Test Procedure: IEC62053-22 Voltage Variation P 19EMA TP26
------------------------------------------------------------------	---------------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

		110% Un	100% Un	90% Un	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.05 In	1.0	0.11	0.13	0.15	± 0.1	± 0.2
In	-	0.15	0.17	0.19	± 0.1	± 0.2
Im	-	0.16	0.17	0.20	± 0.1	± 0.2
0.1 In	0.5ind	0.21	0.23	0.26	± 0.2	± 0.4
In	-	0.29	0.31	0.33	± 0.2	± 0.4
Im	-	0.29	0.30	0.33	± 0.2	± 0.4

Limit Range of Operation

		115% Un	80% Un	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	Accuracy	
				Class 0.2s	Class 0.5s
In	1.0	0.16	0.20	± 0.3	± 0.6
In	0.5ind	0.31	0.35	± 0.6	± 1.2



Voltage Variation (cont.)

IEC 62053-22 X-Ref. 8.2

Specified Operating Range

Test Results ID / Sample No. Voltage Variation / 340090000120	Test Procedure: IEC62053-22 Voltage Variation P 19EMA TP26
------------------------------------------------------------------	---------------------------------------------------------------

Test conditions: *Un: 3x277/480V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

		110% Un	100% Un	90% Un	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.05 In	1.0	0.13	0.13	0.12	± 0.1	± 0.2
In	-	0.17	0.17	0.16	± 0.1	± 0.2
Im	-	0.18	0.17	0.17	± 0.1	± 0.2
0.1 In	0.5ind	0.23	0.24	0.24	± 0.2	± 0.4
In	-	0.32	0.31	0.31	± 0.2	± 0.4
Im	-	0.32	0.31	0.30	± 0.2	± 0.4

Limit Range of Operation

		115% Un	80% Un	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	Accuracy	
				Class 0.2s	Class 0.5s
In	1.0	0.17	0.18	± 0.3	± 0.6
In	0.5ind	0.32	0.33	± 0.6	± 1.2



Voltage Variation (cont.)

IEC 62053-23 X-Ref. 8.2

Specified Operating Range

Test Results ID / Sample No. Voltage Variation / 340090000120	Test Procedure: IEC62053-23 Voltage Variation Q 19EMA TP26
------------------------------------------------------------------	---------------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Reactive Energy kvarh

		110% Un	100% Un	90% Un	Limit of % Error Variation	
Current	PF Sin ϕ	% Error	% Error	% Error	Accuracy	
0.05 In	1.0	0.13	0.14	0.16	Class 2 ±1.0	Class 3 ±2.0
In	-	0.17	0.19	0.21	±1.0	±2.0
Im	-	0.18	0.19	0.21	±1.0	±2.0
0.1 In	0.5ind	0.06	0.07	0.09	±1.5	±3.0
In	-	0.03	0.04	0.06	±1.5	±3.0
Im	-	0.05	0.06	0.08	±1.5	±3.0

Limit Range of Operation

		115% Un	80% Un	Limit of % Error Variation	
Current	PF Sin ϕ	% Error	% Error	Accuracy	
In	1.0	0.18	0.21	Class 2 ±3.0	Class 3 ±6.0
In	0.5ind	0.04	0.06	±4.5	±9.0



Frequency Variation(cont)

IEC62053-23 X-Ref. 8.2

Test Results ID / Sample No.
Frequency Variation / 340090000120

Test Procedure: IEC62053-23 Frequency 51Hz to 49Hz Q
19EMA TP27

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Reactive Import Energy kvarh

		102% F _n	100% F _n	98% F _n	Limit of % Error Variation	
Current	PF Sins φ	% Error	% Error	% Error	Accuracy	
					Class 2	Class 3
0.05 I _n	1.0	0.14	0.14	0.14	±2.5	±2.5
I _n	1.0	0.19	0.19	0.18	±2.5	±2.5
I _m	1.0	0.19	0.19	0.19	±2.5	±2.5
0.10 I _n	0.5ind	0.17	0.07	0.02	±2.5	±2.5
I _n	0.5ind	0.10	0.04	-0.02	±2.5	±2.5
I _m	0.5ind	0.11	0.06	0.00	±2.5	±2.5



2.5.4 Reversed Phase Sequence

IEC 62053-22 X-Ref. 8.2

Test Results ID / Sample No. Reverse Phase / 340090000120	Test Procedure: IEC62053-22 Reverse Phase Sequence 19EMA TP28
--------------------------------------------------------------	------------------------------------------------------------------

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

		Limit of % Error Variation	
Phase Sequence	% Error	Accuracy	
Current		Class 0.2s	Class 0.5s
Sequence L1-L2-L3 0.1 In	0.04	-	-
Sequence L1-L3-L2 0.1 In	0.06	±0.05	±0.1

2.5.5 Voltage Unbalance

IEC 62053-22 X-Ref. 8.2

Test Results ID / Sample No. Voltage Unbalance / 340090000120	Test Procedure: IEC62053-22 Phase Interruption 19EMA TP29
------------------------------------------------------------------	--------------------------------------------------------------

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

		Limit of % Error Variation	
Network Phase/Lines connected	% Error	Accuracy	
		Class 0.2s	Class 0.5s
L1 & L2 & L3	0.05	-	-
L2 & L3	0.09	±0.5	±1.0
L1 & L3	0.07	±0.5	±1.0
L1 & L2	0.08	±0.5	±1.0
L3	0.06	±0.5	±1.0
L2	0.11	±0.5	±1.0
L1	0.03	±0.5	±1.0



2.5.6 Continuous Magnetic Induction of External Origin

IEC 62053-22 X-Ref. 8.2

Test Results ID / Sample No. DC Mag. Field / JB1310214000122	Test Procedure: IEC62053-22 DC Magnetic Field P 19EMA TP33
-----------------------------------------------------------------	---------------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

Electromagnetic Position	% Error	Limit of % Error Variation	
		Accuracy	
		Class 0.2s	Class 0.5s
No field applied	0.06	-	-
Left side of meter	0.17	±2.0	±2.0
Front of meter	0.14	±2.0	±2.0
Right side of meter	0.17	±2.0	±2.0
Top of meter	0.17	±2.0	±2.0



2.5.7 Magnetic Induction of External Origin 0.5mT IEC 62053-22 X-Ref. 8.2

Ac magnetic induction of external origin, produced by a coil of one metre diameter, field strength at its centre 0.5mT (400 Ampere turns)

Test Results ID / Sample No.	Test Procedure: T/T +P X-X FAIRY RING T/T +P Y-Y FAIRY RING T/T +P Z-Z FAIRY RING 19EMA TP34
AC Mag. Fields / JB1310214000072	

Test conditions: $U_n: 3x230/400V$ $F_n: 50Hz$
 $I_n: 5A$ $PF: Cos. \phi = 1.0$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

Phase angle of the field with respect to U3 (Vph)	Direction of field orientation		
	X - X	Y - Y	Z - Z
	% Error	% Error	% Error
No Field Applied	0.12	0.09	0.09
0°	0.11	0.09	0.09
30°	0.11	0.09	0.08
60°	0.11	0.09	0.08
90°	0.11	0.09	0.08
120°	0.10	0.09	0.08
150°	0.10	0.09	0.08
180°	0.10	0.09	0.08
210°	0.10	0.09	0.09
240°	0.10	0.09	0.09
270°	0.10	0.09	0.09
300°	0.10	0.09	0.09
330°	0.10	0.09	0.09
360°	0.09	0.09	0.09

Limit of % Error Variation for Class 0.2s ± 0.5%
Class 0.5s ± 1.0%

2.5.8 Auxiliary Power Supply Voltage Variation

IEC 62053-22 X-Ref. 8.2

Test Results ID / Sample No. Aux Voltage Var / 3400000002003	Test Procedure: IEC62053-22 Aux Voltage Variation (PLE)
-----------------------------------------------------------------	---------------------------------------------------------

Test conditions: U_n : 3x230/400V U_x : 100V F_n : 50Hz
 $0.01I_n$: 0.05A PF : Cos. $\phi = 1.0$

Measurement mode - Active Energy kWh

Auxiliary Power Supply Voltage Level	% Error	Limit of % Error Variation Accuracy	
		Class 0.2s	Class 0.5s
100%	-0.07	-	-
115%	-0.07	±0.05	±0.1
85%	-0.06	±0.05	±0.1

Test conditions: U_n : 3x230/400V U_x : 400V F_n : 50Hz
 $0.01I_n$: 0.05A PF : Cos. $\phi = 1.0$

Measurement mode - Active Energy kWh

Auxiliary Power Supply Voltage Level	% Error	Limit of % Error Variation Accuracy	
		Class 0.2s	Class 0.5s
100%	-0.06	-	-
115%	-0.07	±0.05	±0.1
85%	-0.07	±0.05	±0.1

2.6 Accuracy test in the Presence of Harmonics IEC 62053-22 X-Ref. 8.2

2.6.1 Harmonic Components in the Current and Voltage Circuits X-Ref. 8.2

Test Results ID / Sample No. Harmonics / 340090000120	Test Procedure: IEC62053-22 Harmonics Tests 19EMA TP32
----------------------------------------------------------	-----------------------------------------------------------

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 6A$ $PF: Cos. \phi = 1.0$

Fundamental frequency current: $I_0 = 0.5 I_{max}$
 Fundamental frequency voltage: $U_0 = U_n$
 content of 5th harmonic current: $I_5 = 40\%$ of I_0
 content of 5th harmonic voltage: $U_5 = 10\%$ of U_n

Resulting harmonic power due to the 5th harmonic presence: $P_{resultant} = 1.04 P_0$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

		Limit of % Error Variation	
Waveform	% Error	Accuracy	
		Class 0.2s	Class 0.5s
Fundamental Only (P_0) 0.5 I_{max}	0.07	-	-
Fundamental + 5 th Harmonic ($P_{resultant} = 1.04 P_0$)	0.04	±0.4	±0.5



Harmonic Components in the Current and Voltage Circuits (cont) X-Ref. 8.2

Test Results ID / Sample No. Harmonics / 34000008115	Test Procedure: IEC62053-22 Harmonics Tests 19EMA TP32
---------------------------------------------------------	-----------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 6A* *PF: Cos. φ = 1.0*

Fundamental frequency current: $I_0 = 0.5 I_{max}$
 Fundamental frequency voltage: $U_0 = U_n$
 content of 5th harmonic current: $I_5 = 40\%$ of I_0
 content of 5th harmonic voltage: $U_5 = 10\%$ of U_n

Resulting harmonic power due to the 5th harmonic presence: $P_{resultant} = 1.04 P_0$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

Waveform	% Error	Limit of % Error Variation	
		Accuracy	
Fundamental Only (P_0) 0.5 I_{max}	-0.07	Class 0.2s -	Class 0.5s -
Fundamental + 5 th Harmonic ($P_{resultant} = 1.04 P_0$)	-0.10	±0.4	±0.5

2.6.3 Influence of Odd and Sub Harmonics in the AC Current Circuit

X-Ref. 8.2

Test Results ID / Sample No. Harmonics / 340090000120	Test Procedure: IEC62053-22 Harmonics Tests 19EMA TP32
----------------------------------------------------------	-----------------------------------------------------------

Test conditions: $U_n: 3x230/400V$ $U_x : 230V$ $F_n: 50Hz:$
 $I_n: 5A$ $PF: Cos. \phi = 1.0$

Reference current waveform: $I_{ref} = 0.5 I_n$
 Reference voltage: $U = U_n$
 Test current Phase-fired waveform: $I_{test} = \sqrt{2} \cdot I_{ref}$
 Firing points = 5ms and 15ms \pm 1ms
 Test current Burst fired waveform: $I_{test} = 2 \cdot I_{ref}$
 Distortion factor on the voltage waveform: $< 0.5 \% THD$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

Waveform	% Error	Limit of % Error Variation	
		Accuracy	
		Class 0.2s	Class 0.5s
Fundamental Only 0.5 In	0.07	-	-
Waveform Phase-fired Test current	0.15	± 0.6	± 1.5
Waveform Burst fired Test current	-0.04	± 0.6	± 1.5

Influence of Odd and Sub Harmonics in the AC Current Circuit (cont)

X-Ref. 8.2

Test Results ID / Sample No.
Harmonics / 34000008115

Test Procedure: IEC62053-22 Harmonics Tests
19EMA TP32

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz:$
 $I_n: 5A$ $PF: Cos. \phi = 1.0$

Reference current waveform: $I_{ref} = 0.5 I_n$
Reference voltage: $U = U_n$
Test current Phase-fired waveform: $I_{test} = \sqrt{2} \cdot I_{ref}$
Firing points = 5ms and 15ms \pm 1ms
Test current Burst fired waveform: $I_{test} = 2 \cdot I_{ref}$
Distortion factor on the voltage waveform: < 0.5 % THD

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

Waveform	% Error	Limit of % Error Variation	
		Accuracy	
		Class 0.2s	Class 0.5s
Fundamental Only 0.5 In	-0.08	-	-
Waveform Phase-fired Test current	0.05	± 0.6	± 1.5
Waveform Burst fired Test current	-0.21	± 0.6	± 1.5

3 ELECTRICAL REQUIREMENTS

IEC 62053-22 X-Ref. 7

3.1 Power Consumption

X-Ref. 7.1

Test Results ID / Sample No. Power Consumption / 3400600001062	Test Procedure: EN62053-22 Power Consumption 19EMA TP22
-------------------------------------------------------------------	------------------------------------------------------------

	Volts/V	Amps/A	VA	Watts/W
<p>Auxiliary Power Supply</p> <p><u>Wiring Configuration:</u> <u>Single Phase Two Wire</u></p> <p>Voltage Circuit: L1</p>	276.6	0.0153	4.28	1.94

Power consumption limits for auxiliary power supply circuits shall not exceed the following based on IEC 62053-61: 1998-02

<u>Voltage Circuits</u>	<u>Single Phase</u>	<u>Two Element</u>	<u>Three Element</u>
Basic Meter	2W 10VA	2W 10VA	2W 10VA
multi-energy meter	3W 15VA	2.5W 12.5VA	2W 10VA
Multi-function meter	5W 25VA	3.5W 17.5VA	3W 15VA

3.2 Influence of Supply Voltage

IEC 62052-11 X-Ref. 7

Voltage dips and interruptions

X-Ref. 7.1.2

Test Results ID / Sample No.
Voltage Dips / 34000002002

Test Procedure: IEC62052-11 Voltage Dips
19EMA TP10

Environmental Conditions

Power Supply	230V, 50Hz
Temperature	21°C
Relative Humidity	42%
Barometric Pressure	998mB

Test Circuit: *1 phase 2 wire, in the case of Polyphase meters tests were conducted on each voltage circuit in turn.*

The tests were applied under the following conditions;

- voltage and auxiliary circuits energised with reference voltage
- current circuits open.

Test a)	Voltage interruption of:	V = 100%
	Interruption time:	1s
	Number of interruptions:	3
	Restoring time between interruption:	50ms
Test b)	Voltage interruption of:	V = 100%
	Interruption time:	20ms
	Number of interruptions:	1
Test c)	Voltage depression of:	V=50%
	Depression time:	60s
	Number of depressions:	1

The application of the above test did not produce a change in the meter registers of more than x kWh/kvarh, and the test output did not produce a signal equivalent of more than x kWh/kvarh, where x is given by

$$x = 10^{-6} \cdot m \cdot U_n \cdot I_{max}$$

3.3 Test of Influence of Short-Time Over-Currents IEC 62053-22 X-Ref. 7.2

Test Results ID / Sample No.
STOC / 340060001062

Test Procedure: IEC62053-22 Short-Time Over-Current
I9EMA TP23

Environmental Conditions

Temperature	21°C
Relative Humidity	51%
Barometric Pressure	1008mB

Test Conditions: $I_m: 6A$ $F_n: 50Hz$

Test Circuit: $3\text{ phase } 4\text{ wire}$

The test was applied under the following conditions;

Meter for connection through current transformer:

An impulse currents were applied = $20 \times I_{max}$
At rated frequency for 0.5 second duration
Applied to each current phase

On completion of the test, the meters voltage circuits were energised at reference voltage for 1 hour after which the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions.

Power Factor	Current	% Error
$\text{Cos. } \phi = 1.0$	In	0.01

Limit of % Error: Class 0.2s $\pm 0.05\%$ for connection through a current transformer
Class 0.5s $\pm 0.05\%$ for connection through a current transformer

The meter showed no signs of damage and functioned correctly.

3.4 Test of Influence of Self Heating

IEC 227122262053-22
X-Ref. 7.3

X-Ref. 7

Test conditions:- The meter voltage circuits were energised at reference voltage for at least 2 hours, without any current in the current circuits, after which the meter's maximum rated current was applied and the meter error determined every 5 minutes. The test was conducted at power factors of both $\text{Cos. } \phi = 1.0$ and $\text{Cos. } \phi = 0.5 \text{ ind.}$

Test Results ID / Sample No. Self Heating / 340090000120	Test Procedure: IEC62053-22 Self Heating 19EMA TP24
-------------------------------------------------------------	--------------------------------------------------------

Test conditions: *Un: 3x230/400V* *Ux: 230V*
 Im: 6A *Fn: 50Hz*

Test Circuit: *3 phase 4 wire*

Measurement Mode Active Energy kWh

Elapsed Test time (minutes)	Un Im Cos. $\phi = 1.0$	Un Im Cos. $\phi = 0.5$
	<i>% Error</i>	<i>% Error</i>
1	<i>0.05</i>	<i>0.16</i>
5	<i>0.06</i>	<i>0.16</i>
10	<i>0.06</i>	<i>0.16</i>
15	<i>0.06</i>	<i>0.16</i>
20	<i>0.06</i>	<i>0.16</i>
25	<i>0.06</i>	<i>0.16</i>
30	<i>0.06</i>	<i>0.16</i>
35	<i>0.06</i>	<i>0.16</i>
40	<i>0.06</i>	<i>0.16</i>
45	<i>0.06</i>	<i>0.16</i>
50	<i>0.06</i>	<i>0.16</i>
55	<i>0.06</i>	<i>0.16</i>
60	<i>0.06</i>	<i>0.16</i>

Limit of % Error Variation: Class 0.2s $\pm 0.1\%$ @ Cos. $\phi = 1.0$ & Cos. $\phi = 0.5 \text{ ind}$
 Class 0.5s $\pm 0.2\%$ @ Cos. $\phi = 1.0$ & Cos. $\phi = 0.5 \text{ ind}$



3.5 Test of Influence of Heating

IEC 62052-11 X-Ref. 7.2

Test Results ID / Sample No.
Heating / 340000002002

Test Procedure: IEC62052-11 Heating
19EMA TP11

Test conditions: $115\%U_n: 3 \times 318.5/551.7V$ $I_{max}: 6A$ $F_n: 50Hz$

Ambient Temperature : $40^{\circ}C$
Test Duration : 2 hours
Surface Temperature Rise: 2K

Permissible temperature rise: 25K

Surface temperature of the meter was measured on the meter back, approximately 10mm above the meter current circuit and voltage circuit terminal block.

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or degradation in the meter's insulation properties.

4 ELECTROMAGNETIC COMPATIBILITY (E.M.C.) IEC 62052-11 X-Ref. 7.5

4.1 Immunity to Electrostatic Discharges (ESD) X-Ref. 7.5.2

Test Results ID / Sample No. ESD / JB1310214000072	Test Procedure: IEC62052-11 Electrostatic Discharge 19EMA TP14
-------------------------------------------------------	-------------------------------------------------------------------

The meter was tested in accordance with IEC 61000-4-2 as follows:

Environmental Conditions

Power Supply	230V, 50Hz
Temperature	19°C
Relative Humidity	40%
Barometric Pressure	998mB

E.S.D Generator specification:

Test level severities: 8kV contact, conductive surfaces / coupling planes

15kV air gap discharge - non conducting surfaces

Positive / Negative polarity

Number of discharges: 10 at each polarity

Rise time of discharge current: <1ns

Pulse duration (50%) 30ns

Time between discharges: 1s

Meter in operating condition with the voltage and auxiliary circuits energised. Current circuits open.

The application of the electrostatic discharge did not produce a change in the meter registers of more than x kWh, and the test output did not produce a signal equivalent of more than x kWh, where x is given by

$$x = 10^{-6} \cdot m \cdot Un \cdot I_{max}$$

where

x is the critical change value in kWh

m is the number of measuring elements

Un is the reference voltage

I_{max} is the maximum current

4.2 Immunity to Electromagnetic RF Fields

X-Ref. 7.5.3

Test Results ID / Sample No.
RI / JB1310214000072

Test Procedure: IEC62052-11 Radiated Immunity
19EMA TP15

The meter was tested in accordance with IEC 61000-4-3 in the SGS Anechoic chamber as follows:

Environmental Conditions

Power Supply	230V, 5A, 50Hz
Temperature	23°C
Relative Humidity	38%
Barometric Pressure	1011mB

Port:	Enclosure
Test Level:	10 V/m (test 1) & 30 V/m (test 2)
Frequency Range:	80-2000 MHz
Dwell Time:	6 Secs (test 1), 2 Secs (test 2)
Frequency Step Size:	1%
Modulation:	80%, 1 kHz Amplitude Modulation.

Operating Mode:

Mode 1) Voltage and auxiliary circuits energised with reference voltage and basic current I_b applied

Mode 2) Voltage and auxiliary circuits energised with reference voltage, with no current applied

Test Results (Radiated Immunity 80-2000MHz)

EUT Face	Polarity	Test 1 Maximum % Error Observed	Test 2	Limit of % Error Variation	
				Accuracy	
				Class 0.5s	Class 0.2s
Front	Horizontal	0.30	Note 1	±2.0	±1.0
Front	Vertical	0.18	Note 1	±2.0	±1.0
Rear	Horizontal	0.18	Note 1	±2.0	±1.0
Rear	Vertical	0.18	Note 1	±2.0	±1.0
LHS	Horizontal	0.18	Note 1	±2.0	±1.0
LHS	Vertical	0.30	Note 1	±2.0	±1.0
RHS	Horizontal	0.18	Note 1	±2.0	±1.0
RHS	Vertical	0.18	Note 1	±2.0	±1.0



Immunity to Electromagnetic RF Fields (cont)

X-Ref. 7.5.3

Note 1: The application of the RF electromagnetic field did not produce a change in the meter registers of more than x kWh, and the test output did not produce a signal equivalent of more than x kWh, where x is given by

$$x = 10^{-6} \cdot m \cdot U_n \cdot I_{max}$$

where

x is the critical change value in kWh

m is the number of measuring elements

U_n is the reference voltage

I_{max} is the maximum current

4.3 Fast Transient Burst Test

X-Ref. 7.5.4

Test Results ID / Sample No.
FTB / JB1310426000105

Test Procedure: IEC62052-11 Fast Transient Bursts
I9EMA TP16

The meter was tested in accordance with IEC 61000-4-4 as follows:

Environmental Conditions

Power Supply	230V, 5A, 50Hz
Temperature	20°C
Relative Humidity	44%
Barometric Pressure	992 mB

Transient/Burst specification:

- Pulse level severity 2kV & 4kV
- Rise time 5ns
- Width 50ns
- Repetition Rate 5 kHz & 2.5 kHz
- Burst Duration 15ms
- Burst Period 300ms
- Burst Generation Asynchronous (Common mode)

Operating mode: The meter voltage circuits were energised at reference voltage U_n , with $I_b/I_n \cos \phi = 1.0$ in the current circuits.

Test voltage severity level $\pm 4kV$, Repetition Rate 5kHz voltage and current circuits
Test voltage severity level $\pm 2kV$, Repetition Rate 5kHz auxiliary circuits $> 40V$

The test voltage was applied on the current and voltage circuits in common mode, for a test duration of 60 seconds at each polarity.



Fast Transient Burst Test (cont)

X-Ref. 7.5.4

Test conditions: $Un: 3x230/400V$ $Fn: 50Hz$
 $In: 5A$ $PF: Cos. \phi = 1.0$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

Test Voltage (kV)	% Error	Limit of % Error Variation	
		Accuracy	
		Class 0.2s	Class 0.5s
No FTB applied	-0.007	-	-
+4 Voltage Circuits	0.065	±1.0	±2.0
-4 Voltage Circuits	-0.073	±1.0	±2.0
+4 Current Circuits	0.065	±1.0	±2.0
-4 Current Circuits	0.058	±1.0	±2.0
No FTB applied	0.005	±1.0	±2.0
+2 (Auxiliary Circuits of > 40V)	0.051	±1.0	±2.0
-2 (Auxiliary Circuits of > 40V)	-0.007	±1.0	±2.0

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or corruption to meter register data.

4.4 Immunity to Conducted Disturbances

X-Ref. 7.5.5

Test Results ID / Sample No.
CI / JB1310214000072

Test Procedure: IEC62052-11 Conducted Immunity
I9EMA TP17

The meter was tested in accordance with IEC 61000-4-6 as follows:

Environmental Conditions

Power Supply	230V, 5A, 50Hz
Temperature	20°C
Relative Humidity	44%
Barometric Pressure	980mB

Ports:	Current, Voltage and Auxiliary Circuits
Test Level:	10 V
Frequency Range:	0.15 to 80 MHz
Dwell Time:	4 Secs
Frequency Step Size:	1%
Modulation:	80%, 1kHz Amplitude Modulation.

The compliance test was performed as follows:

Operating Mode

Voltage and auxiliary circuits energised with reference voltage and with basic current I_b applied

Test Results

MUT Port	Frequency Range (MHz)	% Error	Limit of % Error Variation	
			Accuracy	
			Class 0.5s	Class 0.2s
Voltage & Current Circuits	0.15 to 80	0.12	±2.0	±1.0
Auxiliary Circuits	0.15 to 80	0.36	±2.0	±1.0



4.5 Surge Immunity

X-Ref 7.5.6

Test Results ID / Sample No.
Surge / JB1310214000072

Test Procedure: IEC62052-11 Surge
19EMA TP18

The meter was tested in accordance with IEC 61000-4-5 as follows:

Ports:	Voltage and Auxiliary Circuits
Test Voltage:	4kV mains, 1kV auxiliary
Test Mode:	Differential
Phase Angle:	60° and 240° relative to zero crossing
Number of Tests:	5 positive and 5 negative
Repetition Rate:	1/min

Environmental Conditions

Power Supply	230V, 50Hz
Temperature	19°C
Relative Humidity	40 %
Barometric Pressure	998mB

The application of the surge immunity test voltage did not produce a change in the meter registers of more than x kWh and the test output did not produce a signal equivalent of more than x kWh, where x is given by

$$x = 10^{-6} \cdot m \cdot U_n \cdot I_{max}$$

4.6 Immunity to Damped Oscillatory Waves

X-Ref. 7.5.7

Test Results ID / Sample No.
DOW / JB1310426000105

Test Procedure: IEC62052-11 Damped Oscillatory Waves
19EMA TP19

The meter was tested in accordance with IEC 61000-4-12 as follows:

Environmental Conditions

Temperature	20°C
Relative Humidity	42%
Barometric Pressure	996mB

Ports:	Voltage and Auxiliary Circuits
Test Level:	Common Mode: 2.5kV Differential Mode: 1kV
Test Frequencies:	100 kHz, repetition rate: 40Hz 1 MHz, repetition rate: 400Hz
Test Duration:	60s (15 cycles with 2s on, 2s off, for each frequency)
Operating Mode:	The meter voltage and auxiliary circuits were energised at reference voltage U_n , with I_b/I_n $\text{Cos. } \phi = 1.0$ in the current circuits.

The test voltage was applied on the voltage circuits in common & differential coupling, for a test duration of 60 seconds at each polarity.



Immunity to Damped Oscillatory Waves (cont.)

X-Ref. 7.5.7

Test a)100kHz Test Frequency Results:

3 Phase Voltage Supply			Limit of % Error Variation	
Test Voltage(kV)	Coupling	% Error	Accuracy	
			Class 0.2s	Class 0.5s
No DOW's applied	-	0.020	-	-
±1	L1-N	0.226	±1.0	±2.0
±1	L2-N	0.219	±1.0	±2.0
±1	L3-N	0.226	±1.0	±2.0
±1	L1-L2	0.027	±1.0	±2.0
±1	L1-L3	0.034	±1.0	±2.0
±1	L2-L3	0.034	±1.0	±2.0
±2.5	L1,L2,L3,N	0.167	±1.0	±2.0

Auxiliary Power Supply			Limit of % Error Variation	
Test Voltage(kV)	Coupling	% Error	Accuracy	
			Class 0.2s	Class 0.5s
±1	L1-L2	0.027	±1.0	±2.0
±2.5	L1 & L2	0.034	±1.0	±2.0

Immunity to Damped Oscillatory Waves (cont.)

X-Ref. 7.5.7

Test b) 1MHz Test Frequency Results:

3 Phase Voltage Supply			Limit of % Error Variation	
Test Voltage(kV)	Coupling	% Error	Accuracy	
			Class 0.2s	Class 0.5s
No DOW's applied	-	0.020	-	-
±1	L1-N	0.226	±1.0	±2.0
±1	L2-N	0.234	±1.0	±2.0
±1	L3-N	0.226	±1.0	±2.0
±1	L1-L2	0.049	±1.0	±2.0
±1	L1-L3	0.034	±1.0	±2.0
±1	L2-L3	0.042	±1.0	±2.0
±2.5	L1,L2,L3,N	0.182	±1.0	±2.0

Auxiliary Power Supply			Limit of % Error Variation	
Test Voltage(kV)	Coupling	% Error	Accuracy	
			Class 0.2s	Class 0.5s
±1	L1-L2	0.027	±1.0	±2.0
±2.5	L1 & L2	0.020	±1.0	±2.0



4.7 Radio Interference Measurement

X-Ref. 7.5.8

Radiated Emissions

Sample No.:
JB1310214000072

Test Procedure: IEC62052-11 Radiated Emissions
19EMA TP21

The meter was tested in accordance with EN55022 as follows:

Environmental Conditions

Power Supply	230V, 50Hz
Temperature	21°C
Relative Humidity	39%
Barometric Pressure	1014mB

The MUT compliance measurements were performed in the SGS Semi-Anechoic chamber (which is in compliance with the site attenuation requirements of EN55016-1-4:2007, A1:2008).

The measurement distance was 3m and the limit has been adjusted using inverse proportionality factor of 20dB per decade.

Operating Mode: The MUT was operated with voltage and auxiliary circuits energised with reference voltage and a current of between 0.1Iref and 0.2Iref and 1m leads attached to all terminals.




Radiated Emissions (cont)

Results:

Vertical Polarisation Worst Case Emissions Compliance Measurements 30-1000MHz

SGS Radiated Emissions 30-1000MHz - Vertical



Frequency (MHz)	QuasiPeak (dBµV/m)	Meas. Time (ms)	Bandwidth (kHz)	Height (cm)	Polarization	Azimuth (deg)	Corr. (dB)	Margin (dB)	Limit (dBµV/m)
33.640000	29.8	15000.0	120.000	100.0	V	198.0	18.8	10.2	40.0
35.120000	32.6	15000.0	120.000	100.0	V	16.0	17.8	7.4	40.0
46.520000	17.1	15000.0	120.000	100.0	V	51.0	10.8	22.9	40.0
109.040000	20.5	15000.0	120.000	100.0	V	111.0	8.0	19.5	40.0
148.000000	29.5	15000.0	120.000	100.0	V	86.0	9.7	10.5	40.0
159.520000	28.4	15000.0	120.000	100.0	V	76.0	10.5	11.6	40.0
188.360000	25.1	15000.0	120.000	100.0	V	80.0	11.1	14.9	40.0
403.640000	27.3	15000.0	120.000	138.0	V	0.0	16.2	19.7	47.0
497.160000	27.1	15000.0	120.000	100.0	V	86.0	18.6	19.9	47.0
703.760000	23.8	15000.0	120.000	100.0	V	274.0	22.0	23.2	47.0




Radiated Emissions (cont)

Results:

Vertical Polarisation Worst Case Emissions Compliance Measurements 1-6GHz

Note: Emissions between 1.85-2GHz are ambient emissions and are not produced by the MUT

SGS Radiated Emissions 1-6GHz - Vertical



Max Peak

Frequency (MHz)	MaxPeak (dBµV/m)	Meas. Time (ms)	Bandwidth (kHz)	Height (cm)	Polarization	Azimuth (deg)	Corr. (dB)	Margin (dB)	Limit (dBµV/m)	Comment
1148.400000	38.0	15000.0	1000.000	100.0	V	22.0	-13.4	32.0	70.0	
1158.800000	40.3	15000.0	1000.000	100.0	V	26.0	-13.3	29.7	70.0	
1247.200000	40.7	15000.0	1000.000	100.0	V	358.0	-12.5	29.3	70.0	
1323.600000	40.9	15000.0	1000.000	111.0	V	12.0	-11.9	29.1	70.0	
1383.200000	39.1	15000.0	1000.000	111.0	V	6.0	-11.4	30.9	70.0	
1690.800000	37.6	15000.0	1000.000	111.0	V	280.0	-9.0	32.4	70.0	

Averages

Frequency (MHz)	CAverage (dBµV/m)	Meas. Time (ms)	Bandwidth (kHz)	Height (cm)	Polarization	Azimuth (deg)	Corr. (dB)	Margin (dB)	Limit (dBµV/m)	Comment
1148.400000	25.6	15000.0	1000.000	100.0	V	22.0	-13.4	24.4	50.0	
1158.800000	27.4	15000.0	1000.000	100.0	V	26.0	-13.3	22.6	50.0	
1247.200000	29.3	15000.0	1000.000	100.0	V	358.0	-12.5	20.7	50.0	
1323.600000	30.4	15000.0	1000.000	111.0	V	12.0	-11.9	19.6	50.0	
1383.200000	27.9	15000.0	1000.000	111.0	V	6.0	-11.4	22.1	50.0	
1690.800000	24.1	15000.0	1000.000	111.0	V	280.0	-9.0	25.9	50.0	




Radiated Emissions (cont)

Results:

Horizontal Polarisation Worst Case Emissions Compliance Measurements 30-1000MHz

SGS Radiated Emissions 30-1000MHz - Horizontal



Frequency (MHz)	QuasiPeak (dBµV/m)	Meas. Time (ms)	Bandwidth (kHz)	Height (cm)	Polarization	Azimuth (deg)	Corr. (dB)	Margin (dB)	Limit (dBµV/m)
34.840000	20.3	15000.0	120.000	192.0	H	136.0	18.0	19.7	40.0
75.840000	19.7	15000.0	120.000	302.0	H	324.0	7.2	20.3	40.0
108.000000	22.9	15000.0	120.000	209.0	H	293.0	8.1	17.1	40.0
152.760000	25.6	15000.0	120.000	136.0	H	110.0	10.2	14.4	40.0
458.320000	32.9	15000.0	120.000	158.0	H	33.0	17.4	14.1	47.0
576.200000	31.0	15000.0	120.000	111.0	H	46.0	19.8	16.0	47.0




Radiated Emissions (cont)

Results:

Horizontal Polarisation Worst Case Emissions Compliance Measurements 1-6GHz

Note: Emissions between 1.85-2GHz are ambient emissions and are not produced by the MUT

SGS Radiated Emissions 1-6GHz - Horizontal



Max Peak

Frequency (MHz)	MaxPeak (dBµV/m)	Meas. Time (ms)	Bandwidth (kHz)	Height (cm)	Polarization	Azimuth (deg)	Corr. (dB)	Margin (dB)	Limit (dBµV/m)
1172.400000	39.6	15000.0	1000.000	100.0	H	71.0	-13.2	30.4	70.0
1245.200000	41.1	15000.0	1000.000	100.0	H	293.0	-12.5	28.9	70.0
1260.800000	40.2	15000.0	1000.000	100.0	H	290.0	-12.4	29.8	70.0
1286.800000	40.4	15000.0	1000.000	100.0	H	285.0	-12.2	29.6	70.0
1557.200000	37.4	15000.0	1000.000	150.0	H	18.0	-9.8	32.6	70.0
1815.200000	38.0	15000.0	1000.000	293.0	H	0.0	-8.4	32.0	70.0

Averages

Frequency (MHz)	CAverage (dBµV/m)	Meas. Time (ms)	Bandwidth (kHz)	Height (cm)	Polarization	Azimuth (deg)	Corr. (dB)	Margin (dB)	Limit (dBµV/m)
1172.400000	24.0	15000.0	1000.000	312.0	H	103.0	-13.2	26.0	50.0
1245.200000	30.2	15000.0	1000.000	100.0	H	285.0	-12.5	19.8	50.0
1260.800000	26.8	15000.0	1000.000	100.0	H	309.0	-12.4	23.2	50.0
1286.800000	29.8	15000.0	1000.000	100.0	H	285.0	-12.2	20.2	50.0
1557.200000	23.6	15000.0	1000.000	233.0	H	104.0	-9.8	26.4	50.0
1815.200000	24.6	15000.0	1000.000	150.0	H	52.0	-8.4	25.4	50.0



Radio Interference Measurement (cont)

X-Ref. 7.5.8

Conducted Emissions

Sample No.:
JB1310214000072

Test Procedure: IEC62052-11 Conducted Emissions
19EMA TP21

The meter was tested in accordance with EN55022 as follows:

Environmental Conditions

Power Supply	230V, 50Hz
Temperature	20°C
Relative Humidity	40%
Barometric Pressure	998mB

The emissions on the AC mains were measured in the frequency range 0.15 – 30 MHz

Operating Mode: The MUT was operated with voltage and auxiliary circuits energised with reference voltage and a current of between 0.1Iref and 0.2Iref and 1m leads attached to all terminals.




Conducted Emissions (cont)

Results:

Line 1 Terminal Worst Case Emissions Compliance Measurements

Mains Terminals 0.15-30MHz PEAKS



Frequency (MHz)	QuasiPeak (dBµV)	CAverage (dBµV)	Meas. Time (ms)	Bandwidth (kHz)	Corr. (dB)	Comment
0.150481	42.7	35.2	15000.0	9.000	9.1	
0.245288	36.1	32.1	15000.0	9.000	9.2	
0.372819	31.1	26.8	15000.0	9.000	9.2	
0.798244	33.1	29.1	15000.0	9.000	9.3	
1.250619	32.4	28.5	15000.0	9.000	9.3	
1.731388	30.3	26.8	15000.0	9.000	9.3	
2.278569	28.8	25.4	15000.0	9.000	9.3	
2.744900	27.3	23.6	15000.0	9.000	9.4	
5.146750	26.7	23.3	15000.0	9.000	9.9	
13.711250	38.1	36.7	15000.0	9.000	10.6	
15.409000	41.8	40.2	15000.0	9.000	10.7	
17.630000	42.5	40.3	15000.0	9.000	10.6	




Conducted Emissions (cont)

Results:

Line 2 Terminal Worst Case Emissions Compliance Measurements

Mains Terminals 0.15-30MHz PEAKS



Frequency (MHz)	QuasiPeak (dBµV)	CAverage (dBµV)	Meas. Time (ms)	Bandwidth (kHz)	Corr. (dB)	Comment
0.153850	40.1	33.4	15000.0	9.000	9.1	
0.237106	35.0	31.0	15000.0	9.000	9.2	
0.709212	32.0	27.9	15000.0	9.000	9.3	
1.228481	31.2	27.4	15000.0	9.000	9.3	
1.753525	29.7	26.4	15000.0	9.000	9.3	
2.214081	27.9	24.8	15000.0	9.000	9.3	
2.727575	26.3	22.8	15000.0	9.000	9.4	
13.682375	40.6	38.6	15000.0	9.000	10.6	
15.243000	46.4	44.6	15000.0	9.000	10.7	
0.366562	30.1	25.9	15000.0	9.000	9.2	




Conducted Emissions (cont)

Results:

Line 3 Terminal Worst Case Emissions Compliance Measurements

Mains Terminals 0.15-30MHz PEAKS



Frequency (MHz)	QuasiPeak (dBµV)	CAverage (dBµV)	Meas. Time (ms)	Bandwidth (kHz)	Corr. (dB)	Comment
0.154331	39.5	33.4	15000.0	9.000	9.1	
0.254431	34.0	30.7	15000.0	9.000	9.2	
0.353569	29.0	25.7	15000.0	9.000	9.2	
0.775625	31.4	28.2	15000.0	9.000	9.3	
1.251100	30.7	27.8	15000.0	9.000	9.3	
1.786250	29.4	26.9	15000.0	9.000	9.3	
2.313219	28.2	25.6	15000.0	9.000	9.3	
2.673194	26.5	24.0	15000.0	9.000	9.4	
13.678875	38.3	36.5	15000.0	9.000	10.6	
15.242000	47.4	45.3	15000.0	9.000	10.7	




Conducted Emissions (cont)

Results:

Neutral Terminal Worst Case Emissions Compliance Measurements

Mains Terminals 0.15-30MHz PEAKS



Frequency (MHz)	QuasiPeak (dBµV)	CAverage (dBµV)	Meas. Time (ms)	Bandwidth (kHz)	Corr. (dB)	Comment
0.151925	47.2	40.5	15000.0	9.000	9.1	
0.251062	42.5	39.4	15000.0	9.000	9.2	
0.753488	39.5	36.2	15000.0	9.000	9.3	
1.219338	37.8	34.7	15000.0	9.000	9.3	
1.299225	37.8	34.7	15000.0	9.000	9.3	
1.764112	36.1	33.3	15000.0	9.000	9.3	
2.371931	33.4	30.9	15000.0	9.000	9.3	
2.770406	34.4	31.9	15000.0	9.000	9.4	
3.240588	30.8	28.3	15000.0	9.000	9.5	
5.078875	32.8	30.1	15000.0	9.000	9.9	
5.620750	32.7	30.1	15000.0	9.000	10.0	
13.712125	26.8	24.1	15000.0	9.000	10.6	
15.409000	22.6	18.4	15000.0	9.000	10.7	
17.629000	27.5	23.3	15000.0	9.000	10.6	




Conducted Emissions (cont)

Results:

Line 1 Auxiliary Voltage Terminal Worst Case Emissions Compliance Measurements

Mains Terminals 0.15-30MHz PEAKS




Frequency (MHz)	QuasiPeak (dBµV)	CAverage (dBµV)	Meas. Time (ms)	Bandwidth (kHz)	Corr. (dB)	Comment
0.155294	47.4	40.5	15000.0	9.000	9.2	
0.244806	46.5	43.0	15000.0	9.000	9.2	
0.343944	43.4	39.9	15000.0	9.000	9.3	
0.754450	47.2	43.8	15000.0	9.000	9.3	
1.253025	46.2	43.0	15000.0	9.000	9.3	
1.751119	44.0	41.1	15000.0	9.000	9.3	
2.256431	41.7	39.0	15000.0	9.000	9.4	
2.259800	41.7	39.0	15000.0	9.000	9.4	
2.744900	40.5	37.6	15000.0	9.000	9.4	
3.226150	37.2	34.3	15000.0	9.000	9.5	
3.640506	32.8	29.8	15000.0	9.000	9.6	
4.660000	39.9	37.1	15000.0	9.000	9.7	
5.112250	43.4	40.6	15000.0	9.000	9.7	
5.576500	43.5	40.6	15000.0	9.000	9.8	
6.496000	42.3	38.8	15000.0	9.000	9.9	
7.393750	43.6	40.4	15000.0	9.000	9.9	
15.433000	44.1	42.7	15000.0	9.000	10.3	

Conducted Emissions (cont)

Results:

Line 2 Auxiliary Voltage Terminal Worst Case Emissions Compliance Measurements

Mains Terminals 0.15-30MHz PEAKS



Frequency (MHz)	QuasiPeak (dBµV)	CAverage (dBµV)	Meas. Time (ms)	Bandwidth (kHz)	Corr. (dB)	Comment
0.154331	51.4	45.6	15000.0	9.000	9.2	
0.249619	47.7	44.2	15000.0	9.000	9.2	
0.381962	43.7	39.9	15000.0	9.000	9.3	
0.736644	47.1	43.7	15000.0	9.000	9.3	
1.279494	46.2	43.0	15000.0	9.000	9.3	
1.764112	44.0	41.1	15000.0	9.000	9.3	
2.306481	41.8	39.1	15000.0	9.000	9.4	
2.769925	40.5	37.6	15000.0	9.000	9.4	
3.243475	37.1	34.2	15000.0	9.000	9.5	
4.658125	40.4	37.5	15000.0	9.000	9.7	
5.151250	43.6	40.8	15000.0	9.000	9.7	
6.139750	43.5	40.7	15000.0	9.000	9.8	
7.043750	44.3	41.3	15000.0	9.000	9.9	
13.762000	47.9	46.0	15000.0	9.000	10.3	
15.437000	48.2	46.9	15000.0	9.000	10.3	

5 CLIMATIC INFLUENCES

IEC 62052-11 X-Ref. 6

5.1 Dry Heat Test

X-Ref. 6.3.1

Test Results ID / Sample No. Dry Heat / 340090000120	Test Procedure: IEC62052-11 Dry Heat 19EMA TP07
---------------------------------------------------------	----------------------------------------------------

The meter was tested in accordance with IEC 60068-2-2 as follows:

Meter in the non-operating condition
Temperature $+85^{\circ}\text{C} \pm 2^{\circ}\text{C}$
Duration of the test 72h

On completion of the above test the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions with no signs of damage or degradation in the meter's insulation properties.

5.2 Cold Test

X-Ref. 6.3.2

Test Results ID / Sample No. Cold / 340000002001	Test Procedure: EN62052-11 Cold 19EMA TP08
-----------------------------------------------------	-----------------------------------------------

The meter was tested in accordance with IEC 60068-2-1 as follows:

Meter in the non-operating condition
Temperature $-40^{\circ}\text{C} \pm 3^{\circ}\text{C}$
Duration of the test 72h

On completion of the above test the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or corruption to meter register data.

5.3 Damp Heat, Cyclic Test

X-Ref. 6.3.3

Test Results ID / Sample No. Damp Heat / 340060001062	Test Procedure: IEC62052-11 Damp Heat 19EMA TP09
----------------------------------------------------------	-----------------------------------------------------

The meter was tested in accordance with IEC 60068-2-30 as follows:

Meter with reference voltage applied
Upper Temperature of $+40^{\circ}\text{C}$
Duration of the test: 6 cycles

On completion of the above test the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions with no signs of damage or degradation in the meter's insulation properties.



6 MECHANICAL REQUIREMENTS

IEC 62052-11 X-Ref. 5.2.2

6.1 Spring Hammer Test

X-Ref. 5.2.2.1

Test Results ID / Sample No.
Spring Hammer / 34000002002

Test Procedure: IEC62052-11 Spring Hammer
19EMA TP01

Environmental Conditions

Temperature	22°C
Relative Humidity	42%
Barometric Pressure	1001mB

The meter was tested in accordance with IEC 60068-2-75 as follows:

Kinetic Energy of Spring Hammer 0.2 Nm ± 0.05 Nm

The meter case and terminal cover where acted upon all external surfaces, including the display window. After the test no damage was evident and the meter continued to function correctly.



MECHANICAL REQUIREMENTS (cont)

IEC 62052-11 X-Ref. 5.2.2

6.2 Shock Test

X-Ref. 5.2.2.2

Test Results ID / Sample No.
Shock / 340060001062

Test Procedure: IEC62052-11 Shock
19EMA TP02

Environmental Conditions

Temperature	21°C
Relative Humidity	51%
Barometric Pressure	1008mB

The meter was tested in accordance with IEC 60068-2-27 as follows:

Meter in the non-operating condition
Half Sine Pulse
Peak Acceleration of 30 gn (300 m/s²)
Pulse Duration of 18 ms

On completion of the above tests the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions.

6.3 Vibration Test

X-Ref. 5.2.2.3

Test Results ID / Sample No.
Vibration / 340060001062

Test Procedure: IEC62052-11 Vibration
19EMA TP03

Environmental Conditions

Temperature	21°C
Relative Humidity	51%
Barometric Pressure	1008mB

The meter was tested in accordance with IEC 60068-2-6 as follows:

Meter in the non-operating condition
Test Procedure A
Frequency Range of 10 Hz to 150 Hz (Transition frequency of 60 Hz)
For $F < 60$ Hz, constant amplitude of movement 0.075 mm
For $F > 60$ Hz, constant acceleration of 9.8 m/s² (1g)
10 sweep cycles per axis

On completion of the above test the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions.



6.4 Resistance to Heat & Fire

X-Ref. 5.8

Test Results ID / Sample No. Heat & Fire / 340090000114 & New Case Sample No. 1	Test Procedure: IEC62052-11 Heat & Fire 19EMA TP04
------------------------------------------------------------------------------------	-------------------------------------------------------

The meter was tested in accordance with IEC 60695-2-11 as follows:

Terminal block tested at 960°C for 30 seconds.

Result: Flames extinguish with 30 seconds when glow wire removed.

Terminal cover and meter case tested at 650°C for 30 seconds.

Result: No flames or drips occur.



6.5 Penetration of Dust & Water

X-Ref. 5.9

At the request of Schneider the meter was fitted to an IP66 rated enclosure for the dust and water ingress tests

Penetration of Dust

Sample No: Sample 340000002002	Test Procedure: IEC50470-1 Dust & Water 19EMA TP05
-----------------------------------	-------------------------------------------------------

The penetration of dust test was conducted at an external accredited laboratory as given in the supporting documentation

The ac/impulse voltage tests were performed at SGS (UK)

The meter was tested in accordance with IEC 60529 as follows:

Dust Test: IP5X, non-operating condition, Neither under, nor over pressure

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions with no signs of damage or degradation in the meter's insulation properties.

Penetration of Water

Sample No: Sample 340000002003	Test Procedure: IEC50470-1 Dust & Water 19EMA TP05
-----------------------------------	-------------------------------------------------------

The meter was tested in accordance with IEC 60529 as follows:

Water Test: IPX1, non-operating condition

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions with no signs of damage or degradation in the meter's insulation properties.

ANNEX A Photographs of Meter Under Test

Front View




Rear View



Photographs of Meter Under Test (cont)

LHS View




RHS View



Photographs of Meter Under Test (cont)

Top View



Bottom View

