

Certificate of Compliance

Number: **1877**

Product: **Clipsal type WHS series – single pole**
Clipsal type WHD series – double pole
Clipsal type WHT series – triple pole
surface mounting switches

<u>Series</u>	<u>Model</u>	<u>Voltage (V)</u>	<u>Current (A)</u>
WHS	WHS20	250	20
	WHS35	250	35
	WHS55	250	55
	WHS63	250	63
WHD	WHD20	250	20
	WHD35	250	35
	WHD55	250	55
	WHD63	250	63
WHT	WHT20	440	20
	WHT35	440	35
	WHT55	440	55
	WHT63	440	63
	WHT80	440	80

Client: **Clipsal Asia Limited.**
Kwai Chung N.T. Hong Kong

Examined and tested to the relevant requirements of: **BS EN 60529: 1992**
Specification for degrees of protection provided by enclosures (IP code)


Result: **Complied IP66**

Note:

This **test certificate** is based on assessment(s) and test(s) applied to the specific **test item(s)** as submitted by the **client**. ITACS disclaims any and all responsibility or obligation for any other item.

Initial distribution: **Client (1)** **ITACS file (1)**
original **copy**

Authorised signature:



Jurek W. Botiuk 30th January 2001

ITACS[®]

**International Testing and
Certification Services**
NATA ACCREDITATION 1700

PO Box 300, Hindmarsh
South Australia 5007
4-6 Second Street, Bowden
South Australia 5007
Telephone (08) 8346 8680
International + 61 8 8346 8680
Facsimile (08) 8346 7072
E-Mail itacs@itacslab.com

ITACS[®]

**International Testing and
Certification Services**

NATA ACCREDITATION 1700

PO Box 300, Hindmarsh

South Australia 5007

4-6 Second Street, Bowden

South Australia 5007

Telephone (08) 8346 8680

International + 61 8 8346 8680

Facsimile (08) 8346 7072

E-Mail itacs@itacslab.com

30th January 2001

Clipsal Asia Limited
3/F Wyler Centre One,
200 Tai Lin Pai Road,
Kwai Chung N.T. Hong Kong
Attention Fiona Ko

Dear Fiona

Subject: Certificate of Compliance 1877

Please find enclosed Certificate of Compliance 1877 for the Clipsal WHS Series, WHD Series and WHT Series. The reports will follow shortly.

Regards



**Adam Kennewell
Testing Officer**