

ADDENDUM TO 3710 ACM INSTALLATION AND OPERATION MANUAL

P24/48 OPTION

92/6/12

WARNING

THE UNIT CONTAINED WITHIN IS SPECIALLY
DESIGNED TO OPERATE FROM 24 OR 48 VOLT D.C.

APPLICATION OF A.C. VOLTAGE TO THE "POWER" INPUT
TERMINALS WILL PERMANENTLY DAMAGE THE UNIT AND
VOID THE WARRANTY.

DO NOT HIPOT TEST THE POWER INPUT TERMINALS OF THIS
UNIT.

POWER SUPPLY WIRING

Positive D.C. Voltage Wire: 3710 ACM "L" Terminal.

Negative D.C. Voltage Wire: 3710 ACM "N" Terminal.