



333 Pfingsten Road
Northbrook, Illinois 60062-2096
United States Country Code (1)
(847) 272-8800
FAX No. (847) 272-8129
<http://www.ul.com>

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 120901-E161835A

ISSUE DATE: September 12, 2001

Page 1 of 2

Issued to:

Merlin Gerin, DBA Schneider Electric S A
Av Des Jeux Olympiques, 38050
Grenoble Cedex 9 France

Report Reference:

E161835, January 18, 2000

**This is to Certify that
representative samples of:**

Low Voltage AC Power Circuit Breaker Masterpact, Type NW with suffix
N1, H1, H2, H3 and L1

**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.**

Standard(s) for Safety:

UL 1066, the Standard for Low Voltage AC and DC Power Circuit Breakers
used in Enclosures and ANSI 37.50, Low Voltage AC Power Circuit Breakers
used in Enclosures.

Additional Information:

These breakers are rated 400A through 5000A with a maximum voltage rating
of 635 V ac as listed in the attached addendum.

**Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number
(may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Gail Zielen*
Gail Zielen, Engineering Project Handler
Underwriters Laboratories Inc.

Review Engineer: *Antonio L. Romanacce*
Antonio Romanacce, Project Engineer
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service



333 Pfingsten Road
Northbrook, Illinois 60062-2096
United States Country Code (1)
(847) 272-8800
FAX No. (847) 272-8129
<http://www.ul.com>

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 120901-E161835A

Page 2 of 2

ISSUE DATE: September 12, 2001

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

C.B Type	<u>S.C. Current Rating (kA, rms, sym)</u>		
	<u>254 V Max.</u>	<u>508 V Max.</u>	<u>635 V Max.</u>
Type N1	42	42	42
Type H1	65	65	65
Type H2	85	85	85
Type H3	100	100	85
Type L1	200	200	130

Engineer: *Gail Zielen*
Gail Zielen, Engineering Project Handler

Review Engineer: *Antonio L. Romanacce*
Antonio Romanacce, Project Engineer

A not-for-profit organization
dedicated to public safety and
committed to quality service