

Certificate of Compliance

Certificate Number **20111026 – E63335**
Report Reference **E63335 – 2011 June 10**
Issue Date **2011 October 26**

Page 1 of 1



Issued to: SCHNEIDER ELECTRIC INDUSTRIES S A S
ELECTROPOLE/EYBENS, POWER / LV
31 RUE PIERRE MENDES FRANCE
38050 GRENOBLE CEDEX 9, FRANCE

*This is to certify that
representative samples of*

**Circuit Breakers, Molded Case and Circuit-breaker
Enclosures**

**Molded case circuit breakers POWERPACT L with suffix LD, LG, LJ, LL
or NLD, NLG, NLJ, NLL rated 250A, 400 A and 600 A, 600 V ac, 3 poles.**

Square D - Type LD, LG, LJ, LL

Schneider Electric - Type NLD, NLG, NLJ, NLL

*Have been investigated by Underwriters Laboratories in accordance with
the Standard(s) indicated on this Certificate.*

**Standard(s) for Safety: ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and
Circuit-Breaker Enclosures."**

Additional Information: See UL On-line Certification Directory at WWW.UL.COM for additional information.

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and
Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word
"LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product
identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus>