

Northbrook, Illinois • (847) 72-8800
Melville, New York • (631) 71-6200
Santa Clara, California • (415) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 877-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 111201-E10027

ISSUE DATE: December 11, 2001

Page 1 of 1

Issued to: Square D Company
3700 6th Street S.W.
Cedar Rapids, IA 52404 USA

Report Reference: E10027, October 18, 2001

**This is to Certify that
representative samples of:** Molded Case Circuit Breakers, Powerpact R, Catalog number Prefix RG, RJ, RK
or RL may or may not be preceded by N, F or P.

**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.**

Standard(s) for Safety: UL 489, Molded Case Circuit Breakers & Circuit Breaker Enclosures

Additional Information: These are two, three or four pole circuit breakers, rated from 600A through 2500A, 600 V ac
maximum, 50/60 Hz.
Current Interrupting Ratings is as follows:
1) 125,000A, 240 V ac, 3 phase, 50/60 Hz
2) 100,000A, 480 V ac, 3 phase, 50/60 Hz
3) 65,000A, 600 V ac, 3 phase, 50/60 Hz
+ also applies to two pole breakers rated 1-3 phase

**Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number
(may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Lawrence R. Smith*
Lawrence R. Smith, Lead Eng. Associate
Underwriters Laboratories Inc.

Review Engineer: *Antonio L. Romanacce*
Antonio Romanacce, Eng. Team Leader
Underwriters Laboratories Inc.