

CERTIFICATE OF COMPLIANCE

Certificate Number 20140612-E301538
Report Reference E301538-20051209
Issue Date 2014-JUNE-12

Issued to: SCHNEIDER ELECTRIC INDUSTRIES SAS
ELECTROPOLE/EYBENS, POWER / FD
31 RUE PIERRE MENDES FRANCE
38050 GRENOBLE CEDEX 9 FRANCE

**This is to certify that
representative samples of**

GROUND FAULT SENSING AND RELAYING
EQUIPMENT

Ground Fault, Type GFP, rated 25, 40, 63, 80, 100A, 2P,
4P, 26mA, 86mA, 260mA from 120V AC to 480Y/277 Vac.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1053 - Ground-Fault Sensing and Relaying Equipment
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

