

Electrical network protection

Easergy Sepam series 80

Modbus Communication

User's manual
02/2017



Safety instructions

Safety symbols and messages

Read these instructions carefully and look at the equipment to become familiar with the device before trying to install, operate, service or maintain it. The following special messages may appear throughout this bulletin or on the equipment to warn of potential hazards or to call attention to information that clarifies or simplifies a procedure.



ANSI symbol.

IEC symbol.

Risk of electric shock

The addition of either symbol to a Danger or Warning safety label indicates that an electrical hazard exists, which will result in personal injury if the instructions are not followed.

Safety alert

This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages that follow this symbol to avoid possible injury or death.



Safety messages

▲ DANGER

DANGER indicates an imminently hazardous situation which, if not avoided, **will result in death or serious injury.**

▲ WARNING

WARNING indicates a potentially hazardous situation which, if not avoided, **can result in death or serious injury.**

▲ CAUTION

CAUTION indicates a potentially hazardous situation which, if not avoided, **can result in minor or moderate injury.**

NOTICE

NOTICE is used to address practices not related to physical injury.

Important notes

Restricted liability

Electrical equipment should be serviced and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this manual. This document is not intended as an instruction manual for untrained persons.


Device operation

The user is responsible for checking that the rated characteristics of the device are suitable for its application. The user is responsible for reading and following the device's operating and installation instructions before attempting to commission or maintain it. Failure to follow these instructions can affect device operation and constitute a hazard for people and property.

Protective grounding

The user is responsible for compliance with all the existing international and national electrical codes concerning protective grounding of any device.

| | |
|---|-----------|
| Presentation | 2 |
| Managing the Modbus protocol | 3 |
| Configuring the communication interfaces | 4 |
| Serial line communication | 4 |
| Ethernet communication | 6 |
| Commissioning and diagnosis | 10 |
| Serial line communication | 10 |
| Ethernet communication | 12 |
| Data addresses and coding | 17 |
| Addresses in direct-access mode | 19 |
| Time-setting and synchronization | 39 |
| Time-tagged events | 41 |
| Transferring records | 43 |
| Access to remote settings | 47 |
| Customized table | 49 |
| Security | 51 |
| Reading Sepam identification | 52 |
| Appendix 1. Modbus protocol | 53 |
| Appendix 2. Function settings | 58 |



Easergy Sepam series 80 - two ports for communication and remote operation by SFT2841.

General

Modbus communication allows Sepam to be connected to a supervisor or any other device with a master Modbus communication channel.

Sepam is always a slave station.

Easergy Sepam series 80 has 2 identical and independent serial communication ports, COM1 and COM2. Easergy Sepam series 80 can also be fitted with an optional Ethernet communication interface. Use of COM2 port and Ethernet interface are mutually exclusive.

Sepam is connected to a Modbus communication network via a communication interface.

There is a choice of 3 types of communication interface:

■ communication interfaces to connect Sepam to a single serial network:

- ACE949-2, for connection to a 2-wire RS 485 network
- ACE959, for connection to a 4-wire RS 485 network
- ACE937, for connection to a fiber-optic star network

■ communication interfaces to connect Sepam to 2 serial networks:

- ACE969TP-2, for connection to:
 - one 2-wire RS 485 Modbus S-LAN supervision communication network
 - one 2-wire RS 485 E-LAN engineering communication network
- ACE969FO-2, for connection to:
 - one fiber-optic Modbus S-LAN supervision communication network
 - one 2-wire RS 485 E-LAN engineering communication network

■ communication interfaces to connect Sepam to an Ethernet network:

- ACE850TP for copper electrical connection to the Ethernet network
- ACE850FO for optical connection to the Ethernet network.

Accessing Sepam data

Data available

Modbus communication provides access to many different functions, including:

- reading of metering and diagnosis information
- reading of status conditions and remote indications
- transfer of time-tagged events
- transfer of files such as disturbance recordings and tripping contexts and, for Easergy Sepam series 60 and series 80, out-of-sync contexts, motor start reports, motor start trends and data logs
- viewing of protection settings
- reading of Sepam configuration and identification
- remote control of the analog output
- time-setting and synchronization.

The actual list depends on the application, the type of Sepam and the enabled functions.

Modbus communication also offers a number of additional functions (when enabled):

- transmission of remote controls
- modification of protection settings.

A password may be set up to protect access to these two functions.

Access modes

Depending on the data, two access modes are used:

- direct access - the data may be accessed directly in a single read or write operation
- indirect access - access requires a number of read and write operations, using a protocol that is specific to the data accessed.

Customized table

With Easergy Sepam series 80, it is possible to set up for each Modbus port a customized sub-group of data for quick reading of the most significant information on the user application.

Compatibility with Sepam 2000

Even though Easergy Sepam series 80 offers many additional functions, it remains compatible with Sepam 2000 addresses and formats for most information.

Protocol operation

Modbus is used to exchange information between a master and one or more slave units, identified by a number. It implements request-reply dialog, where requests are always initiated by the master. Modbus exists in ASCII and binary (RTU mode) formats.

Data is exchanged in the form of 16-bit words (also called registers) or simply bits. Each piece of information (bit or register) has a 16-bit address.

A detailed description of the protocol is provided in the appendix. It may also be found at www.modbus.org.

Modbus functions

The Modbus protocol used by Easergy Sepam series 80 is a compatible sub-group of the RTU Modbus protocol.

The functions listed below are handled by Easergy Sepam series 80:

- basic functions (data access):
 - function 1: reading of n output or internal bits
 - function 2: reading of n input bits
 - function 3: reading of n output or internal words
 - function 4: reading of n input words
 - function 5: writing of 1 bit
 - function 6: writing of 1 word
 - function 7: high-speed reading of 8 bits
 - function 15: writing of n bits
 - function 16: writing of n words.
- communication-management functions:
 - function 8: Modbus diagnosis
 - function 11: reading of Modbus event counter
 - function 43: sub-function 14: reading of identification.
- enhanced functions:
 - function 102: secure access.

The following exception codes are supported:

- 1: unknown function code
- 2: incorrect address
- 3: incorrect data
- 4: not ready (cannot process request)
- 7: not acknowledged (remote reading and setting in particular).

Multi-master operation

Serial line Modbus operation

When Sepam units are connected via a gateway to a multiple-access network (Ethernet, Modbus+, etc.), a number of masters may address the same unit via the same communication port.

The serial line Modbus protocol cannot manage this type of architecture. The network designer is responsible for avoiding collisions.

- For direct-access data, in general, no particular precautions must be taken.
- For indirect-access data, Sepam provides two exchange zones on each port, making possible two simultaneous, independent accesses by two different masters.

Modbus over TCP/IP operation

The ACE850 accepts up to 8 simultaneous Modbus/TCP connections.

Sepam accepts the Unit-Id 255 or any value in the range 1-247.

If several clients are accessing indirect-access data, they must make proper use of the two exchange zones provided. No access synchronization is provided by Sepam units.

Performance


The typical response time (time between the end of request reception and sending the reply) is less than 10 milliseconds for 90% of exchanges.

It may occasionally be longer, but not exceed 150 ms.

In indirect mode, the time needed between the request (or an acknowledgment) and the availability of the corresponding data is linked to the Sepam low-priority cycle time and may vary from a few dozen to several hundred milliseconds.

Configuring the communication interfaces

Serial line communication




SFT2841: Sepam configuration screen.

Access to configuration parameters


The Sepam communication interfaces must be configured using SFT2841 software. The configurations can be accessed from the Communication configuration window in the SFT2841 software.

To access this window:

- open the **Sepam configuration** window in SFT2841
- select the communication port you are going to configure, by checking the COM1 or COM2 box
- click on the relevant button : the **Communication configuration** window appears
- select the type of interface used: ACE949/ACE959/ACE937, ACE969TP or ACE969FO
- select the Modbus communication protocol.

The configuration parameters will vary depending on the communication interface selected: ACE949/ACE959/ACE937, ACE969TP or ACE969FO. The table below specifies the parameters to be configured depending on the communication interface chosen.

| Parameters to be configured | ACE949 ACE959 ACE937 | ACE969TP | ACE969FO |
|-----------------------------|----------------------------|----------|----------|
| Physical layer parameters | ■ | ■ | ■ |
| Fiber-optic parameters | | | ■ |
| Advanced Modbus parameters | ■ | ■ | ■ |
| E-LAN parameters | | ■ | ■ |



SFT2841: communication configuration window for ACE949.

Configuring the physical layer of the Modbus port

Asynchronous serial transmission is used with the following character format:

- 1 start bit
 - 8 data bits
 - 1 stop bit
 - parity according to parameter setting.
- The number of stop bits is always fixed at 1.

If a configuration with parity has been selected, each character will contain 11 bits: 1 start bit + 8 data bits + 1 parity bit + 1 stop bit.

If a no parity configuration has been selected, each character will contain 10 bits: 1 start bit + 8 data bits + 1 stop bit.

The configuration parameters for the physical layer of the Modbus port are as follows:

- slave number (Sepam address)
- transmission speed
- parity check type.

| Parameters | Authorized values | Default value |
|---------------|--------------------------------|---------------|
| Sepam address | 1 to 247 | 1 |
| Speed | 4800, 9600, 19200 or 38400 bps | 19200 bps |
| Parity | No parity, even or odd | Even |

Configuring the ACE969FO-2 fiber-optic port

The configuration for the physical layer of the ACE969FO-2 fiber-optic port is completed with the following 2 parameters:

- link idle state: light-on or light-off
- echo mode: with or without.

| Fiber-optic parameters | Authorized values | Default value |
|------------------------|---|---------------|
| Link idle state | Light Off or Light On | Light Off |
| Echo mode | Yes (fiber-optic ring) or No (fiber-optic star) | No |

Note: in echo mode, the Modbus master will receive the echo of its own request before the slave's reply. The Modbus master must be able to disregard this echo. Otherwise, it is impossible to create a Modbus fiber-optic ring.



Modbus Advanced parameters window.


Configuring Modbus advanced parameters

With Easergy Sepam series 80, remote controls and remote settings can be protected by a password.

Advanced parameters can be used to configure the security function by:

- activating the function
- entering the password for the remote controls
- entering the password for the remote settings.

| Advanced parameters | Authorized values | Default value |
|--------------------------|-------------------|---------------|
| Security function | On/Off | Off |
| Remote controls password | 4-digit code | 0000 |
| Remote settings password | 4-digit code | 0000 |



Communication configuration window for ACE969FO.

Configuring the physical layer of the ACE969-2 E-LAN port

The E-LAN port on the ACE969TP-2 and ACE969FO-2 communication interfaces is a 2-wire RS 485 port.

The configuration parameters for the physical layer of the E-LAN port are:

- Sepam address
- transmission speed
- parity check type.

The number of stop bits is always fixed at 1.


If a configuration with parity has been selected, each character will contain 11 bits: 1 start bit + 8 data bits + 1 parity bit + 1 stop bit.

If a no parity configuration has been selected, each character will contain 10 bits: 1 start bit + 8 data bits + 1 stop bit.

| Parameters | Authorized values | Default value |
|---------------|--------------------------------|---------------|
| Sepam address | 1 to 247 | 1 |
| Speed | 4800, 9600, 19200 or 38400 bps | 38400 bps |
| Parity | No parity, even or odd | Odd |

Configuration tips

- The Sepam address MUST be assigned before Sepam is connected to the communication network.
- You are also strongly advised to set the other physical layer configuration parameters before connecting to the communication network.
- Modifying the configuration parameters during normal operation will not disturb Sepam but will reset the communication port.



SFT2841: Sepam configuration screen.

Access to configuration parameters

The Sepam communication interfaces must be configured using SFT2841 software. The configuration parameters can be accessed from the Communication configuration window in the SFT2841 software.

To access this window:


- open the **Sepam configuration** window in SFT2841
- select the Ethernet communication port
- click on the relevant button : the **Communication configuration** window appears
- select the type of interface used: ACE850TP or ACE850FO.

Configuring an ACE850 involves:

- configuring the standard Ethernet parameters (mandatory)
- configuring one or more of the following sets of advanced optional parameters:
 - SNMP: Ethernet network management
 - SNTP: time synchronization
 - IP filtering: access control
 - RSTP: Ethernet ring management
 - User accounts: access control.

Ethernet and TCP/IP configuration


Before configuring the ACE850, obtain a unique static IP address, subnet mask, and default gateway address from the network administrator. See the section on IP address and parameter guidelines, page 9.



| Parameters | Description | Authorized values |
|--|--|--|
| Frame format | Used to select the format for data sent over an Ethernet connection. | Ethernet II, 802.3, Auto Default: Ethernet II |
| Media type | Used to define the physical Ethernet connection. | ACE850TP <ul style="list-style-type: none"> ■ 10T/100Tx Auto ■ 10BaseT-HD ■ 10BaseT-FD ■ 100BaseTX-HD ■ 100BaseTX-FD Default: 10T/100Tx Auto |
| IP address | Used to enter the static IP address of the ACE850. | ACE850FO <ul style="list-style-type: none"> ■ 100BaseFX-HD ■ 100BaseFX-FD Default: 100BaseFX-FD |
| Subnet mask | Used to enter the subnet mask of your network. | 0.0.0.0 to 255.255.255.255 Default: 255.255.0.0 |
| Default gateway | Used to enter the default gateway (router) IP address used for wide area network (WAN) communications. | 0.0.0.0 to 255.255.255.255 Default: 0.0.0.0 |
| Allow CID file to override IP parameters | This option is irrelevant when only Modbus communication is used. | Default: not checked |
| Keep alive | Timeout value used to test for session disconnection. | 1 to 60 seconds Default: 30 seconds |
| FTP session inactivity timeout | Timeout value used to force disconnection of an inactive FTP session | 30 to 900 seconds Default: 30 seconds |

Duplicate IP address detection

The ACE850 IP address must be unique in the network. If it is not unique, the Status LED repeats a four blink-pause pattern and a new IP address must be assigned to the ACE850 or to the conflicting device.



SFT2841: SNMP configuration.


SNMP configuration

The ACE850 supports SNMP V1, allowing a network administrator to remotely access it with an SNMP manager and view the network status and diagnostics in the MIB2 format (only a subset of MIB2 is implemented).

Additionally, the ACE850 may be configured to send SNMP traps in the following cases:

- ACE850 start/restart
- Link up
- Link down
- Authentication failure.

| Parameters | Description | Authorized values |
|---------------------------|---|--|
| System Name | This parameter is the same as the Sepam label. | Not modifiable from this screen. |
| System Contact | Name of the administrative contact | String (< 16 characters) Default: empty string |
| System Location | Location of the Sepam/ACE850 | String (< 16 characters) Default: empty string |
| Read-only Community Name | SNMP community that has read-only access to the MIB. Acts as a password. | String (< 16 characters) Default: "public" |
| Read-write Community Name | SNMP community that has read-write access to the MIB. Acts as a password. | String (< 16 characters) Default: "private" |
| Enable traps | Checking this check box enables SNMP to send traps. | Default: "not checked" |
| Traps Community Name | SNMP community that is used with traps. | String (< 16 characters) Default: "public" |
| Manager 1 IP address | IP address of the SNMP manager to which traps are sent. | 0.0.0.0 to 255.255.255.255 Default: 0.0.0.0 |
| Manager 2 IP address | IP address of a second SNMP manager to which traps are sent. | 0.0.0.0 to 255.255.255.255 Default: 0.0.0.0 |




SFT2841: SNTP configuration.

SNTP configuration

SNTP is a time synchronization protocol that can be used to synchronize the Sepam. SNTP is used in mode 3-4 (unicast mode).

- If SNTP is used, the synchronization source for Sepam must be defined as Ethernet.
- If SNTP is not used, the Sepam synchronization must be ensured by other means (Modbus frames, synchronization tops).

| Parameters | Description | Authorized values |
|-----------------------------|---|---|
| Enable SNTP | Enables the time and date of the Sepam to be set by the Simple Network Time Protocol (SNTP) server. | Default: not enabled |
| Time Zone Offset | Determines the difference between local time and Coordinated Universal Time (UTC) (same as GMT). | UTC-12 to UTC+14 Default: UTC |
| Enable Daylight Saving Time | Enables the use of Daylight Saving Time (Summer time). | Default: not enabled |
| DST offset | Difference between standard time and Daylight Saving Time. | + 30 or + 60 minutes Default: + 60 minutes |
| DST starts | If enabled, DST starts on the selected date. | Default: last Sunday of March |
| DST ends | If enabled, DST ends on the selected date. | Default: last Sunday of October |
| Primary Server IP Address | The IP address of the SNTP server the ACE850 contacts to get the time message. | 0.0.0.0 to 255.255.255.255 Default: 0.0.0.0 |
| Secondary Server IP Address | The IP address of another SNTP server the ACE850 contacts in case the primary server is down. | 0.0.0.0 to 255.255.255.255 Default: 0.0.0.0 |
| Poll Interval | Controls how often the ACE850 contacts the SNTP server for the correct time. | 1 to 300 minutes Default: 60 minutes |




SFT2841: IP filtering configuration.

IP filtering configuration

The IP filtering function allows the administrator to specify which Modbus/TCP clients and which IEC 61850 clients have access to the ACE850 services.

Note: if IP filtering is enabled, access is forbidden to any client not in the filtered list.

| Parameters | Description | Authorized values |
|------------------|---|---|
| Enable filtering | Check this box to activate filtering based on IP addresses. | Default: not enabled |
| IP address | The IP address of a client for which filtering options are defined. | 0.0.0.0 to 255.255.255.255 Default: 0.0.0.0 |
| IEC 61850 | Check this box to grant IEC 61850 access to the given IP address. | Default: not checked |
| Modbus | Check this box to grant Modbus/TCP access to the given IP address. | Default: not checked |



SFT2841: RSTP configuration.

RSTP configuration

The RSTP protocol enables the use of redundant Ethernet architectures such as rings.

It must be enabled each time the ACE850 is included in a loop. It may be disabled in other cases.


Changing the default settings is normally not required and should be performed with extreme care as it could jeopardize the stability of the Ethernet network.

If in doubt, it is always possible to revert to the default values using the Default settings button.

| Parameters | Description | Authorized values |
|--------------------|--|--|
| Enable RSTP | Check this box to activate the use of the RSTP protocol. | Default: enabled |
| Bridge priority | Priority of the bridge. The bridge with the lowest priority becomes root. | 0 - 61440, by steps of 4096 Default: 61440 |
| Hello time | Amount of time between the transmission of configuration messages | 1 to 10 seconds Default: 2 seconds |
| Forward delay time | Time value to control how fast a port changes its spanning state when moving towards the forwarding state | 4 to 30 seconds Default: 21 seconds |
| Max age time | Valid duration of configuration message once sent by the root bridge | 6 to 40 seconds Default: 40 seconds |
| Max transmit count | Maximum BPDUs that can be transmitted by the Port Transmit state machine in any Hello time. This value limits the maximum transmission rate. | 3 to 100 Default: 32 |
| Cost style | RSTP (32 bits) or STP (16 bits) cost style selection | Default: RSTP |

Note: RSTP parameters must verify the following relationships:

- $2 \times (\text{Forward_delay_time} - 1 \text{ second}) \geq \text{Max_age_time}$
- $\text{Max_age_time} \geq 2 \times (\text{Hello_time} + 1 \text{ second})$.



SFT2841: User accounts configuration.

User accounts configuration

ACE850 users are assigned usernames and passwords used to gain access to the FTP or WEB servers. Each user belongs to a group which determines the user's access rights:

- Administrator: read-write access to the FTP server, access to the WEB server
- Operator: read-only access to the FTP server, access to the WEB server
- Guest: no access to the FTP server, access to the WEB server

Up to 4 user accounts can be defined.

| Parameters | Description | Authorized values |
|---------------------|---|---|
| User control enable | Check this box to enable the configuration of users account. Currently, the ACE850 will not operate if this box is not checked. Ensure that this box is always checked. | Default: enabled |
| User n | Check this box to create this user account. Uncheck it to delete the account (only the last account in the list can be deleted). | Default: user 1 enabled Users 2 to 4 disabled |
| Name | User name | String (1 to 8 characters) |
| Password | User password | String (4 to 8 characters) |
| Group | Group to which the user belongs | Administrator, Operator, Guest |

The following account is always created by default as user 1:

- Name: Admin
- Password: ACE850
- Group: Administrator

IP address and parameters guidelines

IP addresses

Several configuration parameters are IP addresses. These addresses must follow precise rules which are enforced by SFT2841 software and ACE850 interface. These rules are:

- Every IP address is made of 4 fields separated by dots: x . y . z . t
- Each field is a decimal value coded on 8 bits (range [0..255]).
- The first field (x) must be in the range [1..224] but must not be 127.
- Intermediate fields can cover the full range [0..255].
- The last field must not be 0 (range [0..255]).

IP subnet mask

The IP subnet mask is also made of 4 dot separated fields:

- The binary representation of the subnet mask is made of a set of 8 to 30 contiguous ones in the most significant part, followed by a set of contiguous zeroes (255.0.0.0 to 255.255.255.252).
- For a class A IP address ($x \leq 126$), the number of ones in the subnet mask must be at least 8 (255.y.z.t).
- For a class B IP address ($128 \leq x \leq 191$), the number of ones in the subnet mask must be at least 16 (255.255.z.t).
- For a class C IP address ($192 \leq x \leq 223$), the number of ones in the subnet mask must be at least 24 (255.255.255.t).
- The subnet part of the device IP address, obtained when applying the subnet mask, must not be 0.

IP default gateway

- An IP address of 0.0.0.0 means no gateway.
- If a gateway is defined, it must belong to the same subnet as the device.

Installing the communication network

Preliminary study

According to the installation characteristics and constraints, a technical study must first determine the communication network requirements, including:

- the type of medium (electrical or fiber optic)
- the number of Sepam units per network
- the transmission speed
- the ACE interfaces configuration
- the Sepam parameter settings.

Sepam operating instructions

Communication interfaces must be installed and connected in accordance with the Easergy Sepam series 80 installation and operation manual instructions, reference SEPED303003EN.

Preliminary checks

Perform the following:

- check the CCA612 cord connection between the ACE interface and the Sepam base unit
- check the ACE Modbus communication port connection
- check the complete configuration of the ACE
- for the ACE969, check the auxiliary power supply connection.

Checking the operation of the ACE interface

You can use the following to check that an ACE interface is operating correctly:

- the indicator LEDs on the front panel of the ACE
- the information provided by the SFT2841 software connected to Sepam:
 - on the Diagnosis screen
 - on the Communication configuration screens.

Link activity LED for ACE949-2, ACE959 and ACE937

The link activity LED for ACE949-2, ACE959 and ACE937 interfaces flashes when Sepam transmission or reception is active.

Indicator LEDs on the ACE969

- green "on" LED: ACE969 energized
- red "key" LED: ACE969 interface status:
 - LED off: ACE969 configured and communication operational
 - LED flashing: ACE969 configuration error or ACE969 not configured
 - LED on: ACE969 error
- S-LAN and E-LAN Tx/Rx LEDs:
 - Tx flashing: Sepam transmitting
 - Rx flashing: Sepam receiving
 - Tx and Rx off: RS 485 communication is idle
 - Tx or Rx LED on while the RS485 communication network is idle: the idle state voltage of the RS485 network is incorrect.

Diagnosis using SFT2841 software


Sepam diagnosis screen

When connected to Sepam, the SFT2841 software informs the operator of the general Sepam status and of the Sepam communication status in particular. The Sepam diagnosis screen displays Sepam status information. You can get detailed status information about each communication channel using buttons on the screen.


Sepam communication diagnosis

The operator is provided with the following information to assist with identifying and resolving communication problems:

- name of the protocol configured
- Modbus interface version number
- number of valid frames received (CPT9)
- number of invalid (mistaken) frames received (CPT2).



SFT2841: Sepam series 80 diagnosis screen.



SFT2841: Communication diagnosis.

Link activity LED

The ACE interface link activity LEDs are activated by variations in the signal on the Modbus network. When the supervisor communicates with Sepam (during transmission or reception), these LEDs flash. After wiring, check the information given by the link activity LEDs when the supervisor operates.

Note: flashing indicates that there is traffic passing to or from Sepam; it does not mean that the exchanges are valid.

Functional test

If there is any doubt about correct operation of the link:

- run read/write cycles in the test zone
- use Modbus diagnosis function 8 (sub-code 0, echo mode).

The Modbus frames below, transmitted or received by a supervisor, are an example of a test performed when communication is implemented.

| Test zone | | | |
|--|--------------|-------------------------|------|
| Read | Transmission | 01 03 0C00 0002 | C75B |
| | Reception | 01 03 04 0000 0000 | FA33 |
| Write | Transmission | 01 10 0C00 0001 02 1234 | 6727 |
| | Reception | 01 10 0C00 0001 | 0299 |
| Read | Transmission | 01 03 0C00 0001 | B75A |
| | Reception | 01 03 02 1234 | B539 |
| Function 8 - Modbus diagnosis, echo mode | | | |
| Transmission | | 01 08 0000 1234 | ED7C |
| Reception | | 01 08 0000 1234 | ED7C |

Even in echo mode, Sepam recalculates and checks the CRC sent by the master:

- if the CRC received is valid, Sepam replies
- if the CRC received is invalid, Sepam does not reply.

Modbus diagnosis counters

Counter definition

Sepam manages the Modbus diagnosis counters. These are:

- **CPT1:** Number of valid frames received, whether the slave is involved or not
- **CPT2:** Number of frames received with a CRC error or physical error (frames with more than 255 bytes, frames received with at least one parity, overrun, framing or line-break error)
- **CPT3:** Number of exception responses generated (even if not transmitted, due to receipt of a broadcast request)
- **CPT4:** Number of frames specifically addressed to the station (excluding broadcasting)
- **CPT5:** Number of valid broadcast frames received
- **CPT6:** Not significant
- **CPT7:** Not significant
- **CPT8:** Number of frames received with at least one character having a physical error (parity, overrun, framing or line break)
- **CPT9:** Number of valid requests received and correctly executed.

Counter reset

The counters are reset to 0:

- when they reach the maximum value FFFFh (65535)
- when they are reset by a Modbus command (function 8)
- when Sepam auxiliary power is lost
- when communication parameters are modified.

Using the counters

Modbus diagnosis counters help to detect and resolve communications problems. They can be accessed by the dedicated read functions (Modbus protocol functions 8 and 11).

The CPT2 and CPT9 counters can be displayed on SFT2841

("Sepam Diagnosis" screen).

An incorrect speed (or parity) increments CPT2.

Non-reception is signaled by the lack of change on CPT9.

Operating anomalies

It is advisable to connect the Sepam units to the Modbus network one by one. Make sure that the supervisor is sending frames to the relevant Sepam by checking the activity on the RS 232 - RS 485 converter or the fiber-optic converter if there is one, and on the ACE module.

RS 485 network

- check the wiring on each ACE module
- check the tightness of the screw terminals on each ACE module
- check the connection of the CCA612 cord linking the ACE module to the Sepam base unit
- check that polarization is only at one point and that impedance matching is at both ends of the RS 485 network
- check the auxiliary power supply connection to the ACE969TP-2
- check that the ACE909-2 or ACE919 converter used is connected, powered and set up correctly.

Fiber-optic network

- check the connections on the ACE module
- check the connection of the CCA612 cord linking the ACE module to the Sepam base unit
- check the auxiliary power supply connection to the ACE969FO-2
- check that the converter or fiber-optic star used is correctly connected, powered and configured
- for a fiber-optic ring, check that the Modbus master can correctly handle the echo of its requests.

In all cases

- check all the ACE configuration parameters on SFT2841
- check the CPT2 and CPT9 diagnostic counters on SFT2841 ("Sepam Diagnosis" screen).

Installing the Ethernet network

Preliminary study

According to the installation characteristics and constraints, a technical study must first determine the Ethernet network requirements, including:

- the network topology
- the various subnets (if any) and their interconnections
- the IP addressing scheme

Sepam operating instructions

Communication interfaces must be installed and connected in accordance with the Easergy Sepam series 80 installation and operation manual instructions, reference SEPED303003EN.

Preliminary checks

Perform the following actions:

- check the CCA614 cord connection between the ACE850 interface and the Sepam base unit
- check the connection of the ACE850 to the Ethernet network
- check the auxiliary power supply connection
- check the complete configuration of the ACE850.

Checking the operation of the ACE interface

You can use the following to check that an ACE850 interface is operating correctly:

- the indicator LEDs on the front panel of the ACE850
- the information provided by the SFT2841 software connected to Sepam
- the Web pages embedded inside the ACE850.

Basic diagnostics

Diagnosis using indicator LEDs on the ACE850

1 On/fault indicator. This indicator has the following states:

- Off: the ACE850 interface is not powered
- steady red: the ACE850 is initializing or is faulty
- blinking red: the ACE850 is unable to establish communication with the Sepam base unit, or the ACE850 is not properly configured
- steady green: the ACE850 is operating correctly
- fast blinking green: indicates a transient state which occurs at startup when IEC 61850 communication is also used
- steady green and blinking red: communication with the base unit has been lost. This can indicate a normal situation due to a restart of the Sepam after parameters have been downloaded. The ACE850 automatically resumes normal operation in a few seconds.

This status can also indicate an error condition, in which case, ACE850 restarts automatically within 15 seconds and try to re-establish connection.

2 Status indicator. This indicator has the following states:


- Off: the Ethernet communication is not started
- steady green: the Ethernet communication is correctly operating
- three blinks pattern: no logical Ethernet link
- four blinks pattern: duplicate IP address
- six blinks pattern: invalid IP configuration.

3 and 5 Speed indicators. These indicators have the following states:


- Off: the corresponding physical link is down or the port speed is 10Mbps
- On: the corresponding port operates at 100Mbps.

4 and 6 Link/Activity indicators. These indicators have the following states:

- Off: the corresponding physical link is not established
- On: the corresponding physical link is established
- blinking: the indicator blinks with the activity on the link.




ACE850 communication interface.




SFT2841: Sepam diagnosis screen.

Diagnosis using SFT2841 software


When connected to Sepam, the SFT2841 software informs the operator of the general Sepam status and of the Sepam communication status in particular. Sepam status information appears on the Sepam diagnosis screen on which buttons can be used to obtain detailed status information on each communication channel. The Sepam diagnosis screen can be used to check that the Sepam base unit and the ACE850 interface are correctly connected:



Diagnosis screen detail: ACE850 not or improperly connected.




Diagnosis screen detail: ACE850 connected properly.



SFT2841: Ethernet diagnosis screen.

The Ethernet diagnosis screen can be used to check:

- the ACE850 module status. The ACE850 status is OK if the ACE850 validates its configuration.
- the communication ports status
- the current ACE850 IP address. If the current IP address is different from the one configured, this could mean that the configured address is not valid, unless the IEC 61850 protocol is also being used.



Advanced diagnostics using the embedded Web server

The advanced diagnostics feature is only available when it is possible to establish an Ethernet connection with the ACE850. If not, the basic diagnostics must be used to solve the problems.

Accessing the ACE850 Web server

1. Start your web browser (Internet explorer 6.0 or higher, Mozilla Firefox for example).
2. In the address text box, type the address of the ACE850 (169.254.0.10 is the default), then press **Enter**.
3. In the login window, type your username and password (default is Admin, ACE850).
4. From the left side menu, choose the language for the current session.
5. From the menu, click **Diagnostics** to access the diagnostics menu.

Diagnostics Web pages


There are two general diagnostics pages dealing with Ethernet operation:

- Ethernet global statistics
 - Ethernet port statistics
- There is also a set of protocol dedicated diagnostic pages:
- Modbus statistics
 - IEC 61850 statistics (not covered in this manual)
 - SNMP statistics
 - STNP statistics
 - RSTP statistics


Diagnostic pages are automatically refreshed every 5 seconds (approximately).



ACE850 home page.



ACE850 Ethernet TCP/IP statistics.




ACE850 Ethernet port statistics.

Ethernet TCP/IP statistics


| Item | Description |
|-----------------------|---|
| Mac address | Unique Ethernet hardware address of the ACE850 |
| Frame type | Value of the frame type configured with SFT2841 |
| TCP/IP parameters | Parameter values configured with SFT2841 |
| Frames received | Total number of received Ethernet frames, regardless of port or protocol |
| Frames transmitted | Total number of transmitted Ethernet frames, regardless of port or protocol |
| Reset Counters button | Button to reset the Ethernet counters |

Ethernet port statistics


| Item | Description |
|------------------------|---|
| Port P1/P2 buttons | Selection of the port of which statistics are displayed |
| Frames transmitted OK | A counter that increments each time a frame is successfully transmitted. |
| Collisions | A counter that increments each time a frame is retransmitted due to collision detection. |
| Excessive collisions | A counter that increments each time a frame cannot be sent because it has reached the maximum collision status based on the Truncated Binary Exponential Backoff algorithm. |
| Carrier sense errors | A counter that increments each time there is a collision because carrier sense is disabled. |
| Internal MAC Tx errors | A counter that increments for every transmission error that is not caused by late, excessive, or carrier sense collisions. |
| Link speed | Actual link speed |
| Frames received OK | A counter that increments each time a frame is successfully received. |
| Alignment errors | A counter that increments each time a received frame has an FCS error and does not end on an 8-bit frame boundary. |
| CRC errors | A counter that increments each time a received frame has a CRC or an alignment error. |
| FCS errors | A counter that increments each time a received frame has a FCS or an alignment error. |
| Late collisions | A counter that increments each time a collision occurs after the slot time (512 bits starting at the preamble). |
| Reset counters button | Button to reset the port counters |



ACE850 Modbus/TCP server statistics.



ACE850 Modbus/TCP connections statistics.



ACE850 SNMP statistics.

Modbus/TCP server statistics

| Item | Description |
|------------------------|--|
| Port status | Modbus port status |
| Opened TCP connections | Number of Modbus clients currently connected |
| Received messages | Total number of Modbus requests |
| Transmitted messages | Total number of Modbus responses |
| Reset counters button | Button to reset the messages counters |

Note: the Web interface uses one Modbus connection to operate.

Modbus/TCP connections statistics

| Item | Description |
|-----------------------|--|
| Index | Connection number |
| Remote IP | IP address of the Modbus client |
| Remote port | TCP port number on the client side |
| Local port | TCP port number on the server side |
| Transmitted messages | Number of Modbus requests for this connection |
| Received messages | Number of Modbus normal responses for this connection |
| Sent errors | Number of Modbus exception responses for this connection |
| Reset counters button | Button to reset the messages counters |

SNMP statistics

| Item | Description |
|-----------------------|---|
| SNMP agent status | Status of the SNMP agent |
| Bad Community usages | Number of requests with invalid community |
| Received messages | Total number of SNMP requests |
| Transmitted messages | Total number of SNMP responses |
| Reset counters button | Button to reset the messages counters |

PEB0411

SNTP Statistics

| SNTP Protocol | |
|-------------------------------|--------------|
| SNTP Client Status | Enabled |
| Active SNTP Server IP Address | 169.254.0.20 |
| Poll Interval (minutes) | 1 |
| Round Trip Delay | 0,002 |
| Local Offset | 0,003 |

| Date and Time | |
|---------------------------------|-------------------------|
| Daylight Saving Time | Enabled |
| Last Successful Time Sync (UTC) | 2009-04-22 08:58:13:210 |
| Device Date and Time (UTC) | 2009-04-22 08:59:07:114 |
| Device Date and Time (local) | 2009-04-22 10:29:07:114 |

ACE850 SNTP statistics.

SNTP statistics

| Item | Description |
|--|---|
| SNTP Client status | Value configured for the parameter in SFT2841 |
| Active SNTP server IP address | Address of the server currently answering SNTP requests (0.0.0.0 if no server answer) |
| Poll interval | Value configured for the parameter in SFT2841 |
| Round trip delay | Total time for SNMP request and response messages |
| Local offset | Difference between SNTP time and ACE time |
| Daylight saving time | Value configured for the parameter in SFT2841 |
| Last Successful Time Synchronization (UTC) | Last time the ACE850 successfully contacted the SNTP server (UTC time) |
| Device Date and Time (UTC) | Current time and date of the ACE850 (UTC time) |
| Device Date and Time (local) | Current time and date of the ACE850 (local time) |

PEB0412

RSTP Bridge Statistics

| General | |
|------------------------|---------------------------|
| Bridge Status | Enabled |
| Bridge ID | 61440 / 00:00:54:90:60:02 |
| Designated Root ID | 8192 / 00:0A:DC:19:AE:40 |
| Designated Root Port | 128 / 0 |
| Rootpath Cost | 200000 |
| Total Topology Changes | 3 |

| Configured vs Learned | |
|--------------------------|----|
| Configured Hello Time | 2 |
| Learned Hello Time | 2 |
| Configured Forward Delay | 15 |
| Learned Forward Delay | 15 |
| Configured Max Age | 20 |
| Learned Max Age | 20 |

ACE850 RSTP bridge statistics.

RSTP bridge statistics

| Item | Description |
|--------------------------|---|
| Bridge status | RSTP status of the bridge |
| Bridge ID | Bridge vector (Bridge priority/Bridge Mac address) |
| Designated Root ID | Bridge vector of the RSTP root bridge |
| Designated Root Port | Identifier of the root port (priority/number) |
| Rootpath cost | Path cost to the root |
| Total topology changes | Topology change counter (as defined by 802.1D-2004) |
| Configured hello time | Value of the configured hello time |
| Learned hello time | Operational value for hello time |
| Configured forward delay | Reminder of the configured forward delay |
| Learned forward delay | Operational value for forward delay |
| Configured max age | Value of the configured max age |
| Learned max age | Operational value for max age |

PEB0413

RSTP Port Statistics

Port P1 P2

| Port Status | |
|-----------------------|------------|
| Status | Forwarding |
| Role | Root |
| Priority | 128 |
| Port Path Cost | 200000 |
| Designated Port ID | 128 / 15 |
| Received RSTs | 32824 |
| Transmitted RSTs | 3 |
| Received Configure | 0 |
| Transmitted Configure | 0 |
| Received TCNs | 0 |
| Transmitted TCNs | 0 |

ACE850 RSTP port statistics.

RSTP port statistics

| Item | Description |
|-----------------------|---|
| Port P1 / P2 buttons | Selection of the port of which statistics are displayed |
| Status | RSTP status for the selected port |
| Role | RSTP role for the selected port |
| Priority | Port priority |
| Port path cost | Port contribution to root path cost |
| Designated port ID | Identifier of the link partner port (priority/number) |
| Received RSTs | Number of RST BPDUs received (RSTP) |
| Transmitted RSTs | Number of RST BPDUs sent (RSTP) |
| Received configure | Number of Configuration BPDUs received (STP) |
| Transmitted configure | Number of Configuration BPDUs sent (STP) |
| Received TCNs | Number of Topology change BPDUs received (STP) |
| Transmitted TCNs | Number of Topology change BPDUs sent (STP) |

Presentation

Word addresses

All Sepam information accessible via Modbus communication is organized in 16-bit words. Each word is identified by its address coded on 16 bits, i.e. from 0 to 65535 (FFFFh).

However, to remain compatible with older equipment, the essential information has addresses coded from 0 to 9999 (270Fh).

In the following pages of this document, all addresses are expressed in hexadecimal (xxxxh).

Data which is similar from the control-monitoring application and the coding viewpoint is grouped in adjacent address zones.

Bit addresses

Some information is also available in bit form. The bit address is derived from the word address, where:

bit address = (word address x 16) + bit rank (0 to 15).

Example: word 0C00 bit 0 = C000, word 0C00 bit 14 = C00E.

Non-defined addresses

Only the addresses defined in this document should be used.

If other addresses are used, Sepam may return an exception message or data that is not significant.

Direct-access data

This data is permanently identified by its Modbus address. It may be accessed by a single read or write operation, addressing a part of or the entire zone in question.

Indirect-access data

In this case, the Modbus addresses indicated make up an exchange zone occupied by different data, depending on the context. At least two operations are required for each exchange. The necessary protocol is indicated for each zone.



32-bit formats

For these data, the most-significant word is sent first.

Saturation

In all formats, if a datum overruns the maximum permissible value for the related format, the value read for the datum is the maximum permissible value for the format.

The maximum value can also indicate a non-calculable value.

Data coding

Except where mentioned in the text, Sepam data is coded in one of the formats below:

- 32S: 32-bit signed 2's complement value
- 32NS: 32-bit non-signed value
- 16S: 16-bit signed 2's complement value
- 16NS: 16-bit non-signed value
- 16O: 16-bit signed value, coded with a shift of 8000h (-32768 is coded 0, 0 is coded 8000h, 32767 is coded FFFFh)
- B: bit or set of bits
- IEC: time coding format using four words as per IEC 60870-5-4:

| Bit | 15 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|--------|--------------------------|----|----|----------------|-----------------|----|---|---|---|------------------|----------------|---------------|---|---|---|---|
| Word 1 | reserved | | | | | | | | | | year (0 to 99) | | | | | |
| Word 2 | 0 | 0 | 0 | 0 | month (1 to 12) | | | | 0 | 0 | 0 | day (1 to 31) | | | | |
| Word 3 | 0 | 0 | 0 | hour (0 to 23) | | | | 0 | 0 | minute (0 to 59) | | | | | | |
| Word 4 | millisecond (0 to 59999) | | | | | | | | | | | | | | | |

Bits set to 0 correspond to format fields not used by Sepam. They are always read as 0 and are not taken into account during writing.

The reserved field is read as 0 and may receive different values during writing.

- ASCII: character string in ASCII code, the number of characters is indicated. When ASCII strings do not completely fill the field, zero bytes are added. The order of characters in Modbus words is the following:
 - character n in the LSB position
 - character n+1 in the MSB position
- MMmm: coding of a version number on 16 bits (major index in the MSB position, minor index in LSB position)

For 16 and 32 bits values, the following letter may follow the format code:

- A: an out of range or not computable value is indicated by 7FFFh (16-bit) or 00007FFFh (32-bit)
- B: an out of range or not computable value is indicated by 7FFFFFFFh (32-bit)

List of address zones

| | Starting address | Ending address | Access mode | Access type |
|---|------------------|----------------|-------------|-------------|
| Time management and Sepam (compatible with Sepam 2000) | | | | |
| Synchronization zone | 0002 | 0005 | direct | word |
| Identification zone | 0006 | 000F | direct | word |
| Event table (first table compatible with Sepam 2000) | | | | |
| First table | 0040 | 0060 | indirect | word |
| Second table | 0070 | 0090 | indirect | word |
| Application management | | | | |
| Application zone | 0180 | 01BF | direct | word |
| Metering and diagnosis | | | | |
| 32-bit metering and diagnosis | 0200 | 02B1 | direct | word |
| 16-bit metering and diagnosis | 0300 | 0339 | direct | word |
| Directories | | | | |
| Disturbance recordings | 0400 | 044F | direct | word |
| Tripping context | 0480 | 0497 | direct | word |
| Out-of-sync context | 0500 | 0507 | direct | word |
| Data log (DLG) | 0600 | 067C | direct | word |
| Motor start report (MSR) | 0680 | 06FC | direct | word |
| Motor start trend (MST) | 0700 | 077C | direct | word |
| Test | | | | |
| Test zone | 0C00 | 0C0F | direct | word / bit |
| Status conditions and controls (compatible with Sepam 2000) | | | | |
| Logic/GOOSE inputs and logic equations | 0C10 | 0C19 | direct | word / bit |
| Logic outputs | 0C20 | 0C23 | direct | word / bit |
| Analog-output control | 0C30 | 0C30 | direct | word |
| Logipam counters | 0C40 | 0C57 | direct | word |
| Remote-control orders | 0C84 | 0C8B | direct | word / bit |
| Remote indications | 0C8F | 0C9E | direct | word / bit |
| First access zone to settings | | | | |
| Read settings | 2000 | 207C | indirect | word |
| Read request | 2080 | 2080 | indirect | word |
| Remote setting | 2100 | 217A | indirect | word |
| First zone for recording-data transfer | | | | |
| Selection | 2200 | 2203 | indirect | word |
| Read | 2300 | 237C | indirect | word |
| Customized table | | | | |
| Data table | 2600 | 267C | direct | word |
| Configuration table | 2680 | 26FC | direct | word |
| Second access zone to settings (compatible with Sepam 2000) | | | | |
| Read settings | D000 | D07C | indirect | word |
| Read request | D080 | D080 | indirect | word |
| Remote setting | D100 | D17A | indirect | word |
| Second zone for recording-data transfer (compatible with Sepam 2000) | | | | |
| Selection | D200 | D203 | indirect | word |
| Read | D300 | D37C | indirect | word |
| Metering and miscellaneous for Sepam 2000 compatibility | | | | |
| Disturb. rec. identification zone | D204 | D210 | direct | word |
| Measurements x 1 | FA00 | FA2F | direct | word |
| Measurements x 10 | FB00 | FB24 | direct | word |
| Compact zone | FB80 | FB8F | direct | word |
| Configuration zone | FC00 | FC03 | direct | word |

NOTICE

RISK OF DATA CORRUPTION

When using an ACE850 communication interface with IEC 61850 communication enabled, do not use the following address zones for Modbus/TCP (see the list address zone table):

- first access zone to settings
- first zone for recording-data transfer

Failure to follow these instructions can result in equipment damage.

Presentation

For each zone, the following data is provided:

- each Modbus address for the zone
- the Modbus function codes available for reading
- the Modbus function codes available for writing
- data formats, values and units
- whether the data can be included in a customized table ("config").

The indicated addresses are always word addresses. For bit access, the bit address must be used (see above).

Synchronization zone

The **synchronization zone** is a data structure containing the absolute data and time used by Sepam to time-tag its various recordings (events, disturbance recording, etc.).

| Synchronization zone | Address | Read | Write | Format | Config. |
|---------------------------------|---------|------|-------|--------|---------|
| Absolute time (year) | 0002 | 3 | 16 | IEC | - |
| Absolute time (month + day) | 0003 | 3 | 16 | IEC | - |
| Absolute time (hours + minutes) | 0004 | 3 | 16 | IEC | - |
| Absolute time (milliseconds) | 0005 | 3 | 16 | IEC | - |



The zone should be written in a single block containing 4 words, using function 16 (write word).

Identification zone

The **identification zone** contains system information pertaining to the identification of the Sepam equipment.

| Synchronization zone | Address | Read | Write | Value/ Format | Config. |
|-----------------------------|---------|------|-------|------------------|---------|
| Manufacturer identification | 0006 | 3 | - | 0100 | - |
| Equipment identification | 0007 | 3 | - | 0 | - |
| Marking + equipment type | 0008 | 3 | - | 1200 | - |
| Modbus version | 0009 | 3 | - | MMmm | - |
| Application technical level | 000A | 3 | - | 1 to n | - |
| version | 000B | 3 | - | MMmm | - |
| Sepam check-word | 000C | 3 | - | idem 0C8F | - |
| Summary zone | 000D | 3 | - | 0 (not mngd) | - |
| Command | 000E | 3 | 16 | 0 (not mngd) | - |
| Extension address | 000F | 3 | - | 180 | - |

This zone is provided to ensure compatibility with existing equipment. A more complete description is available starting at address 0180 in the application zone or using the identification read function.

Application zone

The application zone contains a set of information on the contents of Easergy Sepam series 80. Some of the information is reserved.

| Application zone | Address | Read | Write | Format | Config. |
|------------------------------|-----------|------|-------|-----------|---------|
| Reserved | 0180 | 3 | - | - | - |
| Reserved | 0181 | 3 | - | - | - |
| Reserved | 0182 | 3 | - | - | - |
| Application abbreviation | 0183/0185 | 3 | - | ASCII 6c | - |
| Application name | 0186/018F | 3 | - | ASCII 20c | - |
| Sepam marking | 0190/0199 | 3 | - | ASCII 20c | - |
| Application version | 019A/019C | 3 | - | ASCII 6c | - |
| Local-language name | 019D/01A6 | 3 | - | ASCII 12c | - |
| Technical level | 01A7 | 3 | - | 16NS | - |
| UV number | 01A8 | 3 | - | 16NS | - |
| Reserved | 01A9 | 3 | - | - | - |
| Reserved | 01AA | 3 | - | - | - |
| Reserved | 01AB | 3 | - | - | - |
| Reserved | 01AC | 3 | - | - | - |
| Reserved | 01AD | 3 | - | - | - |
| Reserved | 01AE | 3 | - | - | - |
| Local-language version | 01AF | 3 | - | MMmm | - |
| English-language version | 01B0 | 3 | - | MMmm | - |
| Boot version | 01B1 | 3 | - | MMmm | - |
| Base version | 01B2 | 3 | - | MMmm | - |
| Communication version | 01B3 | 3 | - | MMmm | - |
| DSM-module version | 01B4/01B6 | 3 | - | ASCII 6c | - |
| MET148-2 n° 1 module version | 01B7/01B9 | 3 | - | ASCII 6c | - |
| MET148-2 n° 2 module version | 01BA/01BC | 3 | - | ASCII 6c | - |
| MSA141 module version | 01BD/01BF | 3 | - | ASCII 6c | - |
| Reserved | 01C0/01C2 | 3 | - | ASCII 6c | - |
| Mimic-based UMI version | 01C3/01C5 | 3 | - | ASCII 6c | - |
| MCS025 module version | 01C6/01C8 | 3 | - | ASCII 6c | - |
| ACE969 COM1 module version | 01C9/01CB | 3 | - | ASCII 6c | - |
| ACE969 COM2 module version | 01CC/01CE | 3 | - | ASCII 6c | - |
| Reserved | | | | | |
| ACE850 module version | 01CF/01D1 | 3 | - | ASCII 6c | - |

32-bit metering and diagnosis zone

This zone contains all Sepam metering and diagnosis information, coded on 32 bits. Zone size exceeds the capacity of a frame, i.e. at least two requests are required to read it in full. Depending on the application and the parameter settings, some information is not significant.

| 32-bit metering and diagnosis zone | Address | Read | Write | Format | Unit | Config. |
|------------------------------------|-----------|------|-------|--------|-----------|---------|
| Phase current I1 | 0200/0201 | 3, 4 | - | 32NS | 0.1 A | yes |
| Phase current I2 | 0202/0203 | 3, 4 | - | 32NS | 0.1 A | yes |
| Phase current I3 | 0204/0205 | 3, 4 | - | 32NS | 0.1 A | yes |
| Residual current I0Σ | 0206/0207 | 3, 4 | - | 32NS | 0.1 A | yes |
| Residual current I0 | 0208/0209 | 3, 4 | - | 32NS | 0.1 A | yes |
| Demand current Im1 | 020A/020B | 3, 4 | - | 32NS | 0.1 A | yes |
| Demand current Im2 | 020C/020D | 3, 4 | - | 32NS | 0.1 A | yes |
| Demand current Im3 | 020E/020F | 3, 4 | - | 32NS | 0.1 A | yes |
| Peak demand current IM1 | 0210/0211 | 3, 4 | - | 32NS | 0.1 A | yes |
| Peak demand current IM2 | 0212/0213 | 3, 4 | - | 32NS | 0.1 A | yes |
| Peak demand current IM3 | 0214/0215 | 3, 4 | - | 32NS | 0.1 A | yes |
| Phase-to-phase voltage U21 | 0216/0217 | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-phase voltage U32 | 0218/0219 | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-phase voltage U13 | 021A/021B | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-neutral voltage V1 | 021C/021D | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-neutral voltage V2 | 021E/021F | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-neutral voltage V3 | 0220/0221 | 3, 4 | - | 32NS | 1 V | yes |
| Residual voltage V0 | 0222/0223 | 3, 4 | - | 32NS | 1 V | yes |
| Positive sequence voltage Vd | 0224/0225 | 3, 4 | - | 32NS | 1 V | yes |
| Negative-sequence voltage Vi | 0226/0227 | 3, 4 | - | 32NS | 1 V | yes |
| Frequency f | 0228/0229 | 3, 4 | - | 32NSA | 0.01 Hz | yes |
| Active power P | 022A/022B | 3, 4 | - | 32SB | 0.1 kW | yes |
| Reactive power Q | 022C/022D | 3, 4 | - | 32SB | 0.1 kvar | yes |
| Apparent power S | 022E/022F | 3, 4 | - | 32SB | 0.1 kVA | yes |
| Power factor cos φ | 0230/0231 | 3, 4 | - | 32SA | 0.01 | yes |
| Peak demand active power PM | 0232/0233 | 3, 4 | - | 32S | 0.1 kW | yes |
| Peak demand reactive power QM | 0234/0235 | 3, 4 | - | 32S | 0.1 kvar | yes |
| Active power P phase 1 | 0236/0237 | 3, 4 | - | 32SB | 0.1 kW | yes |
| Active power P phase 2 | 0238/0239 | 3, 4 | - | 32SB | 0.1 kW | yes |
| Active power P phase 3 | 023A/023B | 3, 4 | - | 32SB | 0.1 kW | yes |
| Reactive power Q phase 1 | 023C/023D | 3, 4 | - | 32SB | 0.1 kvar | yes |
| Reactive power Q phase 2 | 023E/023F | 3, 4 | - | 32SB | 0.1 kvar | yes |
| Reactive power Q phase 3 | 0240/0241 | 3, 4 | - | 32SB | 0.1 kvar | yes |
| Apparent power S phase 1 | 0242/0243 | 3, 4 | - | 32SB | 0.1 kVA | yes |
| Apparent power S phase 2 | 0244/0245 | 3, 4 | - | 32SB | 0.1 kVA | yes |
| Apparent power S phase 3 | 0246/0247 | 3, 4 | - | 32SB | 0.1 kVA | yes |
| Positive active energy Ea+ | 0248/0249 | 3, 4 | - | 32NS | 100 kWh | yes |
| Negative active energy Ea- | 024A/024B | 3, 4 | - | 32NS | 100 kWh | yes |
| Positive reactive energy Er+ | 024C/024D | 3, 4 | - | 32NS | 100 kvarh | yes |
| Negative reactive energy Er- | 024E/024F | 3, 4 | - | 32NS | 100 kvarh | yes |
| Ext. positive active energy Ea+ | 0250/0251 | 3, 4 | - | 32NS | 100 kWh | yes |
| Ext. negative active energy Ea- | 0252/0253 | 3, 4 | - | 32NS | 100 kWh | yes |
| Ext. positive reactive energy Ea+ | 0254/0255 | 3, 4 | - | 32NS | 100 kvarh | yes |
| Ext. negative reactive energy Ea- | 0256/0257 | 3, 4 | - | 32NS | 100 kvarh | yes |
| Neutral-point voltage Vnt | 0258/0259 | 3, 4 | - | 32NS | 1 V | yes |
| H3 neutral-point voltage V3nt | 025A/025B | 3, 4 | - | 32NS | 1 V | yes |
| H3 residual voltage V3r | 025C/025D | 3, 4 | - | 32NS | 1 V | yes |

32-bit metering and diagnosis zone (cont.)

| 32-bit metering and diagnosis zone | Address | Read | Write | Format | Unit | Config. |
|---|-----------|------|-------|--------|----------------------|---------|
| Phase current I'1 | 025E/025F | 3, 4 | - | 32NS | 0.1 A | yes |
| Phase current I'2 | 0260/0261 | 3, 4 | - | 32NS | 0.1 A | yes |
| Phase current I'3 | 0262/0263 | 3, 4 | - | 32NS | 0.1 A | yes |
| Residual current I'0Σ | 0264/0265 | 3, 4 | - | 32NS | 0.1 A | yes |
| Residual current I'0 | 0266/0267 | 3, 4 | - | 32NS | 0.1 A | yes |
| Number of operations | 0268/0269 | 3, 4 | - | 32NS | 1 | yes |
| Tripping current phase 1 Itrip1 | 026A/026B | 3, 4 | - | 32NS | 0.1 A | yes |
| Tripping current phase 2 Itrip2 | 026C/026D | 3, 4 | - | 32NS | 0.1 A | yes |
| Tripping current phase 3 Itrip3 | 026E/026F | 3, 4 | - | 32NS | 0.1 A | yes |
| Tripping current calculated I0 Itrip0 | 0270/0271 | 3, 4 | - | 32NS | 0.1 A | yes |
| Reserved | 0272/0273 | 3, 4 | - | - | - | yes |
| Reserved | 0274/0275 | 3, 4 | - | - | - | yes |
| Reserved | 0276/0277 | 3, 4 | - | - | - | yes |
| Reserved | 0278/0279 | 3, 4 | - | - | - | yes |
| Reserved | 027A/027B | 3, 4 | - | - | - | yes |
| Number of operations | 027C/027D | 3, 4 | - | 32NS | 1 | yes |
| Differential current Id1 | 027E/027F | 3, 4 | - | 32NSB | 0.1 A | yes |
| Differential current Id2 | 0280/0281 | 3, 4 | - | 32NSB | 0.1 A | yes |
| Differential current Id3 | 0282/0283 | 3, 4 | - | 32NSB | 0.1 A | yes |
| Through current It1 | 0284/0285 | 3, 4 | - | 32NSB | 0.1 A | yes |
| Through current It2 | 0286/0287 | 3, 4 | - | 32NSB | 0.1 A | yes |
| Through current It3 | 0288/0289 | 3, 4 | - | 32NSB | 0.1 A | yes |
| Impedance Zd | 028A/028B | 3, 4 | - | 32NSB | 1 mΩ | yes |
| Impedance Z21 | 028C/028D | 3, 4 | - | 32NSB | 1 mΩ | yes |
| Impedance Z32 | 028E/028F | 3, 4 | - | 32NSB | 1 mΩ | yes |
| Impedance Z13 | 0290/0291 | 3, 4 | - | 32NSB | 1 mΩ | yes |
| Phase-to-phase voltage U'21 | 0292/0293 | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-phase voltage U'32 | 0294/0295 | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-phase voltage U'13 | 0296/0297 | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-neutral voltage V'1 | 0298/0299 | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-neutral voltage V'2 | 029A/029B | 3, 4 | - | 32NS | 1 V | yes |
| Phase-to-neutral voltage V'3 | 029C/029D | 3, 4 | - | 32NS | 1 V | yes |
| Residual voltage V'0 | 029E/029F | 3, 4 | - | 32NS | 1 V | yes |
| Positive sequence voltage V'd | 02A0/02A1 | 3, 4 | - | 32NS | 1 V | yes |
| Negative sequence voltage V'i | 02A2/02A3 | 3, 4 | - | 32NS | 1 V | yes |
| Frequency f' | 02A4/02A5 | 3, 4 | - | 32NSA | 0.01 Hz | yes |
| Voltage difference dU (synchro-check) | 02A6/02A7 | 3, 4 | - | 32NSB | 0,1% of Uns Sync1 | yes |
| Frequency difference df (synchro-check) | 02A8/02A9 | 3, 4 | - | 32NSA | 0.001 Hz | yes |
| Phase difference dPhi (synchro-check) | 02AA/02AB | 3, 4 | - | 32NSA | 0.1° | yes |
| Capacitor capacitance C1 (or C21) | 02AC/02AD | 3, 4 | - | 32NSB | 0.1 μF | yes |
| Capacitor capacitance C2 (or C32) | 02B2/02B3 | 3, 4 | - | 32NSB | 0,1 μF | yes |
| Capacitor capacitance C3 (or C13) | 02B0/02B1 | 3, 4 | - | 32NSB | 0,1 μF | yes |
| Effective rotation direction | 02B2/02B3 | 3, 4 | - | 32NSB | 0=123 ou 1=132 | yes |
| Reserved | 02B4/02FF | | - | | | |

16-bit metering and diagnosis zone

This zone contains all Sepam metering and diagnosis information, coded on 16 bits. Depending on the application and the parameter settings, some information is not significant.

| 16-bit metering and diagnosis zone | Address | Read | Write | Format | Unit | Config. |
|---|---------|------|-------|--------|--------------------|---------|
| Temperature 1 MET148-2 n° 1 | 0300 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 2 MET148-2 n° 1 | 0301 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 3 MET148-2 n° 1 | 0302 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 4 MET148-2 n° 1 | 0303 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 5 MET148-2 n° 1 | 0304 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 6 MET148-2 n° 1 | 0305 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 7 MET148-2 n° 1 | 0306 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 8 MET148-2 n° 1 | 0307 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 1 MET148-2 n° 2 | 0308 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 2 MET148-2 n° 2 | 0309 | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 3 MET148-2 n° 2 | 030A | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 4 MET148-2 n° 2 | 030B | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 5 MET148-2 n° 2 | 030C | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 6 MET148-2 n° 2 | 030D | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 7 MET148-2 n° 2 | 030E | 3, 4 | - | 16SA | 1°C | yes |
| Temperature 8 MET148-2 n° 2 | 030F | 3, 4 | - | 16SA | 1°C | yes |
| Total harmonic distortion Uthd | 0310 | 3, 4 | - | 16NS | 0.1% | yes |
| Total harmonic distortion lthd | 0311 | 3, 4 | - | 16NS | 0.1% | yes |
| Angle $\varphi_0\Sigma$ | 0312 | 3, 4 | - | 16NSA | 1° | yes |
| Reserved | 0313 | 3, 4 | - | - | - | yes |
| Angle φ_0 | 0314 | 3, 4 | - | 16NSA | 1° | yes |
| Angle φ'_0 | 0315 | 3, 4 | - | 16NSA | 1° | yes |
| Angle φ_1 | 0316 | 3, 4 | - | 16NSA | 1° | yes |
| Angle φ_2 | 0317 | 3, 4 | - | 16NSA | 1° | yes |
| Angle φ_3 | 0318 | 3, 4 | - | 16NSA | 1° | yes |
| Negative sequence / unbalance | 0319 | 3, 4 | - | 16NS | % lb | yes |
| Negative sequence / unbalance' | 031A | 3, 4 | - | 16NS | % lb' | yes |
| Machine rotation speed | 031B | 3, 4 | - | 16NS | rpm | yes |
| Thermal capacity used | 031C | 3, 4 | - | 16NS | % | yes |
| Running hours counter | 031D | 3, 4 | - | 16NS | 1 hr | yes |
| Time before tripping | 031E | 3, 4 | - | 16NS | 1 min | yes |
| Time before closing | 031F | 3, 4 | - | 16NS | 1 min | yes |
| Starting time / overload | 0320 | 3, 4 | - | 16NS | 0.01 s | yes |
| Start inhibit time | 0321 | 3, 4 | - | 16NS | 1 min | yes |
| Number of starts allowed | 0322 | 3, 4 | - | 16NS | 1 | yes |
| Learnt cooling time constant T2 (49 RMS) thermal rate 1 | 0323 | 3, 4 | - | 16NS | 1 min | yes |
| Learnt cooling time constant T2 (49 RMS) thermal rate 2 | 0324 | 3, 4 | - | 16NS | 1 min | yes |
| Total cumulative breaking current | 0325 | 3, 4 | - | 16NS | 1(kA) ² | yes |
| Cumulative breaking current (0 < I < 2 In) | 0326 | 3, 4 | - | 16NS | 1(kA) ² | yes |
| Cum. breaking current (2 In < I < 5 In) | 0327 | 3, 4 | - | 16NS | 1(kA) ² | yes |
| Cum. breaking current (5 In < I < 10 In) | 0328 | 3, 4 | - | 16NS | 1(kA) ² | yes |
| Cum. breaking current (10 In < I < 40 In) | 0329 | 3, 4 | - | 16NS | 1(kA) ² | yes |
| Cumulative breaking current (I > 40 In) | 032A | 3, 4 | - | 16NS | 1(kA) ² | yes |
| Initial value of cumulative breaking current | 032B | 3, 4 | - | 16NS | 1(kA) ² | yes |
| Starting/overload current | 032C | 3, 4 | - | 16NS | 1 A | yes |
| Operating time | 032D | 3, 4 | - | 16NS | 1 ms | yes |
| Charging time | 032E | 3, 4 | - | 16NSA | 1 ms | yes |
| Number of racking out operations | 032F | 3, 4 | - | 16NS | 1 | yes |
| Auxiliary voltage | 0330 | 3, 4 | - | 16NS | 0.1 V | yes |
| Number of trips on phase current | 0331 | 3, 4 | - | 16NS | 1 | yes |
| Number of trips on earth-fault current | 0332 | 3, 4 | - | 16NS | 1 | yes |
| Angle I1 / I'1 | 0333 | 3, 4 | - | 16NSA | 1° | yes |
| Angle I2 / I'2 | 0334 | 3, 4 | - | 16NSA | 1° | yes |
| Angle I3 / I'3 | 0335 | 3, 4 | - | 16NSA | 1° | yes |
| Operating time capacitor step 1 | 0336 | 3, 4 | - | 16NS | 1 hr | yes |
| Operating time capacitor step 2 | 0337 | 3, 4 | - | 16NS | 1 hr | yes |
| Operating time capacitor step 3 | 0338 | 3, 4 | - | 16NS | 1 hr | yes |
| Operating time capacitor step 4 | 0339 | 3, 4 | - | 16NS | 1 hr | yes |

Directory zones

These zones indicate the recordings available in Easergy Sepam series 80 for the given data category. They have a similar structure.

Disturbance-recording directory

| Disturbance-recording directory | Address | Read | Write | Format | Unit | Config. |
|---------------------------------|-----------|------|-------|--------|-------|---------|
| Size of set-up files | 0400 | 3 | - | 16NS | bytes | - |
| Size of data files | 0401/0402 | 3 | - | 32NS | bytes | - |
| Number of records available | 0403 | 3 | - | 16NS | 1 | - |
| Date of record 1 (most recent) | 0404/0407 | 3 | - | IEC | - | - |
| Date of record 2 | 0408/040B | 3 | - | IEC | - | - |
| ... | ... | ... | ... | ... | ... | ... |
| Date of record 20 (oldest) | 044C/044F | 3 | - | IEC | - | - |

Tripping-context directory

| Context directory | Address | Read | Write | Format | Unit | Config. |
|---------------------------------|-----------|------|-------|--------|-------|---------|
| Context size | 0480 | 3 | - | 16NS | bytes | - |
| Not used | 0481/0482 | 3 | - | - | - | - |
| Number of records available | 0483 | 3 | - | 16NS | 1 | - |
| Date of record 1 (oldest) | 0484/0487 | 3 | - | IEC | - | - |
| Date of record 2 | 0488/048B | 3 | - | IEC | - | - |
| ... | ... | ... | ... | ... | ... | ... |
| Date of record 5 (least recent) | 0494/0497 | 3 | - | IEC | - | - |

Out-of-sync context directory

| Context directory | Address | Read | Write | Format | Unit | Config. |
|-----------------------------|-----------|------|-------|--------|-------|---------|
| Context size | 0500 | 3 | - | 16NS | bytes | - |
| Not used | 0501/0502 | 3 | - | - | - | - |
| Number of records available | 0503 | 3 | - | 16NS | 1 | - |
| Date of record | 0504 | 3 | - | IEC | - | - |

Data log (DLG) directory

| Context directory | Address | Read | Write | Format | Unit | Config. |
|--|-----------|------|-------|--------|-------|---------|
| Number of files available | 0600 | 3 | - | 16NS | 1 | - |
| Size of configuration file for all files | 0601 | 3 | - | 16NS | bytes | - |
| Size of data file 1 (most recent) | 0602/0603 | 3 | - | 32NS | bytes | - |
| Size of data file 2 | 0604/0605 | 3 | - | 32NS | bytes | - |
| ... | ... | ... | ... | ... | ... | ... |
| Size of data file 20 (oldest) | 0628/0629 | 3 | - | 32NS | bytes | - |
| Date of file 1 (most recent) | 062A/062D | 3 | - | IEC | - | - |
| Date of file 2 | 062E/0631 | 3 | - | IEC | - | - |
| ... | ... | ... | ... | ... | ... | ... |
| Date of file 20 (oldest) | 0676/0679 | 3 | - | IEC | - | - |
| Not used | 067A/067C | 3 | - | - | - | - |

Motor start report (MSR) directory

| Context directory | Address | Read | Write | Format | Unit | Config. |
|--|-----------|------|-------|--------|-------|---------|
| Number of files available | 0680 | 3 | - | 16NS | 1 | - |
| Size of configuration file for all files | 0681 | 3 | - | 16NS | bytes | - |
| Size of data file 1 (most recent) | 0682/0683 | 3 | - | 32NS | bytes | - |
| Size of data file 2 | 0684/0685 | 3 | - | 32NS | bytes | - |
| ... | ... | ... | ... | ... | ... | ... |
| Size of data file 20 (oldest) | 06A8/06A9 | 3 | - | 32NS | bytes | - |
| Date of file 1 (most recent) | 06AA/06AD | 3 | - | IEC | - | - |
| Date of file 2 | 06AE/06B1 | 3 | - | IEC | - | - |
| ... | ... | ... | ... | ... | ... | ... |
| Date of file 20 (oldest) | 06F6/06F9 | 3 | - | IEC | - | - |
| Not used | 06FA/06FC | 3 | - | - | - | - |

Motor start trend (MST) directory

| Context directory | Address | Read | Write | Format | Unit | Config. |
|--|-----------|------|-------|--------|-------|---------|
| Number of files available | 0700 | 3 | - | 16NS | 1 | - |
| Size of configuration file for all files | 0701 | 3 | - | 16NS | bytes | - |
| Size of all files | 0702/0703 | 3 | - | 32NS | bytes | - |
| Not used | 0704/0729 | 3 | - | - | - | - |
| Date of file 1 (most recent) | 072A/072D | 3 | - | IEC | - | - |
| Date of file 2 | 072E/0731 | 3 | - | IEC | - | - |
| ... | ... | ... | ... | ... | ... | ... |
| Date of file 20 (oldest) | 0776/0779 | 3 | - | IEC | - | - |
| Not used | 077A/077C | 3 | - | - | - | - |

Test zone

The **test zone** is a 16-word zone that may be accessed via the communication link by all functions, in both read and write modes, to facilitate communication testing at the time of commissioning or to test the link.

These words are set to zero when Sepam starts.

| Test zone | Address | Bit addresses | Read | Write | Config. |
|--------------|---------|---------------|------------|--------------|---------|
| Test word 1 | 0C00 | C000/C00F | 1, 2, 3, 4 | 5, 6, 15, 16 | - |
| Test word 2 | 0C01 | C010/C01F | 1, 2, 3, 4 | 5, 6, 15, 16 | - |
| ... | ... | ... | ... | ... | ... |
| Test word 16 | 0C0F | C0F0/C0FF | 1, 2, 3, 4 | 5, 6, 15, 16 | - |

Logipam counter zone

Counters used by the Logipam program.

| Logipam counter zone | Address | Read | Write | Config. |
|----------------------|---------|------|-------|---------|
| C1 | 0C40 | 3 | - | yes |
| C2 | 0C41 | 3 | - | yes |
| C3 | 0C42 | 3 | - | yes |
| C4 | 0C43 | 3 | - | yes |
| C5 | 0C44 | 3 | - | yes |
| C6 | 0C45 | 3 | - | yes |
| C7 | 0C46 | 3 | - | yes |
| C8 | 0C47 | 3 | - | yes |
| C9 | 0C48 | 3 | - | yes |
| C10 | 0C49 | 3 | - | yes |
| C11 | 0C4A | 3 | - | yes |
| C12 | 0C4B | 3 | - | yes |
| C13 | 0C4C | 3 | - | yes |
| C14 | 0C4D | 3 | - | yes |
| C15 | 0C4E | 3 | - | yes |
| C16 | 0C4F | 3 | - | yes |
| C17 | 0C50 | 3 | - | yes |
| C18 | 0C51 | 3 | - | yes |
| C19 | 0C52 | 3 | - | yes |
| C20 | 0C53 | 3 | - | yes |
| C21 | 0C54 | 3 | - | yes |
| C22 | 0C55 | 3 | - | yes |
| C23 | 0C56 | 3 | - | yes |
| C24 | 0C57 | 3 | - | yes |

Status-condition and control zones

Logic input / logic equation zone / GOOSE inputs

| Input / equation zone | Address | Bit addresses | Read | Write | Format | Config. |
|---|---------|---------------|------------|-------|--------|---------|
| Logic inputs I101 to I114 (MES120 n° 1) | 0C10 | C100/C10F | 1, 2, 3, 4 | - | B | yes |
| Logic inputs I201 to I214 (MES120 n° 2) | 0C11 | C110/C11F | 1, 2, 3, 4 | - | B | yes |
| Logic inputs I301 to I314 (MES120 n° 3) | 0C12 | C120/C12F | 1, 2, 3, 4 | - | B | yes |
| Logic equation bits (1 st word) | 0C13 | C130/C13F | 1, 2, 3, 4 | - | B | yes |
| Logic equation bits (2 nd word) | 0C14 | C140/C14F | 1, 2, 3, 4 | - | B | yes |
| Logic equation bits (3 rd word) | 0C15 | C150/C15F | 1, 2, 3, 4 | - | B | yes |
| Logic equation bits (4 th word) | 0C16 | C160/C16F | 1, 2, 3, 4 | - | B | yes |
| GOOSE inputs G401 to G416 (1 st word) | 0C17 | C170/C17F | 1, 2, 3, 4 | - | B | yes |
| GOOSE inputs G501 to G516 (2 nd word) | 0C18 | C180/C18F | 1, 2, 3, 4 | - | B | yes |
| Status of GOOSE emission tests | 0C19 | C191/C193 | 1, 2, 3, 4 | - | B | yes |

Logic input bits

| 15 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|----|----|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| - | - | Ix14 | Ix13 | Ix12 | Ix11 | Ix10 | Ix09 | Ix08 | Ix07 | Ix06 | Ix05 | Ix04 | Ix03 | Ix02 | Ix01 |

Logic equation bits

| | 1 st word 0C13 | 2 nd word 0C14 | 3 rd word 0C15 | 4 th word 0C16 |
|--------|------------------------------|------------------------------|------------------------------|------------------------------|
| Bit 00 | V1 | V17 | V_TRIP_STP3 | V_MIMIC_IN_9 |
| Bit 01 | V2 | V18 | V_TRIP_STP4 | V_MIMIC_IN_10 |
| Bit 02 | V3 | V19 | V_CLOSE_STP1 | V_MIMIC_IN_11 |
| Bit 03 | V4 | V20 | V_CLOSE_STP2 | V_MIMIC_IN_12 |
| Bit 04 | V5 | V_TRIPCB | V_CLOSE_STP3 | V_MIMIC_IN_13 |
| Bit 05 | V6 | V_CLOSECB | V_CLOSE_STP4 | V_MIMIC_IN_14 |
| Bit 06 | V7 | V_INHIBCLOSE | V_TRANS_ON_FLT | V_MIMIC_IN_15 |
| Bit 07 | V8 | V_FLAGREC | V_TRANS_STOP | V_MIMIC_IN_16 |
| Bit 08 | V9 | V_RESET | V_MIMIC_IN_1 | V_TRANS_V_EN |
| Bit 09 | V10 | V_CLEAR | V_MIMIC_IN_2 | V_MSR_START |
| Bit 10 | V11 | V_INHIBIT_RESET_LOCAL | V_MIMIC_IN_3 | V_DLG_START |
| Bit 11 | V12 | V_SHUTDOWN | V_MIMIC_IN_4 | Reserved |
| Bit 12 | V13 | V_DE-EXCITATION | V_MIMIC_IN_5 | Reserved |
| Bit 13 | V14 | V_CLOSE_NOCTRL | V_MIMIC_IN_6 | Reserved |
| Bit 14 | V15 | V_TRIP_STP1 | V_MIMIC_IN_7 | Reserved |
| Bit 15 | V16 | V_TRIP_STP2 | V_MIMIC_IN_8 | Reserved |

GOOSE inputs bits and status bits of emission GOOSE tests

| | GOOSE Inputs | | Status of GOOSE emission tests |
|--------|------------------------------|------------------------------|--------------------------------|
| | 1 st word 0C17 | 2 nd word 0C18 | 0C19 |
| Bit 00 | G401 | G501 | GOOSE test n° 1 |
| Bit 01 | G402 | G502 | GOOSE test n° 2 |
| Bit 02 | G403 | G503 | GOOSE test n° 3 |
| Bit 03 | G404 | G504 | GOOSE test n° 4 |
| Bit 04 | G405 | G505 | Reserved |
| Bit 05 | G406 | G506 | Reserved |
| Bit 06 | G407 | G507 | Reserved |
| Bit 07 | G408 | G508 | Reserved |
| Bit 08 | G409 | G509 | Reserved |
| Bit 09 | G410 | G510 | Reserved |
| Bit 10 | G411 | G511 | Reserved |
| Bit 11 | G412 | G512 | Reserved |
| Bit 12 | G413 | G513 | Reserved |
| Bit 13 | G414 | G514 | Reserved |
| Bit 14 | G415 | G515 | Reserved |
| Bit 15 | G416 | G516 | Reserved |

Logic-output zone

This zone indicates the status of the logic outputs and the LEDs on the front panel.

| Logic-output zone | Address | Bit addresses | Read | Write | Format | Config. |
|---|---------|---------------|------------|-------|--------|---------|
| Logic outputs O1 to O5 (base) | 0C20 | C200/C10F | 1, 2, 3, 4 | - | B | yes |
| Logic outputs O101 to O106 (MES120 n° 1) | 0C21 | C210/C21F | 1, 2, 3, 4 | - | B | yes |
| Logic outputs O201 to O206 (MES120 n° 2) | 0C22 | C220/C22F | 1, 2, 3, 4 | - | B | yes |
| Logic outputs O301 to O306 (MES120 n° 3) | 0C23 | C230/C23F | 1, 2, 3, 4 | - | B | yes |
| LED status | 0C24 | C240/C24F | 1, 2, 3, 4 | - | B | yes |

Logic output bits

| 15 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|----|----|----|----|----|----|---|---|---|---|---|----|----|----|----|----|
| - | - | - | - | - | - | - | - | - | - | - | O5 | O4 | O3 | O2 | O1 |

LED bits

| 15 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| - | - | - | - | - | - | L9 | L8 | L7 | L6 | L5 | L4 | L3 | L2 | L1 | LD |

LD: red "Sepam unavailable" LED.

Analog-output control zone

| Analog-output zone | Address | Read | Write | Format | Config. |
|--------------------|---------|------|-------|-------------------------|---------|
| MSA141 | 0C30 | 3 | 6, 16 | 16S/16NS ⁽¹⁾ | - |

⁽¹⁾ As per MSA141 parameter settings (option).

**Remote control of the analog output**

The analog output of the MSA141 module may be set up for remote control via the Modbus communication link. The usable range of the numerical value transmitted is defined by the "min. value" and "max. value" settings of the analog output (SFT2841).

Remote-control zone

| Remote-control zone | Address | Bit addresses | Read | Write | Format | Config. |
|---------------------|---------|---------------|------------|--------------|--------|---------|
| TCM1 to TCM16 | 0C80 | C800/C80F | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| TCM17 to TCM32 | 0C81 | C810/C81F | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| STC1 to STC16 | 0C84 | C840/C84F | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| STC17 to STC32 | 0C85 | C850/C85F | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| STC33 to STC48 | 0C86 | C860/C86F | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| STC49 to STC64 | 0C87 | C870/C87F | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| TC1 to TC16 | 0C88 | C880/C88F | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| TC17 to TC32 | 0C89 | C890/C89F | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| TC33 to TC48 | 0C8A | C8A0/C8AF | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |
| TC49 to TC64 | 0C8B | C8B0/C8BF | 1, 2, 3, 4 | 5, 6, 15, 16 | B | - |

Use of remote-control orders

Remote-control orders can be transmitted to Sepam by:

- 32 bits of maintained remote-control orders (TCM)
- 64 bits of pulse-type remote-control orders (TC)

Pulse-type remote-control orders can be executed in either of the following modes, selected by parameter setting:

- direct mode
- confirmed SBO (Select Before Operate) mode

Maintained remote-control orders (TCM)

Maintained remote-control orders (TCM1 to TCM32) work like bistables. They continuously maintain the value of the last state ordered. They can be used only by the Logipam program. They are reset to zero if Sepam auxiliary power is lost.

Pulse-type remote control orders (TC) in direct mode

The remote-control order is executed when it is written in the remote-control word. The program logic resets it to zero after the remote-control order is acknowledged.

Pulse-type remote control orders (TC) in confirmed SBO mode

Remote-control orders involve two steps:

- selection by the master of the order to be sent by writing the bit in the STC word and checking of the selection by rereading the word
- execution of the order to be sent by writing the bit in the TC word.

The remote-control order is executed if the bit in the STC word and the bit in the associated TC word are set. The program logic resets the STC and TC bits to zero after the remote-control order is acknowledged.

Deselection of the STC bit takes place:

- if the master deselects it by writing in the STC word
- if the master selects (write bit) a bit other than the one already selected
- if the master sets a bit in the TC word which does not match the selection. In this case, no remote-control order is executed.
- if the related order is not given within 30 seconds.

Inhibiting predefined remote control orders

Predefined processing of remote-control orders may be inhibited, except for the tripping remote-control order TC1 which may be activated at any time:

- by choosing Local or Test control mode via the key-switch on Sepam relays with mimic-based UMIs
- by assigning a logic input to the "Inhibit remote control" function.

The parameter setting of the logic input may be done in two modes:

- inhibition if the input is set to 1
- inhibition if the input is set to 0 (negative input).

In all cases, the remote-control orders remain available in Logipam which may be used to define a specific inhibition logic.

Security

It is possible to protect the remote-control zone against writing, see the section on security.



The choice between direct mode or confirmed SBO mode for remote control orders is made in the Sepam General characteristics configuration screen. This is a global parameter that applies to:

- both Sepam communication ports, COM1 and COM2
- Ethernet communication port.

Remote-control zone (cont'd)

Pulse-type remote-control orders not used by the Logipam program are pre-assigned to protection, control and metering functions.

The assignment of the remote-control orders is given in the tables below.

Depending on the applications and functions in operation, certain remote-control orders may not be applicable and will produce no effect.

if the switchgear function is enabled (or running), the following remote-control orders are acknowledged:

- device tripping and closing
- recloser enabling and disabling.

The corresponding value for Sepam 2000 is indicated. This value corresponds to the address, not the role (roles are not static in Sepam 2000).

When a remote-control order (TC) is used by the Logipam program, it is no longer assigned to a predefined function.

| Word 0C88: TC1 to TC16 | | Sepam 2000 |
|-------------------------|--|------------|
| Bit 00: TC1 | Trip / open ⁽¹⁾ | KTC33 |
| Bit 01: TC2 | Closing | KTC34 |
| Bit 02: TC3 | Sepam reset ⁽¹⁾ | KTC35 |
| Bit 03: TC4 | Peak demand current reset | KTC36 |
| Bit 04: TC5 | Peak demand power reset ⁽¹⁾ | KTC37 |
| Bit 05: TC6 | Reserved | KTC38 |
| Bit 06: TC7 | Reserved | KTC39 |
| Bit 07: TC8 | Enable recloser ⁽¹⁾ | KTC40 |
| Bit 08: TC9 | Disable recloser ⁽¹⁾ | KTC41 |
| Bit 09: TC10 | Free | KTC42 |
| Bit 10: TC11 | Free | KTC43 |
| Bit 11: TC12 | Free | KTC44 |
| Bit 12: TC13 | Free | KTC45 |
| Bit 13: TC14 | Free | KTC46 |
| Bit 14: TC15 | Free | KTC47 |
| Bit 15: TC16 | Free | KTC48 |
| Word 0C89: TC17 to TC32 | | Sepam 2000 |
| Bit 00: TC17 | Reserved | KTC49 |
| Bit 01: TC18 | Inhibit disturbance-recording triggering (OPG) | KTC50 |
| Bit 02: TC19 | Confirm disturbance-recording triggering (OPG) | KTC51 |
| Bit 03: TC20 | Manual disturbance-recording triggering (OPG) | KTC52 |
| Bit 04: TC21 | Free | KTC53 |
| to | | |
| Bit 12: TC29 | Free | KTC61 |
| Bit 13: TC30 | Inhibit thermal protection ⁽¹⁾ | KTC62 |
| Bit 14: TC31 | Confirm thermal protection ⁽¹⁾ | KTC63 |
| Bit 15: TC32 | Reset undercurrent protection | KTC64 |
| Word 0C8A: TC33 to TC48 | | Sepam 2000 |
| Bit 00: TC33 | Switching to setting group A ⁽¹⁾ | - |
| Bit 01: TC34 | Switching to setting group B ⁽¹⁾ | - |
| Bit 02: TC35 | Priority group shutdown | - |
| Bit 03: TC36 | Cancel priority group shutdown | - |
| Bit 04: TC37 | Enable synchro-check ⁽¹⁾ | - |
| Bit 05: TC38 | Disable synchro-check ⁽¹⁾ | - |
| Bit 06: TC39 | Enable voltage check ⁽¹⁾ | - |
| Bit 07: TC40 | Disable voltage check ⁽¹⁾ | - |
| Bit 08: TC41 | Open capacitor step 1 | - |
| Bit 09: TC42 | Open capacitor step 2 | - |
| Bit 10: TC43 | Open capacitor step 3 | - |
| Bit 11: TC44 | Open capacitor step 4 | - |
| Bit 12: TC45 | Close capacitor step 1 | - |
| Bit 13: TC46 | Close capacitor step 2 | - |
| Bit 14: TC47 | Close capacitor step 3 | - |
| Bit 15: TC48 | Close capacitor step 4 | - |

⁽¹⁾ The maximum number of remote controls is limited to 1,000,000 over the life of the product.

| Word 0C8B: TC49 to TC64 | | Sepam 2000 |
|-------------------------|---|------------|
| Bit 00: TC49 | Inhibit TS8 (Inductive) and TS9 (Capacitive) ⁽¹⁾ | - |
| Bit 01: TC50 | Confirm TS8 (Inductive) and TS9 (Capacitive) ⁽¹⁾ | - |
| Bit 02: TC51 | Trigger Motor start report | - |
| Bit 03: TC52 | Trigger data log | - |
| Bit 04: TC53 | Stop data log (Circular mode) | - |
| Bit 05: TC54 | 123 phase rotation direction ⁽¹⁾ | - |
| Bit 06: TC55 | 132 phase rotation direction ⁽¹⁾ | - |
| Bit 02: TC56 | Free | - |
| to | | |
| Bit 15: TC64 | Free | - |

⁽¹⁾The maximum number of remote controls is limited to 1,000,000 over the life of the product.

Remote-indications zone

| Remote-indications zone | Address | Bit addresses | Read | Write | Format | Config. |
|-------------------------|---------|---------------|------------|-------|--------|---------|
| Sepam check-word | 0C8F | C8F0/C8FF | 1, 2, 3, 4 | - | B | yes |
| TS1-TS16 | 0C90 | C900/C90F | 1, 2, 3, 4 | - | B | yes |
| TS17-TS32 | 0C91 | C910/C91F | 1, 2, 3, 4 | - | B | yes |
| TS33-TS48 | 0C92 | C920/C92F | 1, 2, 3, 4 | - | B | yes |
| TS49-TS64 | 0C93 | C930/C93F | 1, 2, 3, 4 | - | B | yes |
| TS65-TS80 | 0C94 | C940/C94F | 1, 2, 3, 4 | - | B | yes |
| TS81-TS96 | 0C95 | C950/C95F | 1, 2, 3, 4 | - | B | yes |
| TS97-TS112 | 0C96 | C960/C96F | 1, 2, 3, 4 | - | B | yes |
| TS113-TS128 | 0C97 | C970/C97F | 1, 2, 3, 4 | - | B | yes |
| TS129-TS144 | 0C98 | C980/C98F | 1, 2, 3, 4 | - | B | yes |
| TS145-TS160 | 0C99 | C990/C99F | 1, 2, 3, 4 | - | B | yes |
| TS161-TS176 | 0C9A | C9A0/C9AF | 1, 2, 3, 4 | - | B | yes |
| TS177-TS192 | 0C9B | C9B0/C9BF | 1, 2, 3, 4 | - | B | yes |
| TS193-TS208 | 0C9C | C9C0/C9CF | 1, 2, 3, 4 | - | B | yes |
| TS209-TS224 | 0C9D | C9D0/C9DF | 1, 2, 3, 4 | - | B | yes |
| TS225-TS240 | 0C9E | C9E0/C9EF | 1, 2, 3, 4 | - | B | yes |

The check work comprises a set of information on Sepam status.

The "high-speed reading" function (function 7) is used to access the most-significant byte in the check word (bits 15 to 8).

| Word 0C8F: Sepam check-word | Notes |
|-----------------------------|---|
| Bit 00 | Reserved |
| Bit 01 | Modbus Security function enabled (1) |
| Bit 02 | Reserved |
| Bit 03 | Sepam in "data loss" status in 2 nd event zone (1) (2) |
| Bit 04 | Event in 2 nd event zone (1) |
| Bit 05 | Setting group A in service (2) |
| Bit 06 | Setting group B in service (2) |
| Bit 07 | Sepam time not correct (2) |
| Bit 08 | Sepam partial fault (2) |
| Bit 09 | Sepam major fault |
| Bit 10 | Sepam in parameter setting mode (2) |
| Bit 11 | Remote setting inhibited |
| Bit 12 | Inductive network (1)/capacitive (0) |
| Bit 13 | Sepam not synchronous (2) |
| Bit 14 | Sepam in "data loss" status in 1 st event zone (1) (2) |
| Bit 15 | Event in 1 st event zone (1) |

(1) This information is specific to each communication port.

(2) Status changes of bits 3, 5, 6, 7, 8, 10, 13, 14 trigger sending of a time-tagged event (see the section on time-tagged events).

Remote-indication bits (TS) are pre-assigned to protection, control and metering functions. The tables below present each remote-indication bit. Depending on the applications and functions in operation, certain remote-indication bits may not be applicable.

The corresponding value for Sepam 2000 is indicated. This value corresponds to the address, not the meaning (meanings are not static in Sepam 2000).

When a remote-indication order is used by the Logipam program, it is no longer assigned to a predefined function and the meaning is determined by the Logipam program.

| Word 0C90: TS1 to TS16 | Sepam 2000 |
|------------------------|---|
| Bit 00: TS1 | Matching fault or Trip Circuit Supervision KTS1 |
| Bit 01: TS2 | Control fault KTS2 |
| Bit 02: TS3 | TC / position discrepancy KTS3 |
| Bit 03: TS4 | External tripping 1 KTS4 |
| Bit 04: TS5 | Sepam not reset after fault KTS5 |
| Bit 05: TS6 | External tripping 2 KTS6 |
| Bit 06: TS7 | External tripping 3 KTS7 |
| Bit 07: TS8 | Cos φ inductive (1) KTS8 |
| Bit 08: TS9 | Cos φ capacitive (1) KTS9 |
| Bit 09: TS10 | Closed position KTS10 |
| Bit 10: TS11 | Device racked out KTS11 |
| Bit 11: TS12 | SF6 alarm KTS12 |
| Bit 12: TS13 | Earthing switch closed KTS13 |
| Bit 13: TS14 | Remote-control enabled KTS14 |
| Bit 14: TS15 | Overcurrent protection (summary) KTS15 |
| Bit 15: TS16 | Free KTS16 |

(1) TC49 can be used to inhibit this TS.

| | | |
|---------------------------------|---|-------------------|
| Word 0C91: TS17 to TS32 | | Sepam 2000 |
| Bit 00: TS17 | Free | KTS17 |
| to | | |
| Bit 14: TS31 | Free | KTS31 |
| Bit 15: TS32 | Send blocking signal 1 | KTS32 |
| Word 0C92: TS33 to TS48 | | Sepam 2000 |
| Bit 00: TS33 | Free | KTS33 |
| to | | |
| Bit 15: TS48 | Free | KTS48 |
| Word 0C93: TS49 to TS64 | | Sepam 2000 |
| Bit 00: TS49 | A new disturbance recording is available (TS maintained for 28 ms) | KTS49 |
| Bit 01: TS50 | Disturbance recording inhibited | KTS50 |
| Bit 02: TS51 | Remote setting inhibited | KTS51 |
| Bit 03: TS52 | Free | KTS52 |
| to | | |
| Bit 15: TS64 | Free | KTS64 |
| Word 0C94: TS65 to TS80 | | |
| Bit 00: TS65 | Protection 50/51 unit 1 | |
| Bit 01: TS66 | Protection 50/51 unit 2 | |
| Bit 02: TS67 | Protection 50/51 unit 3 | |
| Bit 03: TS68 | Protection 50/51 unit 4 | |
| Bit 04: TS69 | Protection 50/51 unit 5 | |
| Bit 05: TS70 | Protection 50/51 unit 6 | |
| Bit 06: TS71 | Protection 50/51 unit 7 | |
| Bit 07: TS72 | Protection 50/51 unit 8 | |
| Bit 08: TS73 | Protection 50N/51N unit 1 | |
| Bit 09: TS74 | Protection 50N/51N unit 2 | |
| Bit 10: TS75 | Protection 50N/51N unit 3 | |
| Bit 11: TS76 | Protection 50N/51N unit 4 | |
| Bit 12: TS77 | Protection 50N/51N unit 5 | |
| Bit 13: TS78 | Protection 50N/51N unit 6 | |
| Bit 14: TS79 | Protection 50N/51N unit 7 | |
| Bit 15: TS80 | Protection 50N/51N unit 8 | |
| Word 0C95: TS81 to TS96 | | |
| Bit 00: TS81 | Protection 27 unit 1 | |
| Bit 01: TS82 | Protection 27 unit 2 | |
| Bit 02: TS83 | Protection 27 unit 3 | |
| Bit 03: TS84 | Protection 27 unit 4 | |
| Bit 04: TS85 | Protection 27D unit 1 | |
| Bit 05: TS86 | Protection 27D unit 2 | |
| Bit 06: TS87 | Protection 27R unit 1 | |
| Bit 07: TS88 | Protection 27R unit 2 | |
| Bit 08: TS89 | Protection 59 unit 1 | |
| Bit 09: TS90 | Protection 59 unit 2 | |
| Bit 10: TS91 | Protection 59 unit 3 | |
| Bit 11: TS92 | Protection 59 unit 4 | |
| Bit 12: TS93 | Protection 59N unit 1 | |
| Bit 13: TS94 | Protection 59N unit 2 | |
| Bit 14: TS95 | Protection 51V unit 1 | |
| Bit 15: TS96 | Protection 51V unit 2 | |
| Word 0C96: TS97 to TS112 | | |
| Bit 00: TS97 | Protection 67 unit 1 | |
| Bit 01: TS98 | Protection 67 unit 2 | |
| Bit 02: TS99 | Protection 67N unit 1 | |
| Bit 03: TS100 | Protection 67N unit 2 | |
| Bit 04: TS101 | Protection 46 unit 1 | |
| Bit 05: TS102 | Protection 46 unit 2 | |
| Bit 06: TS103 | Protection 47 unit 1 | |
| Bit 07: TS104 | Protection 47 unit 2 | |
| Bit 08: TS105 | Protection 32P unit 1 | |
| Bit 09: TS106 | Protection 32P unit 2 | |
| Bit 10: TS107 | Protection 32Q | |
| Bit 11: TS108 | Protection 37 | |
| Bit 12: TS109 | Protection 37P unit 1 | |
| Bit 13: TS110 | Protection 37P unit 2 | |
| Bit 14: TS111 | Protection 40 | |
| Bit 15: TS112 | Protection 50BF | |

Word 0C97: TS113 to TS128

| | |
|---------------|---|
| Bit 00: TS113 | Protection 49RMS – alarm set point |
| Bit 01: TS114 | Protection 49RMS – tripping set point |
| Bit 02: TS115 | Protection 48/51LR (locked rotor) |
| Bit 03: TS116 | Protection 48/51LR (locked rotor at start-up) |
| Bit 04: TS117 | Protection 48/51LR (excessive starting time) |
| Bit 05: TS118 | Protection 66 |
| Bit 06: TS119 | Protection 21B |
| Bit 07: TS120 | Protection 50/27 |
| Bit 08: TS121 | Protection 64G2/27TN unit 1 |
| Bit 09: TS122 | Protection 64G2/27TN unit 2 |
| Bit 10: TS123 | Protection 78PS |
| Bit 11: TS124 | Protection 64REF unit 1 |
| Bit 12: TS125 | Protection 64REF unit 2 |
| Bit 13: TS126 | Protection 87T2 |
| Bit 14: TS127 | Protection 87M/87G |
| Bit 15: TS128 | An MSR is currently being recorded |

Word 0C98: TS129 to TS144

| | |
|---------------|---|
| Bit 00: TS129 | Protection 81H unit 1 |
| Bit 01: TS130 | Protection 81H unit 2 |
| Bit 02: TS131 | Protection 81L unit 1 |
| Bit 03: TS132 | Protection 81L unit 2 |
| Bit 04: TS133 | Protection 81L unit 3 |
| Bit 05: TS134 | Protection 81L unit 4 |
| Bit 06: TS135 | Protection 81R unit 1 |
| Bit 07: TS136 | Protection 81R unit 2 |
| Bit 08: TS137 | Protection 12 unit 1 |
| Bit 09: TS138 | Protection 12 unit 2 |
| Bit 10: TS139 | Protection 14 unit 1 |
| Bit 11: TS140 | Protection 14 unit 2 |
| Bit 12: TS141 | Protection 24 unit 1 |
| Bit 13: TS142 | Protection 24 unit 2 |
| Bit 14: TS143 | A data log is in progress |
| Bit 15: TS144 | A new Data log file is available (TS maintained for 28 ms) |

Word 0C99: TS145 to TS160

| | |
|---------------|---|
| Bit 00: TS145 | Protection 38/49T alarm sensor 1 MET148 n° 1 |
| Bit 01: TS146 | Protection 38/49T tripping sensor 1 MET148 n° 1 |
| Bit 02: TS147 | Protection 38/49T alarm sensor 2 MET148 n° 1 |
| Bit 03: TS148 | Protection 38/49T tripping sensor 2 MET148 n° 1 |
| Bit 04: TS149 | Protection 38/49T alarm sensor 3 MET148 n° 1 |
| Bit 05: TS150 | Protection 38/49T tripping sensor 3 MET148 n° 1 |
| Bit 06: TS151 | Protection 38/49T alarm sensor 4 MET148 n° 1 |
| Bit 07: TS152 | Protection 38/49T tripping sensor 4 MET148 n° 1 |
| Bit 08: TS153 | Protection 38/49T alarm sensor 5 MET148 n° 1 |
| Bit 09: TS154 | Protection 38/49T tripping sensor 5 MET148 n° 1 |
| Bit 10: TS155 | Protection 38/49T alarm sensor 6 MET148 n° 1 |
| Bit 11: TS156 | Protection 38/49T tripping sensor 6 MET148 n° 1 |
| Bit 12: TS157 | Protection 38/49T alarm sensor 7 MET148 n° 1 |
| Bit 13: TS158 | Protection 38/49T tripping sensor 7 MET148 n° 1 |
| Bit 14: TS159 | Protection 38/49T alarm sensor 8 MET148 n° 1 |
| Bit 15: TS160 | Protection 38/49T tripping sensor 8 MET148 n° 1 |

Word 0C9A: TS161 to TS176

| | |
|---------------|---|
| Bit 00: TS161 | Protection 38/49T alarm sensor 1 MET148 n° 2 |
| Bit 01: TS162 | Protection 38/49T tripping sensor 1 MET148 n° 2 |
| Bit 02: TS163 | Protection 38/49T alarm sensor 2 MET148 n° 2 |
| Bit 03: TS164 | Protection 38/49T tripping sensor 2 MET148 n° 2 |
| Bit 04: TS165 | Protection 38/49T alarm sensor 3 MET148 n° 2 |
| Bit 05: TS166 | Protection 38/49T tripping sensor 3 MET148 n° 2 |
| Bit 06: TS167 | Protection 38/49T alarm sensor 4 MET148 n° 2 |
| Bit 07: TS168 | Protection 38/49T tripping sensor 4 MET148 n° 2 |
| Bit 08: TS169 | Protection 38/49T alarm sensor 5 MET148 n° 2 |
| Bit 09: TS170 | Protection 38/49T tripping sensor 5 MET148 n° 2 |
| Bit 10: TS171 | Protection 38/49T alarm sensor 6 MET148 n° 2 |
| Bit 11: TS172 | Protection 38/49T tripping sensor 6 MET148 n° 2 |
| Bit 12: TS173 | Protection 38/49T alarm sensor 7 MET148 n° 2 |
| Bit 13: TS174 | Protection 38/49T tripping sensor 7 MET148 n° 2 |
| Bit 14: TS175 | Protection 38/49T alarm sensor 8 MET148 n° 2 |
| Bit 15: TS176 | Protection 38/49T tripping sensor 8 MET148 n° 2 |

Word 0C9B: TS177 to TS192

| | |
|---------------|--|
| Bit 00: TS177 | Protection 51C unit 1 (capacitor step 1) |
| Bit 01: TS178 | Protection 51C unit 2 (capacitor step 1) |
| Bit 02: TS179 | Protection 51C unit 3 (capacitor step 2) |
| Bit 03: TS180 | Protection 51C unit 4 (capacitor step 2) |
| Bit 04: TS181 | Protection 51C unit 5 (capacitor step 3) |
| Bit 05: TS182 | Protection 51C unit 6 (capacitor step 3) |
| Bit 06: TS183 | Protection 51C unit 7 (capacitor step 4) |
| Bit 07: TS184 | Protection 51C unit 8 (capacitor step 4) |
| Bit 08: TS185 | Thermistor alarm |
| Bit 09: TS186 | Thermistor tripping |
| Bit 10: TS187 | Buchholz alarm |
| Bit 11: TS188 | Buchholz tripping |
| Bit 12: TS189 | Thermostat alarm |
| Bit 13: TS190 | Thermostat tripping |
| Bit 14: TS191 | Pressure alarm |
| Bit 15: TS192 | Pressure tripping |

Word 0C9C: TS193 to TS208

| | |
|---------------|-------------------------------------|
| Bit 00: TS193 | MET148-1 module sensor fault |
| Bit 01: TS194 | MET148-2 module sensor fault |
| Bit 02: TS195 | Inhibit thermal protection tripping |
| Bit 03: TS196 | Main-phase reverse rotation |
| Bit 04: TS197 | Additional-phase reverse rotation |
| Bit 05: TS198 | Send blocking signal 2 |
| Bit 06: TS199 | Recloser: On |
| Bit 07: TS200 | Recloser: ready |
| Bit 08: TS201 | Recloser: final trip |
| Bit 09: TS202 | Recloser: reclosing successful |
| Bit 10: TS203 | Recloser: cycle 1 in progress |
| Bit 11: TS204 | Recloser: cycle 2 in progress |
| Bit 12: TS205 | Recloser: cycle 3 in progress |
| Bit 13: TS206 | Recloser: cycle 4 in progress |
| Bit 14: TS207 | Recloser: closing by recloser |
| Bit 15: TS208 | Test mode |

Word 0C9D: TS209 to TS224

| | |
|---------------|-------------------------------------|
| Bit 00: TS209 | Phase CT fault |
| Bit 01: TS210 | Phase VT fault |
| Bit 02: TS211 | Residual VT fault |
| Bit 03: TS212 | Additional phase CT fault |
| Bit 04: TS213 | Additional phase VT fault |
| Bit 05: TS214 | Additional residual VT fault |
| Bit 06: TS215 | Load shedding |
| Bit 07: TS216 | Restart |
| Bit 08: TS217 | Min. V _{aux} |
| Bit 09: TS218 | Max. V _{aux} |
| Bit 10: TS219 | Battery low or absent |
| Bit 11: TS220 | Request for synchro-checked closing |
| Bit 12: TS221 | dU synchronization failure |
| Bit 13: TS222 | dPhi synchronization failure |
| Bit 14: TS223 | dF synchronization failure |
| Bit 15: TS224 | Synchronization stop |

Word 0C9E: TS225 to TS240

| | |
|---------------|---|
| Bit 00: TS225 | Synchronization failure |
| Bit 01: TS226 | Synchronization successful |
| Bit 02: TS227 | Manual capacitor step control |
| Bit 03: TS228 | Automatic capacitor step control |
| Bit 04: TS229 | Capacitor step 1 matching fault |
| Bit 05: TS230 | Capacitor step 2 matching fault |
| Bit 06: TS231 | Capacitor step 3 matching fault |
| Bit 07: TS232 | Capacitor step 4 matching fault |
| Bit 08: TS233 | Tripping |
| Bit 09: TS234 | Closing coil monitoring |
| Bit 10: TS235 | Cumulative breaking current monitoring |
| Bit 11: TS236 | Coupling closing order |
| Bit 12: TS237 | Coupling synchronization failure |
| Bit 13: TS238 | Tripping by automatic transfer (AT) |
| Bit 14: TS239 | Discrepancy in the phase rotation direction |
| Bit 15: TS240 | Ethernet communication fault |

Zones for Sepam 2000 compatibility

Disturb. rec. identification zone

This zone exists exclusively for address and format compatibility with Sepam 2000. When compatibility is not required, use the directory zone (address 400).

| Disturb. rec. identification zone | Address | Read | Write | Format | Unit | Config. |
|-----------------------------------|-----------|------|-------|--------|-------|---------|
| Reserved | D204 | 3 | - | - | - | - |
| Reserved | D205 | 3 | - | - | - | - |
| Size of set-up files | D206 | 3 | - | 16NS | bytes | - |
| Size of data files | D207 | 3 | - | 16NS | bytes | - |
| Number of records available | D208 | 3 | - | 16NS | 1 | - |
| Date of record 1 (most recent) | D209/D20C | 3 | - | IEC | - | - |
| Date of record 2 | D20D/D210 | 3 | - | IEC | - | - |



If data files are larger than 64 Kbytes, the number of records is forced to zero. Only the last two records are provided.

Configuration zone

This zone exists exclusively for address and format compatibility with Sepam 2000. It is static and does not depend on the real configuration of the Easergy Sepam series 80 relay.

| Configuration zone | Address | Read | Write | Value | Config. |
|-------------------------|---------|------|-------|-------|----------|
| Not used | FC00 | 3 | - | 0 | - |
| Easergy Sepam series 80 | | FC01 | 3 | - | 1200 h - |
| Not managed | FC02 | 3 | - | 0 | - |
| Not managed | FC03 | 3 | - | 0 | - |



Residual current

On Sepam 2000, measured and calculated residual currents are exclusive, i.e. they have the same Modbus address. On Sepam series 80, the two values { } exist: the compatible address is used for the & and the new address is used for the { } value.

Number of starts / Inhibit time

On Sepam 2000, these two values are exclusive and use the same Modbus address. They are differentiated by the sign. On Sepam series 80, the two values may both exist, the compatible address is used for the number of starts and the new address is used for the inhibit time.

Metering zone x 1

| Metering zone x 1 | Address | Read | Write | Format | Unit | Config. |
|-------------------------------|---------|------|-------|--------|---------|---------|
| Phase current I1 | FA00 | 3, 4 | - | 16NS | 0.1 A | yes |
| Phase current I2 | FA01 | 3, 4 | - | 16NS | 0.1 A | yes |
| Phase current I3 | FA02 | 3, 4 | - | 16NS | 0.1 A | yes |
| Peak demand current IM1 | FA03 | 3, 4 | - | 16NS | 0.1 A | yes |
| Peak demand current IM2 | FA04 | 3, 4 | - | 16NS | 0.1 A | yes |
| Peak demand current IM3 | FA05 | 3, 4 | - | 16NS | 0.1 A | yes |
| Phase-to-phase voltage U21 | FA06 | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-phase voltage U32 | FA07 | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-phase voltage U13 | FA08 | 3, 4 | - | 16NS | 1 V | yes |
| Frequency f | FA09 | 3, 4 | - | 16NSA | 0.01 Hz | yes |
| Active power P | FA0A | 3, 4 | - | 16O | 1 kW | yes |
| Reactive power Q | FA0B | 3, 4 | - | 16O | 1 kvar | yes |
| Power factor cos φ | FA0C | 3, 4 | - | 16O | 0.01 | yes |
| Peak demand active power PM | FA0D | 3, 4 | - | 16NS | 1 kW | yes |
| Peak demand reactive power QM | FA0E | 3, 4 | - | 16NS | 1 kvar | yes |
| Residual current I0Σ | FA0F | 3, 4 | - | 16NS | 0.1 A | yes |
| T1: temperature 1 MET n° 1 | FA10 | 3, 4 | - | 16O | 1°C | yes |
| T2: temperature 2 MET n° 1 | FA11 | 3, 4 | - | 16O | 1°C | yes |
| T3: temperature 3 MET n° 1 | FA12 | 3, 4 | - | 16O | 1°C | yes |
| T4: temperature 4 MET n° 1 | FA13 | 3, 4 | - | 16O | 1°C | yes |
| T5: temperature 5 MET n° 1 | FA14 | 3, 4 | - | 16O | 1°C | yes |
| T6: temperature 6 MET n° 1 | FA15 | 3, 4 | - | 16O | 1°C | yes |
| T7: temperature 7 MET n° 1 | FA16 | 3, 4 | - | 16O | 1°C | yes |
| T8: temperature 8 MET n° 1 | FA17 | 3, 4 | - | 16O | 1°C | yes |
| T9: temperature 1 MET n° 2 | FA18 | 3, 4 | - | 16O | 1°C | yes |
| T10: temperature 2 MET n° 2 | FA19 | 3, 4 | - | 16O | 1°C | yes |
| T11: temperature 3 MET n° 2 | FA1A | 3, 4 | - | 16O | 1°C | yes |
| T12: temperature 4 MET n° 2 | FA1B | 3, 4 | - | 16O | 1°C | yes |
| Thermal capacity used | FA1C | 3, 4 | - | 16NS | % | yes |
| Number of starts | FA1D | 3, 4 | - | 16NS | 1 | yes |
| Phase current I'1 | FA1E | 3, 4 | - | 16NS | 0.1 A | yes |
| Phase current I'2 | FA1F | 3, 4 | - | 16NS | 0.1 A | yes |
| Phase current I'3 | FA20 | 3, 4 | - | 16NS | 0.1 A | yes |
| Residual current I'0Σ | FA21 | 3, 4 | - | 16NS | 0.1 A | yes |
| Phase-to-neutral voltage V'1 | FA22 | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-neutral voltage V'2 | FA23 | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-neutral voltage V'3 | FA24 | 3, 4 | - | 16NS | 1 V | yes |
| Residual voltage V'0 | FA25 | 3, 4 | - | 16NS | 1 V | yes |
| Residual current I'0 | FA26 | 3, 4 | - | 16NS | 0.1 A | yes |
| Phase-to-phase voltage U'21 | FA27 | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-phase voltage U'32 | FA28 | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-phase voltage U'13 | FA29 | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-neutral voltage V'1 | FA2A | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-neutral voltage V'2 | FA2B | 3, 4 | - | 16NS | 1 V | yes |
| Phase-to-neutral voltage V'3 | FA2C | 3, 4 | - | 16NS | 1 V | yes |
| Residual voltage V'0 | FA2D | 3, 4 | - | 16NS | 1 V | yes |
| Residual current I'0 | FA2E | 3, 4 | - | 16NS | 0.1 A | yes |
| Inhibit time | FA2F | 3, 4 | - | 16NS | 1 min. | yes |

**Residual current**


On Sepam 2000, measured and calculated residual currents are exclusive, i.e. they have the same Modbus address. On Easergy Sepam series 80, the two values may both exist: the compatible address is used for the calculated value and the new address is used for the measured value.

Metering zone x 10

| Metering zone x 10 | Address | Read | Write | Format | Unit | Config. |
|-------------------------------|---------|------|-------|--------|---------|---------|
| Phase current I1 | FB00 | 3, 4 | - | 16NS | 1 A | yes |
| Phase current I2 | FB01 | 3, 4 | - | 16NS | 1 A | yes |
| Phase current I3 | FB02 | 3, 4 | - | 16NS | 1 A | yes |
| Peak demand current IM1 | FB03 | 3, 4 | - | 16NS | 1 A | yes |
| Peak demand current IM2 | FB04 | 3, 4 | - | 16NS | 1 A | yes |
| Peak demand current IM3 | FB05 | 3, 4 | - | 16NS | 1 A | yes |
| Phase-to-phase voltage U21 | FB06 | 3, 4 | - | 16NS | 10 V | yes |
| Phase-to-phase voltage U32 | FB07 | 3, 4 | - | 16NS | 10 V | yes |
| Phase-to-phase voltage U13 | FB08 | 3, 4 | - | 16NS | 10 V | yes |
| Frequency f | FB09 | 3, 4 | - | 16NSA | 0.1 Hz | yes |
| Active power P | FB0A | 3, 4 | - | 16O | 10 kW | yes |
| Reactive power Q | FB0B | 3, 4 | - | 16O | 10 kvar | yes |
| Power factor cos φ | FB0C | 3, 4 | - | 16O | 0.01 | yes |
| Peak demand active power PM | FB0D | 3, 4 | - | 16NS | 10 kW | yes |
| Peak demand reactive power QM | FB0E | 3, 4 | - | 16NS | 10 kvar | yes |
| Residual current I0Σ | FB0F | 3, 4 | - | 16NS | 1 A | yes |
| Last tripping current Itrip1 | FB10 | 3, 4 | - | 16NS | 10 A | yes |
| Last tripping current Itrip2 | FB11 | 3, 4 | - | 16NS | 10 A | yes |
| Last tripping current Itrip3 | FB12 | 3, 4 | - | 16NS | 10 A | yes |
| Last tripping current Itrip0 | FB13 | 3, 4 | - | 16NS | 1 A | yes |
| Phase current I'1 | FB14 | 3, 4 | - | 16NS | 1 A | yes |
| Phase current I'2 | FB15 | 3, 4 | - | 16NS | 1 A | yes |
| Phase current I'3 | FB16 | 3, 4 | - | 16NS | 1 A | yes |
| Phase-to-neutral voltage V1 | FB17 | 3, 4 | - | 16NS | 10 V | yes |
| Phase-to-neutral voltage V2 | FB18 | 3, 4 | - | 16NS | 10 V | yes |
| Phase-to-neutral voltage V3 | FB19 | 3, 4 | - | 16NS | 10 V | yes |
| Reserved | FB1A | 3, 4 | - | - | - | yes |
| Reserved | FB1B | 3, 4 | - | - | - | yes |
| Reserved | FB1C | 3, 4 | - | - | - | yes |
| Residual voltage V0 | FB1D | 3, 4 | - | 16NS | 10 V | yes |
| Residual current I'0Σ | FB1E | 3, 4 | - | 16NS | 1 A | yes |
| Reserved | FB1F | 3, 4 | - | - | - | yes |
| Reserved | FB20 | 3, 4 | - | - | - | yes |
| Reserved | FB21 | 3, 4 | - | - | - | yes |
| Reserved | FB22 | 3, 4 | - | - | - | yes |
| Residual current I0 | FB23 | 3, 4 | - | 16NS | 1 A | yes |
| Residual current I'0 | FB24 | 3, 4 | - | 16NS | 1 A | yes |

Compact zone

| Compact zone | Address | Read | Write | Format | Unit | Config. |
|----------------------------------|---------|------|-------|--------|--------|---------|
| Phase current I1 (x 1) | FB80 | 3, 4 | - | 16NS | 0.1 A | - |
| Phase-to-phase voltage U21 (x 1) | FB81 | 3, 4 | - | 16NS | 1 V | - |
| Active power P (x 1) | FB82 | 3, 4 | - | 16O | 1 kW | - |
| Reactive power Q (x 1) | FB83 | 3, 4 | - | 16O | 1 kvar | - |
| Sepam check-word (copy) | FB84 | 3, 4 | - | B | - | - |
| TS1-TS16 | FB85 | 3, 4 | - | B | - | - |
| TS17-TS32 | FB86 | 3, 4 | - | B | - | - |
| TS33-TS48 | FB87 | 3, 4 | - | B | - | - |
| TS49-TS64 | FB88 | 3, 4 | - | B | - | - |
| Logic inputs I101 to I114 | FB89 | 3, 4 | - | B | - | - |
| Logic inputs I201 to I214 | FB8A | 3, 4 | - | B | - | - |
| Logic inputs I301 to I314 | FB8B | 3, 4 | - | B | - | - |
| Reserved | FB8C | 3, 4 | - | - | - | - |
| Logipam event counter C1 | FB8D | 3, 4 | - | 16NS | - | - |
| Logipam event counter C2 | FB8E | 3, 4 | - | 16NS | - | - |
| Reserved | FB8F | 3, 4 | - | - | - | - |



SFT2841: date and time on the "Sepam diagnosis" screen.

Presentation

Easergy Sepam series 80 manages the date and time internally. If auxiliary power is lost, the date and time function continues to operate, on the condition that a charged battery was installed.

The Sepam internal time function is used in particular to date alarms and other records.

Sepam time can be viewed:

- with SFT2841 ("Sepam diagnosis" screen)
- on the Sepam display
- by a Modbus read of the synchronization zone.

Sepam also supplies in the check-word the indication "Sepam time not correct" if it is necessary to reset the time (often the case when the battery is low or absent). This information can also be viewed with SFT2841, on the "Sepam diagnosis" screen.

Time setting

When Sepam is energized, the time is automatically set using the clock powered by the backup battery, if the battery is charged.

When necessary, it is possible to set the time on the Easergy Sepam series 80 using:

- SFT2841 ("Sepam diagnosis" screen)
- Sepam User Machine Interface
- Serial Modbus communication (COM1 or COM2)
- Modbus/TCP or SNTP (Ethernet)

Modbus time is set by writing, in a single block, the new value for the date and time in the synchronization zone (time frame).

Synchronization

To ensure long-term time stability or to coordinate a number of devices, it is possible to synchronize Sepam relays.

A number of synchronization sources are accepted:

- none (synchronization inhibited)
- a pulse to logic input I103 (minimum duration: 15 ms)
- Modbus communication on COM1
- Modbus communication on COM2
- Ethernet (Modbus or SNTP)

The source is selected using the SFT2841 software, on the "General characteristics" screen.

Non-synchronous status is indicated in the check-word. This information can also be viewed with SFT2841, on the "Sepam diagnosis" screen.

When Sepam is synchronized, time setting is authorized only by sources that are compatible with the synchronization.

| Time setting | Synchronization source | | | |
|-------------------|------------------------|------|---------------|------|
| | None | COM1 | COM2/Ethernet | I103 |
| Local | ■ | | | |
| Via COM1 | ■ | ■ | | ■ |
| Via COM2/Ethernet | ■ | | ■ | ■ |

Synchronization by the Modbus communication link

The time frame is used for both time setting and synchronization of Sepam. In this case, it must be regularly sent at brief intervals (between 10 and 60 seconds) to maintain synchronous time.


It is generally broadcast (slave number = 0).

The Sepam internal clock is reset each time a new time frame is received.


Synchronization is maintained if the reset amplitude is less than 100 milliseconds. With synchronization via the Modbus network, accuracy depends on the master and its control over frame transmission time on the communication network. Sepam is synchronized without delay at the end of the receipt of the frame.

Time changes are made by sending a frame to Sepam with the new date and time. Sepam then switches to a transitional non-synchronous status.

In synchronous status, non-reception of a time frame for over 200 seconds results in the loss of synchronization.



Synchronization of the Sepam clock by the communication network.



External synchronization of the Sepam clock by sending a synchronization pulse to a logic input.

Pulse synchronization

Sepam can be synchronized externally by sending a periodic pulse (synchronization pulse) to logic input I103 (the MES120 module is required).

The pulse is used to reset the Sepam internal clock. Synchronization is carried out on the rising edge of the logic input.

Sepam adapts to synchronization periods from 10 to 60 seconds, in 10-second steps. The shorter the period, the more accurate the time setting.

When energized (or following a loss of synchronization), Sepam is in "non-synchronous" mode. The resetting process (switching of Sepam to "synchronous" mode) is based on a measurement of the difference between Sepam current time and the nearest ten-second period. This measurement is taken when the pulse is received following time setting. Resetting is authorized if the difference is less than or equal to 4 seconds. In this case, Sepam shifts to "synchronous" mode.

Subsequently (after switching to "synchronous" mode), the resetting process is based on the measurement of a difference (between Sepam current time and the nearest ten second period when the pulse is received), which is adapted to match the pulse period.

The pulse period is determined automatically by Sepam when it is energized, based on the first two pulses received. The pulse must be operational before Sepam is energized.

Synchronization operates only after Sepam has been time-set, i.e. after the "incorrect time" end event.

Any time changes greater than ± 4 seconds are made by sending a new time frame. The switch from summer time to winter time (and back) is made in this way as well. There is a temporary loss of synchronization when the time is changed.

Synchronization is lost if:

- the difference in synchronization between the closest 10-second period and pulse reception is greater than the synchronization error for two consecutive pulses
- the pulse is not received for a period longer than 200 seconds.

Synchronization-pulse characteristics

Electrical characteristics

They are identical to those for MES120 module inputs.

Time characteristics

Period: 10 to 60 seconds, in 10-second steps

State 1 minimum duration: 100 ms

State 0 minimum duration: 100 ms

Synchronization clock

The external synchronization mode requires additional equipment, a "synchronization clock" to generate a precise periodic synchronization time pulse. Schneider Electric has tested the following products:

Gorgy Timing, part no. RT3000, equipped with the M540 module

Presentation

The time-tagging function assigns a date and precise time to status changes (events) so that they can be accurately organized over time.

Time-tagging is systematic and concerns:

- logic inputs
- remote indications
- certain information pertaining to Sepam equipment (see Sepam check-word).

Events may be used by a remote monitoring and control system for data logging and histories, for example.

The remote monitoring and control system provides a chronological display of the time-tagged data.

Description

Time-tagging

Event time-tagging uses the Sepam internal clock. When an event is detected, it is tagged with the current Sepam time.

Time-tagging accuracy depends essentially on how well the Sepam internal clock is synchronized (see the section on time setting and synchronization).

Inhibition in Test mode

Test mode may be used to temporarily stop the transmission of all time-tagged events when remote operation of the installation is not to be disturbed by maintenance operations carried out on the electrical equipment. This mode may be accessed via mimic-based UMLs by turning the key-switch.

When Sepam enters Test mode, it:

- transmits remote-indication TS208 "Test mode" with a value of 1
- interrupts the transmission of all time-tagged events.

When Sepam leaves Test mode, it transmits remote-indication TS208 "Test mode" with a value of 0.

Time-tagged events can be transmitted again. Status changes that take place in Test mode are permanently lost.

Event queues

Sepam has four internal storage queues (two per communication port) with a capacity of 64 events. Each queue is independent.

If one queue is full (63 events already recorded), a "**data loss**" event is generated in the 64th position and the queue no longer receives event data. The other queues are not affected and continue to receive any new detected events.

When a queue in "data loss" status is completely emptied, a "data loss" end event is generated and the queue then receives any detected events.

For each event queue of a Modbus port, the check-work contains certain information:

- presence of an event: indicates that there is at least one event that has not been read in the corresponding queue
- data loss: indicates that the queue is in "data loss" status (full).

Initialization

Each time Sepam is initialized (energized), events are generated in the following order:

- "data loss"
- "not synchronous"
- end of "data loss".

The "time not correct" event may also appear if there is no battery.

The function is initialized with the current values of the remote indication and logic input status without creating any events related to those data. After the initialization phase, event detection is activated.



Reading must address only the exchange word, or the entire table.

Reading of events

Two Modbus tables are used to read the corresponding queues of events, in groups of four maximum, using a specific protocol to make sure no events are lost, even if communication problems occur.

| Event tables | Addr. table 1 | Addr. table 2 | Read | Write | Config. |
|---------------|---------------|---------------|------|-------|---------|
| Exchange word | 0040 | 0070 | 3 | 6, 16 | - |
| Event 1 | 0041/0048 | 0071/0078 | 3 | - | - |
| Event 2 | 0049/0050 | 0079/0080 | 3 | - | - |
| Event 3 | 0051/0058 | 0081/0088 | 3 | - | - |
| Event 4 | 0059/0060 | 0089/0090 | 3 | - | - |

Exchange word

It is used to check event reading. It consists of the elements below.

| Bit | 15 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|-----|-------------------------|----|----|----|----|----|---|---|--------------------|---|---|---|---|---|---|---|
| | Exchange number 0...255 | | | | | | | | Event number 0...4 | | | | | | | |

The exchange number is initialized to zero when Sepam is energized and is incremented for each transfer of a new set of events. When it reaches its maximum value (FFh), it automatically goes back to zero.

Sepam numbers the exchanges and the master acknowledges the numbering.

The event number indicates the number of significant events are truly present in the table. The remainder of the table is less significant.

Event table acknowledgment

Following correct reception of the set of events, the master must acknowledge the exchange by writing an exchange word with:

- "Exchange number" field: number of the last exchange carried out
- "Event number" field: set to zero.

The acknowledged events are then cleared from the Sepam queue. If there are other events, they are made available in the table and the exchange number is incremented.

As long as an exchange is not acknowledged, the table remains as is and it is possible to read it again.

If acknowledgment is incorrect (incorrect value for the exchange word), it is not taken into account and the table remains as is.

Clearing an event queue

Writing a value "xxFFh" in the exchange word (any exchange number, event number = FFh) reinitializes the corresponding event queue (all stored events not yet transmitted are deleted).

Description of event coding

An event is coded in 8 words with the following structure:

| Word | Information | Coding |
|--------|-----------------|--|
| 1 | Type of event | 0800 h |
| 2 | Event address | Bit address (see inputs, TS, check-word) |
| 3 | Reserved | 0 |
| 4 | Event direction | 0: falling edge 1: rising edge |
| 5 to 8 | Event time | IEC |

Presentation

Easergy Sepam series 80 records different types of data:

- disturbance recording
- tripping contexts
- out-of-sync context
- data log
- motor start report
- motor start trend

The list of available records may be read in the corresponding directory zones. Two Modbus transfer zones per port recover records using a specific protocol ensuring correct transfer, even if communication problems occur.

Transfer

Transfer is carried out in the same manner for all types of records. Given the volume of data, it is transferred in blocks that are compatible in size with Modbus frames.

To make a transfer, the master:

- determines the list of available records by reading the directory zone
- selects the desired record
- waits until it is available and recovers the first block of data, using the exchange word to ensure correct synchronization
- acknowledges block transfer
- repeats reading and acknowledgment until all the blocks have been received
- reads the directory zone again to check that the record was not overwritten during transfer.

A record may be transferred as many times as desired, until it is overwritten by a new record. If a record is made by Sepam while the oldest record is being transferred, the oldest record is overwritten.

Selection of a new record while a transfer is in progress interrupts the transfer.

Transfer zones

Each transfer zone comprises a zone for record selection and a zone reading record data.

Selection zone

Record transfer is initiated by writing the record identifier to this zone.

| Selection | Addr. zone 1 | Addr. zone 2 | Read | Write | Config. |
|-----------|--------------|--------------|------|-------|---------|
| Word 1 | 2200 | D200 | 3 | 16 | - |
| Word 2 | 2201 | D201 | 3 | 16 | - |
| Word 3 | 2202 | D202 | 3 | 16 | - |
| Word 4 | 2203 | D203 | 3 | 16 | - |

Record identifier

The records to be transferred are identified by their date as indicated in the directory zone, with an indicator in the most-significant byte of word 1:

- 0: disturbance recording
- 1: tripping contexts
- 2: out-of-sync context.
- 3: data log
- 4: motor start report
- 5: motor start trend

| Bit | 15 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|--------|----------------|----|----|----|----|----|---|---|----------------|---|---|---|---|---|---|---|
| Word 1 | Type of record | | | | | | | | | | | | | | | |
| Word 2 | | | | | | | | | Date of record | | | | | | | |
| Word 3 | | | | | | | | | (IEC) | | | | | | | |
| Word 4 | | | | | | | | | | | | | | | | |



The zone should be written in a single block containing 4 words, using function 16 (write word).

Easergy Sepam series 80 capacity for simultaneous transfers is limited. If Sepam cannot handle the request, a type 07 exception reply is sent. In this case, a new request must be made later.



The record transfer is reset if more than 2 seconds elapse between consecutive data read operations.

Data read zone

Record data are made available in this zone.

| Data reading | Addr. zone 1 | Addr. zone 2 | Read | Write | Config. |
|---------------|--------------|--------------|------|-------|---------|
| Exchange word | 2300 | D300 | 3 | 6, 16 | - |
| Data word 1 | 2301 | D301 | 3 | - | - |
| Data word 2 | 2302 | D302 | 3 | - | - |
| ... | ... | ... | 3 | - | - |
| Data word 124 | 237C | D37C | 3 | - | - |

Reading must always begin at the beginning of the zone (exchange word). The data bytes not included in the significant information (see the section on the exchange word) do not contain significant values.

Exchange word

It is used to check data reading. It consists of the elements below.

| | | | | | | | | | | | | | | | | |
|-----|-------------------------|----|----|----|----|----|---|---|--------------------------------|---|---|---|---|---|---|---|
| Bit | 15 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
| | Exchange number 0...255 | | | | | | | | Number of usable bytes 0...248 | | | | | | | |

The exchange number is initialized to zero when Sepam is energized and is incremented for each transfer of a new block of data. When it reaches its maximum value (FFh), it automatically goes back to zero.

Sepam numbers the exchanges and the master acknowledges the numbering.

The number of bytes indicates the usable size of the data zone. It is initialized to zero after an energizing operation and varies between 0 and 248 (F8h).

The exchange word may also have the following values:

- **0000h**: no "read request" has yet been made. This is especially the case when Sepam is energized. The other data words are not significant.
- **FFFFh**: the "read request" has been processed, but the results are not yet available in the read zone. It is necessary to read again later.
- **xxFEh**: the transfer has been cancelled or the record number is not known.

Reading acknowledgment

Following correct reception of the block of data, the master must acknowledge reading by writing an exchange word with:

- "Exchange number" field: number of the last exchange carried out
- "Number of bytes" field: set to zero.

If transfer of the record is not finished, the exchange word is reset to FFFFh while the next block of data is prepared, otherwise the exchange word is not modified.

As long as a read has not been acknowledged, the zone remains as is and it is possible to read it again.

If acknowledgment is incorrect (incorrect value for the exchange word), it is not taken into account and the zone remains as is.

Note: It is not necessary to acknowledge tripping contexts or out-of-sync contexts which are contained in a single block.

Data coding

Disturbance recording

Each record comprises two files as defined by the COMTRADE standard:

- configuration file (.CFG)
- data file (.DAT) in binary mode.

Because the configuration and data files are transferred together, a block may contain the end of the configuration file and the beginning of the data file of a record. It is up to the remote monitoring and control system to reconstruct the files in accordance with the transmitted number of usable bytes and the size of the files indicated in the directory zone.

Tripping contexts

| Word | Information | Format | Unit |
|----------|--|--------|--------------------|
| 00 | (exchange word) | | |
| 01 to 04 | Context date | IEC | - |
| 05/06 | Tripping current phase 1 Itrip1 | 32NS | 0.1 A |
| 07/08 | Tripping current phase 2 Itrip2 | 32NS | 0.1 A |
| 09/0A | Tripping current phase 3 Itrip3 | 32NS | 0.1 A |
| 0B/0C | Residual current I0Σ | 32NS | 0.1 A |
| 0D/0E | Residual current I0 | 32NS | 0.1 A |
| 0F/10 | Negative-sequence current Ii | 32NS | 0.1 A |
| 11/12 | Phase-to-phase voltage U21 | 32NS | 1 V |
| 13/14 | Phase-to-phase voltage U32 | 32NS | 1 V |
| 15/16 | Phase-to-phase voltage U13 | 32NS | 1 V |
| 17/18 | Phase-to-neutral voltage V1 | 32NS | 1 V |
| 19/1A | Phase-to-neutral voltage V2 | 32NS | 1 V |
| 1B/1C | Phase-to-neutral voltage V3 | 32NS | 1 V |
| 1D/1E | Residual voltage V0 | 32NS | 1 V |
| 1F/20 | Positive sequence voltage Vd | 32NS | 1 V |
| 21/22 | Negative-sequence voltage Vi | 32NS | 1 V |
| 23/24 | Frequency f | 32NS | 0.01 Hz |
| 25/26 | Active power P | 32S | 1 kW |
| 27/28 | Reactive power Q | 32S | 1 kvar |
| 29/2A | Apparent power S | 32S | 1 kVA |
| 2B/2C | Additional tripping current I'trip1 | 32NS | 0.1 A |
| 2D/2E | Additional tripping current I'trip2 | 32NS | 0.1 A |
| 2F/30 | Additional tripping current I'trip3 | 32NS | 0.1 A |
| 31/32 | Additional residual current I'0Σ | 32NS | 0.1 A |
| 33/34 | Additional residual current I'0 | 32NS | 0.1 A |
| 35/36 | Additional negative-sequence current I'i | 32NS | 0.1 A |
| 37/38 | Phase-to-phase voltage U'21 | 32NS | 1 V |
| 39/3A | Phase-to-phase voltage U'32 | 32NS | 1 V |
| 3B/3C | Phase-to-phase voltage U'13 | 32NS | 1 V |
| 3D/3E | Phase-to-neutral voltage V'1 | 32NS | 1 V |
| 3F/40 | Phase-to-neutral voltage V'2 | 32NS | 1 V |
| 41/42 | Phase-to-neutral voltage V'3 | 32NS | 1 V |
| 43/44 | Residual voltage V'0 | 32NS | 1 V |
| 45/46 | Positive sequence voltage V'd | 32NS | 1 V |
| 47/48 | Negative sequence voltage V'i | 32NS | 1 V |
| 49/4A | Frequency f' | 32NS | 0.01 Hz |
| 4B/4C | Neutral-point voltage Vnt | 32NS | 1 V |
| 4D/4E | H3 neutral-point voltage V3nt | 32NS | 0.1 % |
| 4F/50 | H3 residual voltage V3r | 32NS | 0.1 % |
| 51/52 | Differential current Id1 | 32NS | 0.1 A |
| 53/54 | Differential current Id2 | 32NS | 0.1 A |
| 55/56 | Differential current Id3 | 32NS | 0.1 A |
| 57/58 | Through current It1 | 32NS | 0.1 A |
| 59/5A | Through current It2 | 32NS | 0.1 A |
| 5B/5C | Through current It3 | 32NS | 0.1 A |
| 5D/5E | Phase rotation direction | 32NS | 0 = 123 1 = 132 |

Out-of-sync context

| Word | Information | Format | Unit |
|----------|-------------------------|--------|-------------------|
| 00 | (exchange word) | | |
| 01 to 04 | Context date | IEC | - |
| 05/06 | Voltage difference dU | 32NS | 0.1% of Uns Sync1 |
| 07 | Frequency difference df | 16NS | 0.001 Hz |
| 08 | Phase difference dφ | 16NS | 0.1° |



Inhibition of remote setting also concerns the SFT2841 connected to Modbus communication ports. When remote setting is inhibited, only the SFT2841 locally connected to Sepam can modify settings and parameters.

NOTICE

HAZARD OF IMPROPER OPERATION

- The device must only be configured and set by qualified personnel, using the results of the installation protection system study.
- During commissioning of the installation and after any modification, check that the Sepam configuration and protection function settings are consistent with the results of this study.

Failure to follow these instructions can result in equipment damage

Presentation

Access to Sepam settings via Modbus communication allows the user to remotely:

- read settings remotely (remote reading)
- modify settings remotely (remote setting), if it has been authorized.

Two Modbus zones per port offer access to the settings, using a specific protocol.

Accessible functions

Remote reading of settings concerns:

- all protection and similar functions
- the main Sepam general parameters.

Remote setting concerns exclusively the protection and similar functions.

Inhibiting remote setting

It is possible to inhibit the remote-setting function using a configuration parameter accessible via SFT2841. In the default set-up (factory settings), the remote-setting function is inhibited.

Security

It is possible to protect the remote-setting zone against writing, see the section on security.

Operating principle

Remote setting reading

For remote setting reading, the master:

- selects the function whose settings are requested (write in the request zone)
- waits until it is available and recovers the setting values, using the exchange word to ensure correct synchronization (read the setting read zone).

Remote setting

For remote setting, the master:

- selects the function whose settings are to be modified remotely and provides the list of new settings (write in the remote-setting zone)
- waits until processing is finished and recovers the accepted setting values, using the exchange word to ensure correct synchronization (read the setting read zone)
- checks that the settings have been accepted and processes any refusals.

It is necessary to make all the settings for the function concerned, even if some of them have not changed.

Setting access zones

Each setting-access zone includes a zone to select the function whose settings are requested, a zone to read the settings of the selected function and a zone to write the settings.

Selection zone for setting requests

A setting read is initiated by writing the function identifier to this zone.

| Setting request | Addr. zone 1 | Addr. zone 2 | Read | Write | Config. |
|---------------------|--------------|--------------|------|-------|---------|
| Function identifier | 2080 | D080 | 3 | 6, 16 | - |

Function identification

Each function is identified by a function code, with a unit number (protection) or a subcode (other functions). A list of the function codes is provided in the appendices, no other values are valid.

| Bit | 15 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|-----|---------------|----|----|----|----|----|---|---|------------------------|---|---|---|---|---|---|---|
| | Function code | | | | | | | | Unit number or subcode | | | | | | | |

Exception replies

In addition to the usual cases, Sepam can send Modbus type 07 exception replies (not acknowledged) if another remote reading (or remote setting) request is being processed.

Setting read zone

Setting values are made available in this zone.

| Writing settings | Addr. zone 1 | Addr. zone 2 | Read | Write | Config. |
|--------------------|--------------|--------------|------|-------|---------|
| Function reference | 2000 | D000 | 3 | - | - |
| Setting 1 | 2001/2002 | D001/D002 | 3 | - | - |
| Setting 2 | 2003/2004 | D002/D003 | 3 | - | - |
| ... | ... | ... | 3 | - | - |
| Setting 61 | 207B/207C | D07B/D07C | 3 | - | - |

Reading must always begin at the beginning of the zone (exchange word). The length of the exchange may concern:

- the exchange word only (validity test)
- the maximum size of the zone (125 words)
- the usable size of the zone (determined by the function being addressed).

Exchange word

It is used to check the reading of the settings and can have the following values:

- **xyy**: where
 - function code **xx** is not 00 or FFh
 - unit number or subcode **yy** is not FFh.

The requested settings are available in the words below. The word is a copy of the request. The zone contents remain valid until the next request is made.

- **FFFFh**: the request has been processed, but the results are not yet available. It is necessary to read again later. The other words are not significant.
- **xxFFh**: where the function code **xx** is not 00 or FFh. The read request for the settings of the designated function is not valid. The function (or the unit) does not exist for this Sepam.
- **0000h**: no "request frame" has yet been formulated. This is especially the case when Sepam is energized. The other words are not significant.

Settings

All settings are 32 bits in length (two Modbus words). They are specific to each function and are described in the appendices.

Remote-setting zone

The new setting values are written in this zone.

| Writing settings | Addr. zone 1 | Addr. zone 2 | Read | Write | Config. |
|--------------------|--------------|--------------|------|-------|---------|
| Function reference | 2100 | D100 | 3 | 16 | - |
| Setting 1 | 2101/2102 | D101/D102 | 3 | 16 | - |
| Setting 2 | 2103/2004 | D102/D003 | 3 | 16 | - |
| ... | ... | ... | 3 | 16 | - |
| Setting 61 | 2179/217A | D179/D17A | 3 | 16 | - |

Writing must always begin at the beginning of the zone.

Function identifier

It is identical to that used to read the settings.

Settings

All settings are 32 bits in length (two Modbus words). They are specific to each function and are described in the appendices.

Exception reply

In addition to the usual cases, Sepam can send type 07 exception replies (not acknowledged) if:

- another remote reading or setting request is being processed
- the remote setting function is inhibited
- Sepam is being set locally (SFT2841 or UMI).

Check on setting acceptance

After processing the remote-setting zone, Sepam updates the read zone with the current function settings. In this case, the exchange word may also have another value:

- **FFFEh** meaning that the settings have been refused. Certain values are incorrect and are replaced by 7FFFFFFFh in the read zone.

Presentation

To reduce the number of Modbus exchanges required by the master to collect the most frequently used information (and the bandwidth used on the network), a customized table can be set up on each communication port of Easergy Sepam series 80. This table is defined via Modbus, using a configuration table.

Use

Configuration table

| Configuration table | Address | Read | Write | Config. |
|---------------------|---------|------|-------|---------|
| Identifier | 2680 | 3 | 16 | - |
| Address datum 1 | 2681 | 3 | 16 | - |
| Address datum 2 | 2682 | 3 | 16 | - |
| ... | ... | 3 | 16 | - |
| Address datum 124 | 26FC | 3 | 16 | - |

Writing the configuration table

This function is used to configure the data table. The first word in the configuration table is used as the configuration identifier. It is copied as is in the first word of the data table. The identifier can have any value, except 0. If the identifier is set to 0, table configuration is cancelled.


The identifier enables masters to generate a number of typical configurations and to check which is active. It is also the means to check that no other master has modified the active configuration. This requires concerted management between the masters. Each other word in the table contains the Modbus address of the datum that should be set up in the corresponding spot in the data table (0 if the position is not used). Only certain Modbus addresses can be set up in these tables. The valid addresses are indicated in this document by "yes" in the "Config." column in the descriptions. It is possible to write the table in part or in whole from any address. When 125 words are used (the maximum size of the data table), at least two writings are required to fill the configuration table because the maximum size of a Modbus write is 123 words.

Reading the configuration table

This function is used to read and check the configuration of the data table. Each address word can have one of the following values:

- 0000: position not used
- FFFFh: invalid address
- Address: address correctly configured.

It is possible to read the zone in part or in whole from any address.



Example: by writing 0C8F to 268C, the result at 260C is a copy of the contents at address 0C8F (check-word).



Caution: configuration takes place one Modbus word after the other. For a 32-bit value, it is necessary to provide the two successive addresses of the value. (This characteristic may be used to switch the order of words if there is a compatibility problem with the 32-bit format. It is also possible to use only the least-significant part of the 32-bit values if the range is sufficient for the given application.)

Data table

| Data table | Address | Read | Write | Config. |
|------------|---------|------|-------|---------|
| Identifier | 2600 | 3 | - | - |
| Datum 1 | 2601 | 3 | - | - |
| Datum 2 | 2602 | 3 | - | - |
| ... | ... | 3 | - | - |
| Datum 124 | 267C | 3 | - | - |

Reading the data table

This function is used to read the data set up at the corresponding position. The validity of the datum is indicated in the configuration table. It is possible to read the table in part or in whole from any address.

Exception replies

Sepam sends a Modbus type 07 exception reply (not acknowledged) if the data table has not been set up. This may occur in the following cases:

- the table was never set up
 - the table was set up, but one or more addresses are incorrect
- The configuration table can be read again to identify the addresses in question;
- the configuration was cancelled (the identifier was set to 0)
 - the configuration was lost (Sepam de-energized). In this case, it must be reloaded.

Examples

Secure writing using function 16 (write word) of value 9999h to Modbus address ABCDh on slave 3.

Request frames

| | |
|------|-------------------------------|
| 03 | Slave |
| 66 | Security function code |
| 00 | Version |
| 0000 | Reserved |
| 1234 | Password |
| 10 | Write-word function code |
| ABCD | Address |
| 0001 | Number of words to be written |
| 02 | Number of bytes |
| 9999 | Value to be written |
| xxxx | CRC16 |

Normal reply frames

| | |
|------|--------------------------|
| 03 | Slave |
| 66 | Security function code |
| 00 | Version |
| 10 | Write-word function code |
| 0001 | Number of words written |
| xxxx | CRC16 |

Exception frames

Write-word function exception: it is not possible to write to the given address.

| | |
|------|--------------------------------|
| 03 | Slave |
| 66 | Security function code |
| 00 | Version |
| 90 | Write-word exception (10 + 80) |
| 02 | Incorrect address |
| xxxx | CRC16 |

Security exception: incorrect password

| | |
|------|------------------------------|
| 03 | Slave |
| E6 | Security exception (66 + 80) |
| 80 | Access refused |
| xxxx | CRC16 |

Presentation

With Easergy Sepam series 80, it is possible to protect remote controls and remote settings using a password.

If enabled in the SFT2841 software, the Easergy Sepam series 80 remote control and settings can be password-protected.

Two different passwords are required:

- one password for the remote controls
 - one password for the remote settings
- thus offering differentiated access.

The ON/OFF status of the security function is given by bit 01 of the Sepam check-word.

Implementation

The security function uses an extension of the Modbus protocol that encapsulates the standard remote-control and remote-setting frames in a special frame.

Request frames

The request frame is made of the following components.

| Field | Size (bytes) | |
|------------------------|--------------|------------------------------------|
| Slave number | 1 | |
| 102 (66h) | 1 | Security function code |
| 00 | 1 | Security version |
| 0000 | 2 | Reserved |
| xxxx | 2 | Password (BCD coding) |
| Standard function code | 1 | Encapsulated standard frame |
| Standard frame data | n | |
| ... | n | |
| CRC16 | 2 | |

The standard function codes that can be used in the request are the codes accepted for writing to the corresponding addresses, i.e. 6 and 16 for words and 5 and 15 for bits.

The security function does not affect reading.

The indicated password is the one created with SFT2841, for the given zone. It is a 16-bit BCD code (e.g. the entered password is 1234, the value in the Modbus field is 1234h).

Reply frames

The standard reply frame is also encapsulated, with a reduced header.

| Field | Size (bytes) | |
|------------------------|--------------|------------------------------------|
| Slave number | 1 | |
| 102 (66h) | 1 | Security function code |
| 00 | 1 | Security version |
| Standard function code | 1 | Encapsulated standard reply |
| Standard reply | n | |
| ... | n | |
| CRC16 | 2 | |

Exception replies

Security-function (access control) exceptions

When the security function is enabled on Sepam, request 102 must be used to access Sepam's protected data.

If a non-secure request is used, a standard exception reply 02 (incorrect data addresses) is sent to indicate that the requested data cannot be accessed.

When request 102 is used, a security-function exception reply 80 can be sent to indicate access refused in the following two cases:

- Incorrect security level (the level asked for in the request is not 00)
- Incorrect password

Standard-function (encapsulated) exceptions

When access control has been negotiated successfully, the reply to request 102 can encapsulate a standard exception reply, as described for replies associated with Modbus standard function codes.

Presentation

The "Read Device Identification" function provides standardized access to the information required to clearly identify a device.

The description is made up of a set of objects (ASCII character strings).

Easergy Sepam series 80 accepts the "read identification" function (conformity level 02).

For a complete description of the function, refer to www.modbus.org. The description below covers a subset of the function, adapted to Easergy Sepam series 80.

Implementation

Request frame

The request frame is made of the following components.

| Field | Size (bytes) | |
|--------------|--------------|------------------------------|
| Slave number | 1 | |
| 43 (2Bh) | 1 | Generic access function code |
| 14 (0Eh) | 1 | Read device identification |
| 01 or 02 | 1 | Type of read |
| 00 | 1 | Object number |
| CRC16 | 2 | |

The type of read is used to select a simplified (01) or a standard (02) description.

Easergy Sepam series 80 identification

The objects making up the Easergy Sepam series 80 identification are listed below.

| Number | Type | Value |
|--------|--------------------|--|
| 0: | VendorName | "Merlin Gerin" or "Schneider Electric" |
| 1: | ProductCode | Application EAN13 code |
| 2: | MajorMinorRevision | Application version number (Vx.yy) |
| 3: | VendorURL | "www.schneider-electric.com" |
| 4: | ProductName | "Easergy Sepam series 80" |
| 5: | ModelName | Application name (e.g. "M87 Motor") |
| 6: | UserAppName | Sepam marking |

The simplified description includes only objects 0 to 2.

Reply frame

The reply frame is made of the following components:

| Field | Size (bytes) | |
|--------------|--------------|--|
| Slave number | 1 | |
| 43 (2Bh) | 1 | Generic access function code |
| 14 (0Eh) | 1 | Read device identification |
| 01 or 02 | 1 | Type of read |
| 02 | 1 | Conformity level |
| 00 | 1 | Continuation-frame flag (none for Sepam) |
| 00 | 1 | Reserved |
| n | 1 | Number of objects (according to read type) |
| Obj1 | 1 | Number of first object |
| lg1 | 1 | Length first object |
| txt1 | lg1 | ASCII string of first object |
| | ... | |
| objn | 1 | Number n^{th} object |
| lgn | 1 | Length n^{th} object |
| txtn | lgn | ASCII string of n^{th} object |
| CRC16 | 2 | |

Exception frame

If an error occurs during request processing, a special exception frame is sent.

| Field | Size (bytes) | |
|--------------|--------------|--------------------------------------|
| Slave number | 1 | |
| 171 (ABh) | 1 | Generic access exception (2Bh + 80h) |
| 14 (0Eh) | 1 | Read device identification |
| 01 | 1 | Type of error |
| CRC16 | 2 | |

Introduction

This appendix describes the Modbus protocol and the functions required for Modbus communication with Easergy Sepam series 80. It is not intended to present the entire protocol.

Presentation

Exchanges

The Modbus protocol exchanges information using a request-reply mechanism between a master and a slave.
 An exchange is always initiated (request sent) by the master. The only action on the part of a slave is to reply to requests received.
 Where the communication network permits, several slaves units can be connected to a single master. A request contains the slave address (a unique number) to identify the recipient. Non-addressed slaves disregard the requests received.

Modbus Protocol Data Unit

Every Modbus request or response frame includes a Modbus PDU (protocol data unit) made up of 2 fields.

| | |
|---------------|------|
| Function code | Data |
|---------------|------|

- function code (1 byte): indicates the type of request (1 to 127)
 - data (0 to n bytes): depends on the function code, see below.
- If there is no error, the function codes in the reply and in the request are identical.

Modbus data types

Modbus uses 2 types of data: bits and 16-bit words (also called registers). Each element of data is identified by a 16-bit address. The most-significant byte in 16-bit words is always sent first, for both data and addresses.

Serial line Modbus

This description is limited to the Modbus protocol using a serial link in binary mode (RTU mode).

Frames

All the frames exchanged have the same structure, made up of 3 parts.

| | | |
|---------------|------------|---------------|
| Slave address | Modbus PDU | Check (CRC16) |
|---------------|------------|---------------|

- Slave address (1 byte): from 1 to 247 (0 for broadcasting)
 - Modbus PDU: as previously described
 - Check (2 bytes): CRC16 used to check frame integrity.
- The slave addresses in the reply and in the request are identical.
 The maximum size of a frame is 256 bytes (255 for Easergy Sepam series 80).

Synchronization of exchanges



Any character that is received after a silence of more than 3.5 characters is considered as the beginning of a new frame. A minimum silence of 3.5 characters must always be observed between two frames.

A slave disregards all frames:

- received with a physical error for 1 or more characters (format error, parity error, etc.)
- with an incorrect CRC16 result
- for which it is not the recipient.

Broadcasting

The master can also address all slaves using the conventional address 0. This type of exchange is called broadcasting. Slaves do not respond to broadcast messages. As a result, only messages that do not require the transmission of data by the slaves can be broadcast.



Modbus over TCP/IP

Requests and replies are exchanged as TCP/IP messages over a TCP connection. The slave address is therefore its IP address.

Frames

The application layer part of a Modbus/TCP frame is made up of 2 fields:

| | |
|-------------|------------|
| MBAP Header | Modbus PDU |
|-------------|------------|

- MBAP (Modbus Application) Header (7 bytes): identifies the frame
- Modbus PDU: as previously described.

Modbus Application header

It contains the following fields:

| Field | Length | Description | Request | Response |
|------------------------|---------|---|---------------------------|--|
| Transaction identifier | 2 bytes | Identification of a Modbus request/response transaction | Initialized by the client | Copied by the server from the received request |
| Protocol identifier | 2 bytes | 0 = Modbus protocol | Initialized by the client | Copied by the server from the received request |
| Length | 2 bytes | Number of following bytes (including unit identifier) | Initialized by the client | Initialized by the server |
| Unit identifier | 1 byte | In case of gateways, identifies a remote slave device connected on a serial line. Should be 255 in other cases. | Initialized by the client | Copied by the server from the received request |

Modbus protocol data units

Types of functions

The Modbus protocol provides read and write functions as well as network-management and diagnostics functions.

For greater clarity, **the number of the slave and of the CRC16 are not presented** in the following descriptions although they must appear in the actual frame.

Read N bits functions (1 and 2)

Request

| | | |
|--------|---------------------------------|-----------------------------|
| 1 or 2 | Address of first bit to be read | Number of bits N to be read |
| 1 byte | 2 bytes | 2 bytes |

Reply

| | | |
|--------|----------------------|-----------------|
| 1 or 2 | Number of bytes read | Data |
| 1 byte | 1 byte | (N + 7)/8 bytes |

Function code

- 1 for internal or output bits
- 2 for input bits.

Data

The first bit sent is the LSB in the first byte and the subsequent bits follow in that order. Any excess bits in the last byte are set to 0.

| byte 1 | | | | | | | | byte 2 | | | | | | | |
|--------|---|---|---|---|---|---|---|--------|---|---|---|---|---|---|---|
| 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
| 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 0 | 0 | 0 | 1 | 1 | 1 | 1 | 1 |
| 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| B | A | 9 | 8 | 7 | 6 | 5 | 4 | 0 | F | E | D | C | | | |

Example: coding of the data field for reading 13 bits, starting at address 104h, with two reply bytes (the vertical numbers indicate the Modbus address of the bit in the corresponding position in the reply).

Read N words functions (3 and 4)

Request

| | | |
|--------|----------------------------------|------------------------------|
| 3 or 4 | Address of first word to be read | Number of words N to be read |
| 1 byte | 2 bytes | 2 bytes |

Reply

| | | |
|--------|----------------------|----------|
| 3 or 4 | Number of bytes read | Data |
| 1 byte | 1 byte | 2N bytes |

Function code

- 3 for internal or output words
- 4 for input words.

Data

Words are sent in the order of increasing addresses.

Write bit function (5)

Request

| | | | | |
|--------|-------------|-----------|--------------------------------------|--------|
| 5 | Bit address | Bit value | 0: bit set to 0 FFh: bit set to 1 | 0 |
| 1 byte | 2 bytes | 1 byte | | 1 byte |

Reply

It is identical to the request.

Write word function (6)

Request

| | | |
|--------|--------------|------------|
| 6 | Word address | Word value |
| 1 byte | 2 bytes | 2 bytes |

Reply

It is identical to the request.

Write N consecutive bits function (15)

Request

| | | | | |
|--------|--------------------------------|----------------|-----------------|-----------------|
| 0Fh | Address of 1 st bit | Number of bits | Number of bytes | Data |
| 1 byte | 2 bytes | 2 bytes | 1 byte | (N + 7)/8 bytes |

Data

Bits are coded similar to the Read bits function.

Reply

| | | |
|--------|--|------------------------|
| 0Fh | Address of 1 st bit written | Number of bits written |
| 1 byte | 2 bytes | 2 bytes |

Write N consecutive words function (16)**Request**

| | | | | |
|--------|---------------------------------|-----------------|-----------------|----------|
| 10h | Address of 1 st word | Number of words | Number of bytes | Data |
| 1 byte | 2 bytes | 2 bytes | 1 byte | 2N bytes |

Data

Words are sent in the order of increasing addresses.

Reply

| | | |
|--------|---|-------------------------|
| 10h | Address of 1 st word written | Number of words written |
| 1 byte | 2 bytes | 2 bytes |

High-speed reading of 8 bits function (7)**Request**

| |
|--------|
| 7 |
| 1 byte |

Reply

| | |
|--------|-------------|
| 7 | Status byte |
| 1 byte | 1 byte |

For Easergy Sepam series 80, the status byte is the most-significant byte in the Sepam check-word (address 0C8Fh), i.e. the bits C8F8h to C8FFh.

Diagnosis function (8)**Request**

| | | |
|--------|---------|---------|
| 8 | Subcode | Data |
| 1 byte | 2 bytes | 2 bytes |

Reply

| | | |
|--------|---------|---------|
| 8 | Subcode | Data |
| 1 byte | 2 bytes | 2 bytes |

Subcodes for function 8

| Sub-code | Use | Request Datum | Reply Datum |
|----------|---|---------------|----------------|
| 0000h | Echo mode | Any | Datum received |
| 000Ah | Reset counters CPT1 to CPT9 | 0000 | 0000 |
| 000Bh | Read CPT1 (frames without errors) | 0000 | CPT1 |
| 000Ch | Read CPT2 (frames with errors) | 0000 | CPT2 |
| 000Dh | Read CPT3 (exception replies) | 0000 | CPT3 |
| 000Eh | Read CPT4 (frames sent to station) | 0000 | CPT4 |
| 000Fh | Read CPT5 (frames broadcast) | 0000 | CPT5 |
| 0010h | Read CPT6 (not managed by Sepam) | 0000 | CPT6 |
| 0011h | Read CPT7 (not managed by Sepam) | 0000 | CPT7 |
| 0012h | Read CPT8 (frames with physical errors) | 0000 | CPT8 |

Read event counter function (11)

For Easergy Sepam series 80, the event counter is CPT9 (number of correct requests received and correctly executed).

Request

| |
|--------|
| 0Bh |
| 1 byte |

Reply

| | | |
|--------|---------|--------------|
| 0Bh | 0000 | Counter CPT9 |
| 1 byte | 2 bytes | 2 bytes |

Exception replies

Each time a slave station receives a frame without errors that it cannot process, it sends an exception reply with the elements below.

| | |
|-----------------------------|-------------------|
| Request function code + 80h | Type of exception |
| 1 byte | 1 byte |

| Type of exception | Meaning |
|-------------------|-------------------------|
| 01 | Unknown function code |
| 02 | Incorrect address |
| 03 | Incorrect datum |
| 04 | Device not ready |
| 07 | Negative acknowledgment |

Calculation of the CRC16

The CRC16 is calculated by the station sending the frame. On reception, the CRC16 is recalculated and compared to the received value. If the two values are not the same, the frame is rejected.

The CRC16 uses two bytes. Contrary to the general Modbus rule, the least-significant byte is sent first. It is the product of the polynomial division of the frame by the generating polynomial $X^{16} + X^{15} + X^2 + 1$.

A number of methods may be used to calculate it. The table method is often used because it is very effective. The program below, written in the C language, is an example of this method.

```

unsigned short CRC16(puchMsg, usDataLen)
unsigned char *puchMsg ;
unsigned short usDataLen ;
{
    unsigned char uchCRCHi = 0xFF ;
    unsigned char uchCRCLo = 0xFF ;
    unsigned uIndex ;
    while (usDataLen-- ) {
        uIndex = uchCRCHi ^ *puchMsg++ ;
        uchCRCHi = uchCRCLo ^ auchCRCHi[uIndex] ;
        uchCRCLo = auchCRCLo[uIndex] ;
    }
    return (uchCRCHi << 8 | uchCRCLo) ;
}

/* Table of CRC values for high-order byte */
static unsigned char auchCRCHi[] = {
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40,
0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40,
0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40,
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40,
0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40,
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40,
0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40 } ;

/* Table of CRC values for low-order byte */
static char auchCRCLo[] = {
0x00, 0xC0, 0xC1, 0x01, 0xC3, 0x03, 0x02, 0xC2, 0xC6, 0x06, 0x07, 0xC7, 0x05, 0xC5, 0xC4, 0x04,
0xCC, 0x0C, 0x0D, 0xCD, 0x0F, 0xCF, 0xCE, 0x0E, 0x0A, 0xCA, 0xCB, 0x0B, 0xC9, 0x09, 0x08, 0xC8,
0xD8, 0x18, 0x19, 0xD9, 0x1B, 0xDB, 0xDA, 0x1A, 0x1E, 0xDE, 0xDF, 0x1F, 0xDD, 0x1D, 0xDC, 0x14,
0xD4, 0xD5, 0x15, 0xD7, 0x17, 0xD6, 0xD2, 0x12, 0xD3, 0xD3, 0x11, 0xD1, 0xD0, 0x10,
0xF0, 0x30, 0x31, 0xF1, 0x33, 0xF3, 0xF2, 0x32, 0x36, 0xF6, 0xF7, 0x37, 0xF5, 0x35, 0x34, 0xF4,
0x3C, 0xFC, 0xFD, 0x3D, 0xFF, 0x3F, 0x3E, 0xFE, 0xFA, 0x3A, 0x3B, 0xFB, 0x39, 0xF9, 0xF8, 0x38,
0x28, 0xE8, 0xE9, 0x29, 0xEB, 0x2B, 0x2A, 0xEA, 0xEE, 0x2E, 0x2F, 0xEF, 0x2D, 0xED, 0xEC, 0x2C,
0xE4, 0x24, 0x25, 0xE5, 0x27, 0xE7, 0xE6, 0x26, 0x22, 0xE2, 0xE3, 0x23, 0xE1, 0x21, 0x20, 0xE0,
0xA0, 0x60, 0x61, 0xA1, 0x63, 0xA3, 0xA2, 0x62, 0x66, 0xA6, 0xA7, 0x67, 0xA5, 0x65, 0xA4,
0x6C, 0xAC, 0xAD, 0x6D, 0xAF, 0x6F, 0x6E, 0xAE, 0xAA, 0x6A, 0x6B, 0xAB, 0x69, 0xA9, 0xA8, 0x68,
0x78, 0xB8, 0xB9, 0x79, 0xBB, 0x7B, 0x7A, 0xBA, 0xBE, 0x7E, 0x7F, 0xBF, 0x7D, 0xBD, 0xBC, 0x7C,
0xB4, 0x74, 0x75, 0xB5, 0x77, 0xB7, 0xB6, 0x76, 0x72, 0xB2, 0xB3, 0x73, 0xB1, 0x71, 0x70, 0xB0,
0x50, 0x90, 0x91, 0x51, 0x93, 0x53, 0x52, 0x92, 0x96, 0x56, 0x57, 0x97, 0x95, 0x55, 0x94, 0x54,
0x9C, 0x5C, 0x5D, 0x9D, 0x5F, 0x9F, 0x9E, 0x5E, 0x5A, 0x9A, 0x9B, 0x5B, 0x99, 0x59, 0x58, 0x98,
0x88, 0x48, 0x49, 0x89, 0x4B, 0x8B, 0x8A, 0x4A, 0x4E, 0x8E, 0x8F, 0x4F, 0x8D, 0x4D, 0x4C, 0x8C,
0x44, 0x84, 0x85, 0x45, 0x87, 0x47, 0x46, 0x86, 0x82, 0x42, 0x43, 0x83, 0x41, 0x81, 0x40 } ;

```

Example of calculation in the C language

The function uses two parameters:

- unsigned char *puchMsg: points to the frame for CRC calculation
- unsigned short usDataLen: number of bytes in the frame.

The function returns the CRC as an unsigned short type. All possible CRC values are listed in two tables indexed according to the value of the successive bytes in the frame. One table contains the 256 possible values for the most-significant byte in the CRC and the other table contains the 256 possible values for the least-significant byte in the CRC.

Note: the result is ready to be inserted in the frame, the order of the bytes has already been reversed.

Setting coding

Data format

All the settings are transmitted in 32-bit signed 2's complement integer format.

Coding of tripping and timer hold curves

The numbers correspond to the setting columns in the lists of settings.

① Tripping curves

- 0 = definite time
- 1 = inverse
- 2 = long time inverse
- 3 = very inverse
- 4 = extremely inverse
- 5 = ultra inverse
- 6 = RI
- 7 = IEC inverse / A
- 8 = IEC long time inverse / B
- 24 = Customized curve
- 25 = EPATR-B
- 26 = EPATR-C
- 9 = IEC very inverse / B
- 10 = IEC extremely inverse / C
- 11 = IEEE moderately inverse
- 12 = IEEE very inverse
- 13 = IEEE extremely inverse
- 14 = IAC inverse
- 15 = IAC very inverse
- 16 = IAC extr. inverse

② Tripping curves

- 0 = definite time
- 7 = IEC inverse / A
- 8 = IEC long time inverse / B
- 9 = IEC very inverse / B
- 10 = IEC extremely inverse / C
- 11 = IEEE moderately inverse
- 12 = IEEE very inverse
- 13 = IEEE extremely inverse
- 17 = Specific Schneider curve
- 20 = RI²

③ Timer hold curves

- 0 = definite time
- 1 = IDMT

Common protection settings

All protection functions have the following settings at the head of the table.

| Setting | Data | Format/Unit |
|---------|--------------------|--|
| 1 | Latching | 0: no 1: yes |
| 2 | Program logic | see below |
| 3 | Activity | 0: Off 1: On |
| 4 | Measurement origin | 0: main 1: additional or special case, see below |

Details on program-logic field

| Bit | 31 | 30 | | 4 | 3 | 2 | 1 | 0 |
|-----|----|----|------|---|---|-----|-----|-----|
| | | | | | | DES | AGR | CDC |

- CDC = 1: the protection function takes part in circuit-breaker/contactors control
= 0: the protection function does not take part
- AGR = 1: the protection function takes part in genset shutdown (generator application)
= 0: the protection function does not take part
- DES = 1: the protection function takes part in de-excitation (generator application)
= 0: the protection function does not take part

When a common protection setting is not applicable to a particular protection function, it is signaled "reserved" in the table for the function.

Measurement origin

A few special cases of coding for the measurement-origin field, for the ANSI 50N/51N, ANSI 67N/67NC and ANSI 59N protection functions, are indicated in the table below:

| Value | 50N/51N | 67N/67NC | 59N |
|-------|---------|----------|-----|
| 0 | I0Σ | I0Σ | V0 |
| 1 | I0 | I0 | Vnt |
| 2 | I'0 | I'0 | |
| 3 | I'0Σ | | |

Protection settings

They are organized according to **increasing ANSI codes**.

ANSI 12 - Overspeed

Function number: 72xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Set point | % |
| 6 | Tripping time delay | 10 ms |

ANSI 14 - Underspeed

Function number: 77xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Set point | % |
| 6 | Tripping time delay | 10 ms |

ANSI 21B - Underimpedance

Function number: 7401

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Zs set point | mΩ |
| 6 | Tripping time delay | 10 ms |

ANSI 24 - Overfluxing (V/Hz)

Function number: 75xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|---|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Machine coupling | 0: delta 1: star |
| 6 | Tripping curve | 0 = definite 21 = Type A 22 = Type B 23 = Type C |
| 7 | Gs set point | 0.01 pu |
| 8 | Tripping time delay | 10 ms |

ANSI 25 – Synchro-check

Function number: 1801

| Setting | Data | Format/Unit |
|---------|--|---|
| 1 | Reserved | |
| 2 | Reserved | |
| 3 | Activity | 0: off 1: on |
| 4 | dUs set point | % Vnp sync1 or % Unp sync1 |
| 5 | dFs set point | 0.01 Hz |
| 6 | dPhis set point | ° |
| 7 | Us high set point | % Vnp sync1 or % Unp sync1 |
| 8 | Us low set point | % Vnp sync1 or % Unp sync1 |
| 9 | Operating modes (no-voltage conditions for which coupling is allowed) | 1: Dead1 AND Live2 2: Live1 AND Dead2 3: Dead1 XOR Dead2 4: Dead1 OR Dead2 5: Dead1 AND Dead2 |
| 10 | Lead time | 10 ms |
| 11 | Use of voltage check for coupling authorization | 0: no 1: yes |

ANSI 27 - Undervoltage

Function number: 32xx

Unit 1: xx = 01 to unit 4: xx = 04

| Setting | Data | Format/Unit |
|---------|---------------------------------|--|
| 1 to 4 | Common settings | |
| 5 | Tripping curve | 0: definite 19: IDMT 27: customized |
| 6 | Voltage mode | 0: phase-to-neutral 1: phase-to-phase |
| 7 | Us set point | % Unp |
| 8 | Tripping time delay | DT: 0.05 to 300 s IDMT: See note below Customized: range = 1 (TMS = 1) |
| 9 | DT of 1st point on the curve | 10 ms |
| 10 | U/Un of 1st point on the curve | % |
| 11 | DT of 2nd point on the curve | 10 ms |
| 12 | U/Un of 2nd point on the curve | % |
| 13 | DT of 3rd point on the curve | N/A |
| 14 | U/Un of 3rd point on the curve | N/A |
| ... | | |
| 29 | DT of 11th point on the curve | N/A |
| 30 | U/Un of 11th point on the curve | N/A |

Note setting 8

- For a setting mode with 10 I/IS: the range varies from 0.05 s to 300 s.

- For a setting in TMS (Time Multiplier Setting) mode, the range depends on the selected curve and varies as follows:

- inverse (SIT) and IEC SIT/A: 0.04 to 4.20
- very inverse (VIT) and IEC VIT/B: 0.07 to 8.33
- long time inverse (LTI) and IEC LTI/B: 0.01 to 0.93
- extremely inverse (EIT) and IEC EIT/C: 0.13 to 15.47
- IEEE moderately inverse: 0.42 to 51.86
- IEEE very inverse: 0.73 to 90.57
- IEEE extremely inverse: 1.24 to 154.32
- IAC inverse: 0.34 to 42.08
- IAC very inverse: 0.61 to 75.75
- IAC extremely inverse: 1.08 to 134.4

Notes settings 9 to 30

The customized curve is unique and only concerns unit 1. However, to retain consistency with the Sepam software architecture, the same frame format is used for all units. Unused points are set to (-1, -1). This is the case for the points for unit 2 and above. It is also the case for additional points for unit 1. For example, if the curve is defined by 6 points, the last 5 are set to (-1, -1). There is no "Number of points" setting in the frame.

For each useful point, the value of T must be greater than or equal to that of the previous point. The first point must be 0 (rising or falling operations are allowed). The value of U/Un for the last useful point must be greater than all the other values of U/Un.

ANSI 27D - Positive sequence undervoltage

Function number: 38xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 4 | Common settings | |
| 5 | Vds set point | % Unp |
| 6 | Tripping time delay | 10 ms |

ANSI 27R - Remanent undervoltage

Function number: 35xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 4 | Common settings | |
| 5 | Us set point | % Unp |
| 6 | Tripping time delay | 10 ms |

ANSI 27TN/64G2 - Third harmonic undervoltage

Function number: 71xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Access | 0: adaptive 1: fixed |
| 6 | Vs set point | 0.1 % Unp |
| 7 | Min. Ss set point | % Sb |
| 8 | Min. Vs set point | % Unp |
| 9 | K set point | 0.01 |
| 10 | Tripping time delay | 10 ms |

ANSI 32P - Directional active overpower

Function number: 53xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|----------------------------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Access | 0: reverse power 1: overpower |
| 6 | Ps set point | 100 W |
| 7 | Tripping time delay | 10 ms |

ANSI 32Q - Directional reactive overpower

Function number: 5401

| Setting | Data | Format/Unit |
|---------|---------------------|----------------------------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Access | 0: reverse power 1: overpower |
| 6 | Qs set point | 100 var |
| 7 | Tripping time delay | 10 ms |

ANSI 37 - Phase undercurrent

Function number: 2201

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Is set point | % Ib |
| 6 | Tripping time delay | 10 ms |

ANSI 37P - Directional active underpower

Function number: 55xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Access | 0: drawn 1: supplied |
| 6 | Ps set point | 100 W |
| 7 | Tripping time delay | 10 ms |

ANSI 38/49T - Temperature monitoring

Function number: 46xx

Unit 1: xx = 01 to unit 16: xx = 10h

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Ts1 alarm set point | °C |
| 6 | Ts2 alarm set point | °C |

ANSI 40 - Field loss (underimpedance)

Function number: 7001

| Setting | Data | Format/Unit |
|---------|-------------------------------|-------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Xa resistance | 1 mΩ |
| 6 | Xb resistance | 1 mΩ |
| 7 | Xc resistance | 1 mΩ |
| 8 | Tripping time delay circle 1 | 10 ms |
| 9 | Tripping time delay circle Xd | 10 ms |

ANSI 46 - Negative sequence / unbalance

Function number: 45xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|---------------|
| 1 to 4 | Common settings | |
| 5 | Tripping curve | ② |
| 6 | Is set point | % Ib or % I'b |
| 7 | Tripping time delay | 10 ms |
| 8 | K setting | 1 to 100 |

ANSI 47 - Negative sequence overvoltage

Function number: 40xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 4 | Common settings | |
| 5 | Vis set point | % Unp |
| 6 | Tripping time delay | 10 ms |

ANSI 48/51LR - Locked rotor / excessive starting time

Function number: 4401

| Setting | Data | Format/Unit |
|---------|----------------------------|-------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Is set point | % Ib |
| 6 | ST excessive starting time | 10 ms |
| 7 | LT locked rotor time | 10 ms |
| 8 | LTS locked on start time | 10 ms |

ANSI 49RMS

Function number: 4301

Thermal overload

| Setting | Data | Format/Unit |
|---------|---|--|
| 1 to 4 | Common settings | |
| 5 | Negative sequence factor (K) | 0: none (0) 1: low (2.25) 2: medium (4.5) 3: high (9) |
| 6 | Is set point (shift group 1/group 2) | % Ib |
| 7 | Ambient temperature taken into account | 0: no 1: yes |
| 8 | Maximum equipment temperature | °C |
| 9 | Additional settings taken into account (group 2) | 0: no 1: yes |
| 10 | Learnt cooling time constant (T2 learnt) taken into account | 0: no 1: yes |
| 11 | Group 1 - thermal alarm set point | % |
| 12 | Group 1 - thermal tripping set point | % |
| 13 | Group 1 - heating time constant | |
| 14 | Group 1 - cooling time constant | min. |
| 15 | Group 1 - initial heat rise | % |
| 16 | Group 2 - thermal alarm set point | % |
| 17 | Group 2 - thermal tripping set point | % |
| 18 | Group 2 - heating time constant | min. |
| 19 | Group 2 - cooling time constant | min. |
| 20 | Group 2 - initial heat rise | % |
| 21 | Group 2 - base current for group 2 | 0.1 A |
| 22 | 49RMS cable - admissible current | 0.1 A |
| | 49RMS capacitor - tripping current | 0.1 A |
| 23 | Associated time constant | min. |
| 24 | Current setting | 0.1 A |
| 25 | Alarm current | 0.1 A |
| 26 | Type of thermal model | 0: generic |

Note: ■ thermal overload for machines: parameters 1 to 21
 ■ thermal overload for cables: parameters 1 to 4 and 22 to 23
 ■ thermal overload for capacitors: parameters 1 to 4 and 22 to 25

Motor thermal overload

| Setting | Data | Format/Unit |
|---------|--|-----------------|
| 1 | Latching | 0: no, 1: yes |
| 2 | Circuit breaker control | 0: no, 1: yes |
| 3 | Activity | 0: off 1: on |
| 4 | Ialarm = current alarm set point | % |
| 5 | Itrip = current tripping set point | % |
| 6 | Tlong = motor heating time constant | min. |
| 7 | Tshort = stator heating time constant | min. |
| 8 | Tcool = cooling time constant | min. |
| 9 | Alpha = rotor/stator exchange coefficient | % |
| 10 | IL = locked rotor current | % |
| 11 | LRT = locked rotor torque | % |
| 12 | Idem = starting current set point | % |
| 13 | Ambient T taken into account by sensor 8 | 0: no, 1: yes |
| 14 | Tmax = max. stator temperature constant | °C |
| 15 | Tc = locked rotor cold limit time | seconds |
| 16 | Th = locked rotor hot limit time | seconds |
| 17 | Sh = Heat rise set point for hot state bit | % |
| ... | Reserved | |
| 25 | Reserved | |
| 26 | Type of thermal model ⁽¹⁾ | 1: Motor |

⁽¹⁾ This setting is always at 1 for the motor thermal overload model.

ANSI 49RMS

Function number: 4301

Transformer thermal overload

| Setting | Data | Format/Unit |
|-----------|---|--|
| 1 | Latching | 0: no, 1: yes |
| 2 | Circuit breaker control | 0: no, 1: yes |
| 3 | Activity | 0: off 1: on |
| 4 | Measurement origin | 0: primary 1: secondary |
| 5 | Type of transformer | 0: AN dry-type 1: AF dry-type 2: distribution ONAN immersed 3: High and medium power ONAN immersed 4: ONAF 5: OF 6: OD |
| 6 | Insulation class ⁽¹⁾ | ■ Dry-type transformer: 105, 120, 130, 135, 180, 200 or 220° ■ Immersed transformer: 0 (not significant) Unit = ° |
| 7 | Alarm temperature (group 1) ⁽²⁾ | ■ Dry-type transformer: Class 105: 95 to 130° Class 120: 110 to 145° Class 130: 120 to 155° Class 180: 170 to 205° Class 200: 190 to 225° Class 220: 210 to 245° ■ Immersed transformer: 98 to 160 ° Unit = ° |
| 8 | Tripping temperature (group 1) | Same as alarm temperature |
| 9 | Alarm temperature (group 2) ⁽²⁾ | Same as group 1 |
| 10 | Tripping temperature (group 2) | Same as group 1 |
| 11 | Transformer time constant | 1 to 600 Unit = minutes |
| 12 | Oil time constant ⁽³⁾ | 5 to 600 Unit = minutes |
| 13 | Ambient T taken into account by sensor 8 | 0: no, 1: yes |
| 14 | Oil T taken into account by sensor 8 ⁽³⁾ | 0: no, 1: yes |
| 15 | Additional settings taken into account (group 2) ⁽³⁾ | 0: no, 1: yes |
| 16 | Restricted oil flow | 0: no, 1: yes |
| 17 ... 25 | Reserved | |
| 26 | Type of thermal model ⁽⁴⁾ | 2: Transformer |

⁽¹⁾ This setting only applies to dry-type transformers. Value 0 accepted for an immersed transformer.

⁽²⁾ Alarm temperature must be less than the tripping temperature.

⁽³⁾ This parameter only applies to immersed transformers. Value 0 accepted for a dry-type transformer.

⁽⁴⁾ This setting is always at 1 for the transformer thermal overload model.

ANSI 50BF - Breaker failure

Function number: 9801

| Setting | Data | Format/Unit |
|---------|-----------------------------|-----------------|
| 1 | Common settings | |
| 2 | Reserved | |
| 3 | Common settings | |
| 4 | Reserved | |
| 5 | Use of breaker closed input | 0: no 1: yes |
| 6 | Is set point | 0.1 A |
| 7 | Time | 10 ms |

ANSI 50/27 - Inadvertent energization

Function number: 7301

| Setting | Data | Format/Unit |
|---------|--------------------------------|-----------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Is set point | 0.1 A |
| 6 | Vs set point | % Unp |
| 7 | T1 time | 10 ms |
| 8 | T2 time | 10 ms |
| 9 | Use of breaker-position inputs | 0: no 1: yes |

ANSI 50/51 - Phase overcurrent

Function number: 01xx

Unit 1: xx = 01 to unit 8: xx = 08

| Setting | Data | Format/Unit |
|---------|---------------------------------------|---|
| 1 to 4 | Common settings | |
| 5 | Confirmation | 0 = none 1 = neg. seq. overvoltage 2 = undervoltage |
| 6 | Group A - tripping curve | ① |
| 7 | Group A - Is set point | 0.1 A |
| 8 | Group A - tripping time delay | 10 ms |
| 9 | Group A - timer hold curve | ③ |
| 10 | Group A - timer hold | 10 ms |
| 11 | Group B - tripping curve | ① |
| 12 | Group B - Is set point | 0.1 A |
| 13 | Group B - tripping time delay | 10 ms |
| 14 | Group B - timer hold curve | ③ |
| 15 | Group B - timer hold | 10 ms |
| 16 | Group A - harmonic 2 restraint | 0: active, 1: inactive |
| 17 | Group A - Isc min | 0.1 A |
| 18 | Group B - harmonic 2 restraint | 0: active, 1: inactive |
| 19 | Group B - Isc min | 0.1 A |
| 20 | H2 restraint set point ⁽¹⁾ | % |

(1) Parameter common to all groups and all units.

ANSI 50N/51N - Earth fault

Function number: 06xx

Unit 1: xx = 01 to unit 8: xx = 08

| Setting | Data | Format/Unit |
|---------|-------------------------------|-----------------|
| 1 to 4 | Common settings | |
| 5 | Group A - tripping curve | ① |
| 6 | Group A - Is0 set point | 0.1 A |
| 7 | Group A - tripping time delay | 10 ms |
| 8 | Group A - timer hold curve | ③ |
| 9 | Group A - timer hold | 10 ms |
| 10 | Group A - H2 restraint | 0: yes 1: no |
| 11 | Group B - tripping curve | ① |
| 12 | Group B - Is0 set point | 0.1 A |
| 13 | Group B - tripping time delay | 10 ms |
| 14 | Group B - timer hold curve | ③ |
| 15 | Group B - timer hold | 10 ms |
| 16 | Group B - H2 restraint | 0: yes 1: no |

ANSI 50V/51V - Voltage-restrained phase overcurrent

Function number: 19xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------|
| 1 to 4 | Common settings | |
| 5 | Tripping curve | ① |
| 6 | Is set point | 0.1 A |
| 7 | Tripping time delay | 10 ms |
| 8 | Timer hold curve | ③ |
| 9 | Timer hold | 10 ms |

ANSI 51C – Capacitor bank unbalance

Function number: 03xx

Unit 1: xx = 01 to unit 8: xx = 08

| Setting | Data | Format/Unit |
|---------|---------------------|-----------------|
| 1 | Latching | 0: no 1: yes |
| 2 | Switchgear control | 0: no 1: yes |
| 3 | Activity | 0: off 1: on |
| 4 | Reserved | |
| 5 | Is set point | 0.01 A |
| 6 | Tripping time delay | 10 ms |

ANSI 59 - Overvoltage

Function number: 28xx

Unit 1: xx = 01 to unit 4: xx = 04

| Setting | Data | Format/Unit |
|---------|---------------------------------------|--|
| 1 to 4 | Common settings | |
| 5 | Voltage mode | 0: phase-to-neutral 1: phase-to-phase |
| 6 | Us set point | % Unp |
| 7 | Tripping time delay | 10 ms |
| 8 | Drop-out/pick-up ratio ⁽¹⁾ | 0,05 % |
| 9 | Vs set point for B83 ⁽¹⁾ | % Unp |

*(1) For a B83 application with additional channels.***ANSI 59N - Neutral voltage displacement**

Function number: 39xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-------------------------|
| 1 to 4 | Common settings | |
| 5 | Tripping curve | 0: definite 18: IDMT |
| 6 | Vs0 set point | % Unp |
| 7 | Tripping time delay | 10 ms |

ANSI 64 REF - Restricted earth fault differential

Function number: 64xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|-----------------|-------------|
| 1 to 4 | Common settings | |
| 5 | Is0 set point | 0.1 A |

ANSI 66 - Starts per hour

Function number: 4201

| Setting | Data | Format/Unit |
|---------|-----------------------------------|-------------|
| 1 | Common settings | |
| 2 | Reserved | |
| 3 | Common settings | |
| 4 | Reserved | |
| 5 | Period of time | Hours |
| 6 | Total number of starts | 1 |
| 7 | Number of consecutive hot starts | 1 |
| 8 | Number of consecutive cold starts | 1 |
| 9 | Delay between stop/start | min. |
| 10 | Delay between consecutive starts | min. |

ANSI 67 - Directional phase overcurrent

Function number: 52xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|--------------------------------|----------------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Group A - direction | 0: line 1: busbar |
| 6 | Group A - characteristic angle | 3: 30° 4: 45° 5: 60° |
| 7 | Group A - tripping logic | 0: 1/3 1: 2/3 |
| 8 | Group A - tripping curve | ① |
| 9 | Group A - Is set point | 0.1 A |
| 10 | Group A - tripping time delay | 10 ms |
| 11 | Group A - timer hold curve | ③ |
| 12 | Group A - timer hold | 10 ms |
| 13 | Group B - direction | 0: line 1: busbar |
| 14 | Group B - characteristic angle | 3: 30° 4: 45° 5: 60° |
| 15 | Group B - tripping logic | 0: 1/3 1: 2/3 |
| 16 | Group B - tripping curve | ① |
| 17 | Group B - Is set point | 0.1 A |
| 18 | Group B - tripping time delay | 10 ms |
| 19 | Group B - timer hold curve | ③ |
| 20 | Group B - timer hold | 10 ms |

ANSI 67N/67NC - Directional earth fault

Function number: 50xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---|---|
| 1 to 4 | Common settings | |
| 5 | Access | 0: projection (type 1) 1: directional (type 2) 2: directional with adjustable sector (type 3) |
| 6 | Group A - direction | 0: line 1: busbar |
| 7 | Group A - types 1 and 2: characteristic angle | 0: -45° 1: 0° 2: 15° 3: 30° 4: 45° 5: 60° 6: 90° |
| | Group A - type 3: limiting angle 1 | 0° to 359° |
| 8 | Group A - type 1: sector | 2: sector 76° 3: sector 83° 4: sector 86° |
| | Group A - type 3: limiting angle 2 | 0° to 359° |
| 9 | Group A - tripping curve | ① |
| 10 | Group A - Is0 set point | 0.1 A |
| 11 | Group A - tripping time delay | 10 ms |
| 12 | Group A - types 1 and 2: Vs0 set point | % Unp |
| | Group A - type 3: Vs0 set point | 0.1% Unp |
| 13 | Group A - timer hold curve | ③ |
| 14 | Group A - timer hold | 10 ms |
| 15 | Group A - memory time | 10 ms |
| 16 | Group A - memory voltage | % Unp |
| 17 | Group B - direction | 0: line 1: busbar |
| 18 | Group B - types 1 and 2: characteristic angle | Same as group A |
| | Group B - type 3: limiting angle 1 | 0° to 359° |
| 19 | Group B - type 1: sector | Same as group A |
| | Group B - type 3: limiting angle 2 | 0° to 359° |
| 20 | Group B - tripping curve | ① |
| 21 | Group B - Is0 set point | 0.1 A |
| 22 | Group B - tripping time delay | 10 ms |
| 23 | Group B - types 1 and 2: Vs0 set point | % Unp |
| | Group B - type 3: Vs0 set point | 0.1% Unp |
| 24 | Group B - timer hold curve | ③ |
| 25 | Group B - timer hold | 10 ms |
| 26 | Group B - memory time | 10 ms |
| 27 | Group B - memory voltage | % Unp |

ANSI 78PS - Pole slip

Function number: 7601

| Setting | Data | Format/Unit |
|---------|--------------------------------------|---|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Access | 0: equal-area criterion 1: power-swing criterion 2: both criteria 3: calculation of the internal angle |
| 6 | T area | 10 ms |
| 7 | Max. number of power swings | 1 to 30 |
| 8 | Max. time between power swings | 10 ms |
| 9 | Starting time | 10 ms |
| 10 | Minimum internal angle for stability | degrees |
| 11 | Confirmation timeout before tripping | 10 ms |

ANSI 81H - Overfrequency

Function number: 57xx

Unit 1: xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|-----------------------------|-------------|
| 1 to 4 | Common settings | |
| 5 | Fs set point ⁽¹⁾ | 0.1 Hz |
| 6 | Tripping time delay | 10 ms |
| 7 | Reserved | |
| 8 | Vs set point | % Unp |
| 9 | Fs set point | 0.01 Hz |

⁽¹⁾ Setting 5 is reserved for future compatibility with firmware versions higher than version 8xx.

ANSI 81L - Underfrequency

Function number: 56xx

Unit 1: xx = 01 to unit 4: xx = 04

| Setting | Data | Format/Unit |
|---------|--|-----------------|
| 1 to 4 | Common settings | |
| 5 | Fs set point ⁽¹⁾ | 0.1 Hz |
| 6 | Tripping time delay | 10 ms |
| 7 | Restraint | 0: no 1: yes |
| 8 | Vs set point | % Unp |
| 9 | Inhibition set point for frequency variation | Hz/s |
| 10 | Fs set point | 0.01 Hz |

⁽¹⁾ Setting 5 is reserved for future compatibility with firmware versions higher than version 8xx.**ANSI 81R – Rate of change of frequency**

Function number: 58xx

Unit: 1 xx = 01, unit 2: xx = 02

| Setting | Data | Format/Unit |
|---------|---------------------|-----------------|
| 1 | Latching | 0: no 1: yes |
| 2 | Switchgear control | 0: no 1: yes |
| 3 | Activity | 0: off 1: on |
| 4 | Reserved | |
| 5 | dfs/dt set point | 0.01 Hz/s |
| 6 | Tripping time delay | 10 ms |

ANSI 87M - Machine differential

Function number: 6201

| Setting | Data | Format/Unit |
|---------|--------------------------|-----------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Ids set point | 1 A |
| 6 | Restraint on sensor loss | 0: no 1: yes |

ANSI 87T - Transformer differential

Function number: 6001

| Setting | Data | Format/Unit |
|---------|---------------------------------|-------------------------------------|
| 1 to 3 | Common settings | |
| 4 | Reserved | |
| 5 | Ids low set point | % In1 |
| 6 | Id/It slope | % |
| 7 | Restraint on CT loss | 0: off 1: on |
| 8 | Test mode | 0: off 1: on |
| 9 | Id/It2 slope | % |
| 10 | Id/It2 characteristic | 0: off 1: on |
| 11 | Slope change point | 0.1 A |
| 12 | Idmax high set point | 0.1 A |
| 13 | Idmax high set point activity | 0: off 1: on |
| 14 | Selection of restraint | 0: conventional 1: self-adaptive |
| 15 | Second-harmonic set point | % |
| 16 | Second-harmonic restraint | 0: off 1: on |
| 17 | Second-harmonic restraint type | 0: phase-specific 1: global |
| 18 | Fifth-harmonic set point | % |
| 19 | Fifth-harmonic restraint | 0: off 1: on |
| 20 | Fifth-harmonic restraint type | 0: phase-specific 1: global |
| 21 | Isinr set point | % |
| 22 | Restraint on closing | 0: off 1: on |
| 23 | Restraint on closing time delay | 10 ms |

Other function settings

ANSI 60 - CT supervision

Function number: 2601: CT supervision
2602: additional CT supervision

| Setting | Data | Format/Unit |
|---------|---|--------------------------|
| 1 | Reserved | |
| 2 | Reserved | |
| 3 | Common settings | |
| 4 | Reserved | |
| 5 | Action on 21G, 46, 40, 51N, 32P, 37P, 32Q, 78PS and 64REF functions | 0: none 1: inhibition |
| 6 | Tripping time delay | 10 ms |

ANSI 60FL - VT supervision

Function number: 2701: VT supervision
2702: additional VT supervision

| Setting | Data | Format/Unit |
|---------|---|-------------------------------------|
| 1 | Reserved | |
| 2 | Reserved | |
| 3 | Common settings | |
| 4 | Reserved | |
| 5 | Use breaker-position or voltage-presence criterion | 0: circuit breaker 1: voltage |
| 6 | Check loss of 3 V/2 U | 0: no 1: yes |
| 7 | Test current | 0: no 1: yes |
| 8 | Use Vi, li criterion | 0: no 1: yes |
| 9 | Action on 21G, 27, 27D, 27TN, 32P, 32Q, 37P, 40, 47, 50/27, 51V, 59, 59N and 78PS functions | 0: none 1: inhibition |
| 10 | Action on 67 function | 0: non directional 1: inhibition |
| 11 | Action on 67N function | 0: non directional 1: inhibition |
| 12 | Vi tripping set point | % |
| 13 | li tripping set point | % |
| 14 | 3 V/ 2 U loss time | 10 ms |
| 15 | Vi, li criterion time | 10 ms |

ANSI 79 - Recloser

Function number: 1701

| Setting | Data | Format/Unit |
|---------|-------------------------------|-----------------|
| 1 | Reserved | |
| 2 | Reserved | |
| 3 | Common settings | |
| 4 | Reserved | |
| 5 | Number of cycles | 1 to 4 |
| 6 | Reclaim time | 10 ms |
| 7 | Safety time until ready | 10 ms |
| 8 | Maximum additional dead time | 0: no 1: yes |
| 9 | Maximum wait time | 10 ms |
| 10 | Cycle 1 activation mode | see below |
| 11 | Cycle 2, 3, 4 activation mode | see below |
| 12 | Cycle 1 dead time | 10 ms |
| 13 | Cycle 2 dead time | 10 ms |
| 14 | Cycle 3 dead time | 10 ms |
| 15 | Cycle 4 dead time | 10 ms |

Cycle activation mode

The activation mode of each cycle is coded as follows:

| Bit | Activation by (if bit set to 1) / Non activation by (if bit set to 0) |
|-----|---|
| 0 | Instantaneous protection 50/51 unit 1 |
| 1 | Delayed protection 50/51 unit 1 |
| 2 | Instantaneous protection 50/51 unit 2 |
| 3 | Delayed protection 50/51 unit 2 |
| 4 | Instantaneous protection 50/51 unit 3 |
| 5 | Delayed protection 50/51 unit 3 |
| 6 | Instantaneous protection 50/51 unit 4 |
| 7 | Delayed protection 50/51 unit 4 |
| 8 | Instantaneous protection 50N/51N unit 1 |
| 9 | Delayed protection 50N/51N unit 1 |
| 10 | Instantaneous protection 50N/51N unit 2 |
| 11 | Delayed protection 50N/51N unit 2 |
| 12 | Instantaneous protection 50N/51N unit 3 |
| 13 | Delayed protection 50N/51N unit 3 |
| 14 | Instantaneous protection 50N/51N unit 4 |
| 15 | Delayed protection 50N/51N unit 4 |
| 16 | Instantaneous protection 67N unit 1 |
| 17 | Delayed protection 67N unit 1 |
| 18 | Instantaneous protection 67N unit 2 |
| 19 | Delayed protection 67N unit 2 |
| 20 | Instantaneous protection 67 unit 1 |
| 21 | Delayed protection 67 unit 1 |
| 22 | Instantaneous protection 67 unit 2 |
| 23 | Delayed protection 67 unit 2 |
| 24 | Instantaneous V_DECL logic equation |

General parameters

These settings are read accessible only.

Function number: D002

| Setting | Data | Format/Unit | |
|---------|--|--|---------------------------|
| 1 | Working language | 1: English | 2: other |
| 2 | Rated frequency | 50, 60 (Hz) | |
| 3 | Active group of settings | 1: group A | 2: group B |
| | | 3: selection by logic input | |
| | | 4: selection by remote control | |
| 4 | Demand-value integration period | 5, 10, 15, 30, 60 minutes | |
| 5 | Type of cubicle | 1: incomer | 2: feeder |
| 6 | Active-energy increment | 100 to 5000000 (W) | |
| 7 | Reactive-energy increment | 100 to 5000000 (var) | |
| 8 | Phase-rotation direction | 1: direction 123 | 2: direction 132 |
| 9 | Temperature unit | 1: °C | 2: °F |
| 10 | Remote-setting authorization | 1: no | 2: yes |
| 11 | Time synchronization mode | 1: COM1 port | 2: COM2 port |
| | | 3: input I103 | 5: none |
| | | 6: Ethernet port | |
| 12 | Remote-control mode | 1: SBO mode | 2: direct mode |
| 13 | Reserved | | |
| 14 | Monitoring of auxiliary power | 1: inactive | 2: active |
| 15 | Rated auxiliary voltage | 24 to 250 (V DC) | |
| 16 | Aux. voltage alarm low set point | % rated Vaux, min. 20 V | |
| 17 | Aux. voltage alarm high set point | % rated Vaux, max. 275 V | |
| 18 | Logic inputs ignored on loss of Vaux | 1: inactive | 2: active |
| 19 | Base current I _b | 0.2 to 1.3 I _n (A) | |
| 20 | Rated current I _n | 1 to 15 kA | |
| 21 | Number of phase CTs | 1: 2 CTs | 2: 3 CTs |
| 22 | Phase CT rating | 1: 1 A | 2: 5 A |
| | | 3: LPCT | |
| 23 | Rated residual current I _{n0} | 10 to 150000 (0.1 A) | |
| 24 | Residual current measurement mode | 1: CSH 2 A | 3: CSH 20 A |
| | | 4: 1 A CT | 6: 5 A CT |
| | | 8: ACE 990 range 1 | |
| | | 9: ACE990 range 2 | |
| | | 11: not measured | |
| 25 | Reserved | | |
| 26 | Rated primary voltage U _{np} | 0 A<I _n 6.25 kA: 220 V U _{np} 250 kV 6.25 kA<I _n 15 kA: 220V U _{np} 20 kV | |
| 27 | Rated secondary voltage U _{ns} | 90 to 230 (V) | |
| 28 | VT wiring | 1: 3 V, 2: 2 U, 3: 1 U, 4: 1 V | |
| 29 | Residual voltage mode | 1: none | 2: Σ3V |
| | | 3: VT U _{ns} /√3 | 4: VT U _{ns} /3 |
| 30 | Neutral-point residual voltage measurement | 1: none | 2: present |
| 31 | Neutral-point rated voltage U _{np} | 220 to 250000 (V) | |
| 32 | Neutral-point rated voltage U _{ns} | 57 V to 133 V | |
| 33 | Reserved | | |
| 34 | Reserved | | |
| 35 | Additional rated current I' _n | 1 to 15 kA | |
| 36 | Number of additional phase CTs | 1: 2 CTs | 2: 3 CTs |
| | | 3: none | |
| 37 | Additional phase CT rating | 1: 1 A | 2: 5 A |
| | | 3: LPCT | |
| 38 | Additional rated residual current I' _{n0} | 10 to 150000 (0.1 A) | |
| 39 | Additional residual current measurement mode | Idem 24 | |
| 40 | Reserved | | |
| 41 | Rated primary voltage U' _{np} | 0 A<I' _n 6.25 kA: 220 V U' _{np} 250 kV 6.25 kA<I' _n 15 kA: 220V U' _{np} 20 kV | |
| 42 | Rated secondary voltage U' _{ns} | 90 to 230 (V) | |
| 43 | VT wiring, additional channels | 1: 3 V, 2: 2 U, 3: 1 U, 4: 1 V | |
| 44 | Residual voltage mode, additional channels | 1: none | 2: Σ3V |
| | | 3: VT U' _{ns} /√3 | 4: VT U' _{ns} /3 |
| 45 | Reserved | | |
| 46 | Reserved | | |
| 47 | Reserved | | |
| 48 | Reserved | | |

Application-specific parameters

These settings are read accessible only.

Function number: D003

| Setting | Data | Format/Unit |
|---------|---|--|
| 1 | Transformer presence | 1: no 2: yes |
| 2 | Voltage winding 1 Un1 | 220 to 250000 V |
| 3 | Voltage winding 2 Un2 | 220 to 440000 V |
| 4 | Power S | 100 to 999000 kVA |
| 5 | Vector shift | 0 to 11 |
| 6 | Rated motor speed | 100 to 3000 rpm ⁽¹⁾ 100 to 3600 rpm ⁽²⁾ |
| 7 | Number of pulses per rotation | 1 to 1800 |
| 8 | Zero speed threshold | 5 to 20% |
| 9 | Number of capacitor steps | 1 to 4 |
| 10 | Type of capacitor step connection | 0: delta 1: star |
| 11 | Weight of capacitor step 1 | 1 |
| 12 | Weight of capacitor step 2 | 1, 2 |
| 13 | Weight of capacitor step 3 | 1, 2, 3, 4 |
| 14 | Weight of capacitor step 4 | 1, 2, 3, 4, 6, 8 |
| 15 | Rated power | kW |
| 16 | Synchronous reactance of d axis | 0,1 % |
| 17 | Transient reactance of d axis | 0,1 % |
| 18 | Synchronous reactance of q axis | 0,1 % |
| 19 | Moment of inertia for turbine + generator or motor + load | Kg.m ² |

⁽¹⁾ For a frequency of 50 Hz.

⁽²⁾ For a frequency of 60 Hz.

Schneider Electric Industries SAS

35, rue Joseph Monier
CS 30323
F - 92506 Rueil-Malmaison Cedex
RCS Nanterre 954 503 439
Share capital 896 313 776 €
www.schneider-electric.com

As standards, specifications and designs change from time to time, please ask for confirmation of the information given in this publication.



Printed on recycled paper.

Production: Schneider Electric
Publication: Schneider Electric
Printed: