
# CAT. NO. HRK4060

QTY. 1 SERIES D2

CONTAINS THREE FUSE ADAPTERS TO REJECT FUSES OTHER THAN CLASS R. **ONE PER FUSE.**

**CAUTION:** Turn switch "OFF" and disconnect power AHEAD of switch before installing fuse adapter kit.

**ATTENTION:** Placer l'interrupteur a hors et couper son alimentation avant de poser les adaptateurs.




1. Insert long pin through hole in load side fuse clip, and then through collar.
2. Push collar FIRMLY onto pin. Pliers will be required. Collar should not be removable once properly installed.

BE CAREFUL NOT TO BREAK ADJACENT MOLDED INSULATORS WHEN INSTALLING ADAPTER KIT.

01109

7 85901 01109 5

SQUARE D COMPANY

Plant 15 40283-604-01

Made in U.S.A.